

**RETEST OF
LEAD IN DRINKING WATER SAMPLING**

Of

Pittsburgh Public Schools

Survey Date: August 9 - 23, 2016

Prepared for:

Pittsburgh Public Schools
Facilities
1305 Muriel Street
Pittsburgh, Pennsylvania 15203

Prepared By:



207 Pine Creek Road
Wexford, PA 15090

TABLE OF CONTENTS

1. INTRODUCTION	1
2. SAMPLING METHODOLOGY	1
3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION.....	2
4. RECOMENDATIONS.....	9
REPORT DISCLAIMER:	10

APPENDIX A DRINKING WATER RESULTS TABLES

APPENDIX B LABORATORY RESULTS

APPENDIX C FACILITY MAPS

1. INTRODUCTION

AGX, Inc. was retained by Pittsburgh Public School District to perform follow-up testing of drinking water and cooking use fixtures and faucets for the presence of lead.

Re-testing and fixture verification were conducted at twenty-four (24) facility buildings from August 8 - 23, 2016. The objective of the testing was to screen the drinking water and cooking use fixtures and faucets that previously exceeded the EPA Publications lead concentrations at or above 20 parts per billion (ppb), and newly installed water fountain bottle filling stations.

2. SAMPLING METHODOLOGY

Sample collection, delivery and analysis were conducted according to EPA's "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002", April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance", October 2006. As per 3Ts, the EPA recommends that if lead is found in any water outlet at levels above 20 parts per billion (ppb), action should be taken to reduce the lead in water concentration.

All designated cold water drinking and cooking use fixtures were tested for lead concentrations. Drinking water and cooking fixtures were defined as classroom faucets, home economic faucets, ice machines, kitchen faucets, cafeteria faucets, nurse's office sink faucets, office sink faucets, teacher's lounge sinks, water fountains and miscellaneous sinks found in classrooms and offices. All samples were collected in 250 mL plastic containers that were prepackaged by the analytical laboratory. At each sample location, a first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than eighteen hours. A second draw sample was collected after the water in the system was discharged for thirty (30) seconds. All samples were analyzed by RJ Lee, Inc., 350 Hochberg Road, Monroeville, PA 15146, an independent PA certified laboratory.

3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION

Drinking water was tested for lead in twenty-four (24) facility buildings and schools. A total of thirty-five (35) samples were collected from thirty-one (31) drinking water and cooking use fixtures and faucets, which exceeded the EPA recommended lead in drinking water concentration of 20 parts per billion (ppb) during initial sampling. The results of the sampling showed reduced lead concentrations to below 20 parts per billion (ppb) in twenty-four (24) of the thirty-one (31) retested fixtures.

A total of twenty-one (21) samples were collected, and twenty-one (21) new drinking fountains with bottle filling stations. All twenty-one (21) of the newly installed drinking fountains with bottle fill stations results were below the limit of detection, which is less than 1.00 ppb.

Analytic results were received by AGX and reviewed in relation to EPA's "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002", April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance", October 2006. Based on the EPA Publications lead concentrations at or above 20 parts per billion (ppb) were considered to be elevated. The low percentage and isolated fixtures with lead concentrations at or above 20 ppb indicated that there were no source water or facility wide lead concerns. Corrective actions, which included the removal from service or labeling of any fixture that exceeded the recommended action level of 20 parts per billion (ppb), were conducted.

Brookline:

At Pittsburgh Brookline K-8 a total of eighty-eight (88) samples were collected from forty-four (44) drinking water and cooking use fixtures and faucets on June 21, 2016. One (1) sample (BRO-01-CF-77) collected was above the EPA lead in drinking water action level of 20 ppb.

On August 9, 2016 the elevated fixture (BRO-01-CF-77) was resampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Carrick:

At Pittsburgh Carrick High School a total of one hundred and fifty-eight (158) samples were collected from eighty-one (81) drinking water and cooking use fixtures and faucets on July 6, 2016. One (1) sample (CAR-02-NF-172) collected was above the EPA lead in drinking water action level of 20 ppb.

On August 9, 2016 the elevated fixture (CAR-02-NF-172) was resampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Chartiers:

At Pittsburgh Chartiers ECC a total of thirty-four (34) samples were collected from eighteen (18) drinking water and cooking use fixtures and faucets on June 14, 2016. One (1) sample (CHA-01-WO-17) collected was above the EPA lead in drinking water action level of 20 ppb.

On August 11, 2016 the elevated fixture (CHA-01-WO-17) and the newly installed drinking water bottle fill stations (CHA-01-WFC-13 and CHA-01-WFC-24) were sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Crescent:

At Pittsburgh Crescent ECC a total of fifty four (54) samples were collected from twenty eight (28) drinking water and cooking use fixtures and faucets on June 17, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

On August 10, 2016 the newly installed drinking water bottle fill station (CRE-01-WFC-10) was sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Cupples Stadium:

At Pittsburgh Cupples Stadium, a total of thirty-six (36) samples were collected from twenty-one (21) drinking water and cooking use fixtures and faucets on July 8, 2016. Two (2) samples (CUP-GF-WO-65 AND CUP-GF-WO-66) collected were above the EPA lead in drinking water action level of 20 ppb.

On August 9, 2016 the elevated fixtures (CUP-GF-WO-65 and CUP-GF-WO-66) and the newly installed drinking water bottle fill station (CUP-GF-WFC-34) were sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Greenfield:

At Pittsburgh Greenfield PreK-8 a total of fifty-three (53) samples were collected from twenty-eight (28) drinking water and cooking use fixtures and faucets on June 16, 2016. One (1) sample (GRE-01-CF-9) collected was above the EPA lead in drinking water action level of 20 ppb.

On August 9, 2016 the elevated fixture (GRE-01-CF-9) was resampled. Sample (GRE-01-CF-9) collected was above the EPA lead in drinking water action level of 20 ppb

King:

At Pittsburgh King PreK-8 a total of one hundred ninety-two (192) samples were collected from ninety-seven (97) drinking water and cooking use fixtures and faucets on June 21, 2016. Two (2) samples (KIN-02-TF-64 and KIN-01-MS-29) collected were above the EPA lead in drinking water action level of 20 ppb.

On August 23, 2016 the elevated fixture (KIN-02-TF-64 and KIN-01-MS-29) were resampled. Sample (KIN-02-TF-64) collected was above the EPA lead in drinking water action level of 20 ppb

Langley:

At Pittsburgh Langley K-8, a total of one hundred and twenty-seven (127) samples were collected from sixty-five (65) drinking water and cooking use fixtures and faucets on July 8, 2016. Eight (8) samples (LAN-01-CF-151, LAN-01-CF-157, LAN-01-CF-170, LAN-01-CF-274, LAN-02-CF-217, LAN-01-MS-136, LAN-02-WC-271 and LAN-02-WC-272) collected were above the EPA lead in drinking water action level of 20 ppb.

On August 11, 2016 the elevated fixtures (LAN-01-CF-151, LAN-01-CF-157, LAN-01-CF-170, LAN-01-CF-274, LAN-02-CF-217, LAN-01-MS-136,) and the newly installed drinking water bottle fill stations (LAN-01-WFC-140, LAN-01-WFC-197) were sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb. Drinking water fountains (LAN-02-WC-271 and LAN-02-WC-272) were removed.

Linden:

At Pittsburgh Linden K-5 a total of forty-six (46) samples were collected from twenty-four (24) drinking water and cooking use fixtures and faucets on June 24, 2016. Three (3) samples (LND-BS-CF-8, LND-BS-MS-19 and LND-BS-CF-56) collected were above the EPA lead in drinking water action level of 20 ppb.

On August 10, 2016 the elevated fixtures (LND-BS-CF-8, LND-BS-MS-19 and LND-BS-CF-56) and the newly installed drinking water bottle fill station (LND-BS-WFC-18) were sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Manchester:

At Pittsburgh Manchester PreK-8 a total of eighty (80) samples were collected from forty one (41) drinking water and cooking use fixtures and faucets on June 17, 2016. Two (2) samples (MAN-01-CF-39 and MAN-02-CF-66) collected were above the EPA lead in drinking water action level of 20 ppb.

On August 11, 2016 the elevated fixtures (MAN-01-CF-39 and MAN-02-CF-66) were sampled. Samples (MAN-01-CF-39 and MAN-02-CF-66) collected were above the EPA lead in drinking water action level of 20 ppb

Milliones:

At Pittsburgh Milliones 6-12 a total of fifty-seven (57) samples were collected from thirty (30) drinking water and cooking use fixtures and faucets on June 25, 2016. One (1) sample (MLO-02-NF-3) collected was above the EPA lead in drinking water action level of 20 ppb.

On August 12, 2016 the elevated fixture (MLO-02-NF-3) and the newly installed drinking water bottle fill station (MLO-02-WFC-09) were sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Morrow:

At Pittsburgh Morrow PreK-8 a total of eighty-eight (88) samples were collected from thirty-five (35) drinking water and cooking use fixtures and faucets on June 15, 2016. Three (3) samples (MOR-01-CF-38, MOR-01-WO-66 and MOR-02-OF-55) collected were above the EPA lead in drinking water action level of 20 ppb.

On August 11, 2016 the elevated fixtures (MOR-01-CF-38, MOR-01-WO-66 and MOR-02-OF-55) and the newly installed drinking water bottle fill station (MOR-BS-WFC-18) were sampled. Samples (MOR-01-CF-38 and MOR-02-OF-55) collected were above the EPA lead in drinking water action level of 20 ppb. Drinking water fountain (MOR-01-WO-66) was removed.

Morrow Rooney:

At Pittsburgh Morrow (Rooney) a total of fifty-seven (57) samples were collected from thirty (30) drinking water and cooking use fixtures and faucets on June 30, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

On August 11, 2016 the newly installed drinking water bottle fill station (MRN-BS-WFC-12) was sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Perry:

At Pittsburgh Perry High School a total of ninety-nine (99) samples were collected from fifty-two (52) drinking water and cooking use fixtures and faucets on July 7, 2016. Two (2) samples (PER-03-CF-134 and PER-BS-MS-4) collected were above the EPA lead in drinking water action level of 20 ppb.

On August 11, 2016 the elevated fixtures (PER-03-CF-134 and PER-BS-MS-4) and the newly installed drinking water bottle fill station (PER-03-WFC-157) were sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Pioneer:

At Pittsburgh Pioneer a total of fifty-six (56) samples were collected from twenty-nine (29) drinking water and cooking use fixtures and faucets on June 29, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

On August 9, 2016 the newly installed drinking water bottle fill station (PIO-01-WFC-22) was sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

South Annex:

At Pittsburgh South Annex (Online) a total of twenty (20) samples were collected from eleven (11) drinking water and cooking use fixtures and faucets June 28, 2016. Four (4) samples (SOU-01-CF-2, SOU-01-CF-3, SOU-01-CF-5 and SOU-01-WO-41) collected were above the EPA lead in drinking water action level of 20 ppb.

On August 12, 2016 the newly installed drinking water bottle fill station (SOU-02-WFC-15) was sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb. Fixtures (SOU-01-CF-2, SOU-01-CF-3, SOU-01-CF-5 and SOU-01-WO-41) were disconnected.

South Brook:

At Pittsburgh South Brook a total of forty-seven (47) samples were collected from twenty-four (24) drinking water and cooking use fixtures and faucets June 29, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

On August 9, 2016 the newly installed drinking water bottle fill station (SBK-02-WFC-81) was sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Sterrett:

At Pittsburgh Sterrett 6-8 a total of fifty-four (54) samples were collected from twenty-eight (28) drinking water and cooking use fixtures and faucets June 30, 2016. One (1) sample (STE-02-TF-75) collected was above the EPA lead in drinking water action level of 20 ppb.

On August 10, 2016 the elevated fixture (STE-02-TF-75) and the newly installed drinking water bottle fill station (STE-01-WFC-46) were sampled. Sample (STE-02-TF-75) collected was above the EPA lead in drinking water action level of 20 ppb.

Sunnyside:

At Pittsburgh Sunnyside PreK-8 a total of eighty-two (82) samples were collected from forty-two (42) drinking water and cooking use fixtures and faucets June 17, 2016. One (1) sample (SUN-01-CF-63) collected was above the EPA lead in drinking water action level of 20 ppb.

On August 10, 2016 the elevated fixture (SUN-01-CF-63) and the newly installed drinking water bottle fill station (SUN-01-WFC-55) were sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Weil:

At Pittsburgh Weil PreK-5 a total of sixty-four (64) samples were collected from thirty-three (33) drinking water and cooking use fixtures and faucets June 17, 2016. One (1) sample (WEI-02-CF-45) collected was above the EPA lead in drinking water action level of 20 ppb.

On August 12, 2016 the elevated fixture (WEI-02-CF-45) and the newly installed drinking water bottle fill station (WEI-01-WFC-9, WEI-01-WFC-18 and WEI-02-WFC-38) were sampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

West Liberty:

At Pittsburgh West Liberty K-5 a total of forty-four (44) samples were collected from twenty-three (23) drinking water and cooking use fixtures and faucets on June 29, 2016. Two (2) samples (WLB-01-NF-15 and WLB-02-CF-49) collected were above the EPA lead in drinking water action level of 20 ppb.

On August 9, 2016 the elevated fixture (WLB-02-CF-49) was resampled along with the new drinking fountain bottle filling station (WLB-02-WFC-34). No samples collected were above the EPA lead in drinking water action level of 20 ppb. Fixture (WLB-01-NF-15) was removed.

Westinghouse:

At Pittsburgh Westinghouse 6-12 a total of one hundred twenty-eight (128) samples were collected from sixty-nine (69) drinking water and cooking use fixtures and faucets June 14, 2016. Two (2) samples (WES-01-MS-206 and WES-GF-NF-106) collected were above the EPA lead in drinking water action level of 20 ppb.

On August 10, 2016 the elevated fixtures (WES-01-MS-206 and WES-GF-NF-106) were resampled along with the new drinking fountain bottle filling station (WES-01-WFC-199). No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Westinghouse Field House:

At Pittsburgh Westinghouse Field House a total of eleven (11) samples were collected from seven (7) drinking water and cooking use fixtures and faucets June 14, 2016. One (1) sample (WFH-GF-MS-10) collected was above the EPA lead in drinking water action level of 20 ppb.

On August 10, 2016 the elevated fixture (WFH-GF-MS-10) was resampled. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

Table 1: Retested facility drinking water and cooking use fixtures and faucets that exceeded the EPA recommended concentration of lead in water during initial sampling, number of newly installed drinking fountains with bottle fill stations sampled along with total number of drinking water samples obtained on August 9-23, 2016.

School/Building	Date Sampled	Total # of Fixtures Retested	# of Drinking Fountains w/ Bottle Fill Stations Tested	# Samples Collected
Pittsburgh Brookline K-8	8/9/2016	1	0	1
Pittsburgh Carrick High School	8/9/2016	1	0	1
Pittsburgh Chartiers ECC	8/11/2016	1	2	3
Pittsburgh Crescent ECC	8/10/2016	0	1	1
Pittsburgh Cupples Stadium	8/9/2016	2	1	3
Pittsburgh Greenfield PreK-8	8/9/2016	1	0	1
Pittsburgh King PreK-8	8/23/2016	2	0	6
Pittsburgh Langley K-8	8/11/2016	6	2	8
Pittsburgh Linden K-5	8/10/2016	3	1	4
Pittsburgh Manchester PreK-8	8/11/2016	2	0	2
Pittsburgh Milliones 6-12	8/12/2016	1	1	2
Pittsburgh Morrow PreK-5	8/11/2016	2	1	3
Pittsburgh Morrow Rooney	8/11/2016	0	1	1
Pittsburgh Perry High School	8/11/2016	2	1	3
Pittsburgh Pioneer	8/9/2016	0	1	1
Pittsburgh South Annex (Online)	8/12/2016	0	1	1
Pittsburgh South Brook 6-8	8/9/2016	0	1	1

School/Building	Date Sampled	Total # of Fixtures Retested	# of Drinking Fountains w/ Bottle Fill Stations Tested	# Samples Collected
Pittsburgh Sterrett 6-8	8/10/2016	1	1	2
Pittsburgh Sunnyside PreK-8	8/10/2016	1	1	2
Pittsburgh Weil PreK-5	8/12/2016	1	3	4
Pittsburgh West Liberty K-5	8/9/2016	1	1	2
Pittsburgh Westinghouse 6-12	8/10/2016	2	1	3
Pittsburgh Westinghouse Field House	8/10/2016	1	0	1

4. RECOMMENDATIONS

1. All drinking water sources that exceed the “3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance”, October 2006 recommended lead concentration of 20 parts per billion (ppb) or greater should be remediated to reduce lead concentrations. Remediation may include but not be limited to posting signs indicating “not for drinking”, cleaning fixtures, replace individual fixtures with lead free fixtures, replace the system or plumbing (lead solder joints or brass) with lead free materials, point of source filters and/or disabling fixtures. The remediation action will depend on the fixture and circumstances involved. Following remediation efforts before any drinking water source is placed back into service the fixture should be re-tested to ensure the lead level was reduced below the recommended lead concentration of 20 parts per billion (ppb).
2. Signs stating “Hand Wash Only” or “Not for Drinking” should be posted at designated non-drinking water sources (restrooms, science labs, utility sinks, wash sinks, etc.).
3. A procedure should be devised to inform staff of best drinking water practices, which should include but not be limited to:
 - a. Staff and students should refrain from using classroom faucets for drinking water. Instead they should be encouraged to use designated water fountains, bottle fill stations, kitchen faucets and teachers’ lounge sinks.
 - b. Prior to drinking, water should be run for one minute or until the water runs cold.
 - c. Only use cold water for drinking and cooking.

4. Following any break longer than five days the water in the facility should be run through non-filtered drinking water sources to ensure stagnant water has been moved through the plumbing. It is recommended that flushing directions provided by EPA's "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002", April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance", October 2006 be followed.
5. A procedure should be devised to routinely clean drinking water sources and distribution piping. Cleaning should include but not be limited to ensuring fixtures are free from debris, drain properly, aerators (screens) are clean and free from debris, and filters changed in accordance with the manufactures guidelines.

REPORT DISCLAIMER:

This AGX, Inc. report is based on information supplied by the client, occupants and on conditions readily observable or measurable on the date or dates of this study. The results and recommendations presented herein should not be relied upon exclusively for the prevention of all possible illnesses, injuries, or losses. These services are a supplement to, and not a substitute for, the client's responsibility for protecting the health and safety of the occupants of the facility, and others, and for complying with applicable laws and regulations.

This report and the associated attachments and appendices have been produced and developed for, and at the request of, Pittsburgh Board of Public Education. It conveys the findings of AGX as of the date(s) noted herein. This report is intended for the exclusive use of Pittsburgh Board of Public Education (including its management, officers and the School Board).

APPENDIX A

DRINKING WATER RESULTS TABLES

Pittsburgh Brookline K-8

Drinking Water Sample Results

School: Pittsburgh Brookline K-8

Address: 500 Woodbourne Avenue, Pittsburgh PA, 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (Fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
BRO-GF-SL-00	SL	Service Line	15	6/21/2016	0600	P	<1.00									
BRO-GF-WM-00	WM	Water Main	15	6/21/2016	0603	P	1.00									
BRO-GF-KF-6	KF	Kitchen faucets	3D	6/21/2016	0613	P	1.17	P	1.01							
BRO-GF-WC-17	WC	Water fountain with cooler	CORR 1A	6/21/2016												Removed
BRO-GF-WC-18	WC	Water fountain with cooler	CORR 1A	6/21/2016												Removed
BRO-GF-CF-24	CF	Classroom faucets	DEMOUNTABLE CL	6/21/2016	0828	P	2.01	P	<1.00							
BRO-GF-CF-27	CF	Classroom faucets	ANNEX BUILDING	6/21/2016	0837	P	3.71	P	<1.00							
BRO-01-WC-32	WC	Water fountain with cooler	CORR 100	6/21/2016	0638	P	<1.00	P	<1.00							
BRO-01-WC-33	WC	Water fountain with cooler	CORR 100	6/21/2016	0639	P	<1.00	P	<1.00							
BRO-01-WC-43	WC	Water fountain with cooler	CORR 100B	6/21/2016	0709	P	<1.00	P	<1.00							
BRO-01-WC-44	WC	Water fountain with cooler	CORR 100B	6/21/2016	0710	P	<1.00	P	<1.00							
BRO-02-TF-48	TF	Teacher's lounge sinks	216	6/21/2016	0722	P	1.03	P	<1.00							
BRO-02-WC-49	WC	Water fountain with cooler	CORR 200	6/21/2016	0728	P	<1.00	P	<1.00							
BRO-02-WC-50	WC	Water fountain with cooler	CORR 200	6/21/2016	0729	P	<1.00	P	<1.00							
BRO-02-NF-57	NF	Nurse's office sink faucets	219	6/21/2016	0727	P	2.40	P	<1.00							
BRO-02-WC-64	WC	Water fountain with cooler	CORR 200B	6/21/2016	0754	P	<1.00	P	<1.00							
BRO-02-WC-65	WC	Water fountain with cooler	CORR 200B	6/21/2016	0755	P	<1.00	P	<1.00							
BRO-02-CF-66	CF	Classroom faucets	213	6/21/2016	0752	P	7.56	P	<1.00							
BRO-GF-CF-71	CF	Classroom faucets	11F	6/21/2016	0626	P	1.31	P	1.33							
BRO-GF-CF-72	CF	Classroom faucets	11	6/21/2016	0630	P	1.77	P	1.43							
BRO-01-CF-73	CF	Classroom faucets	103	6/21/2016	0643	P	2.20	P	<1.00							
BRO-01-WC-74	WC	Water fountain with cooler	CORR 100A	6/21/2016	0649	P	<1.00	P	<1.00							
BRO-01-WC-75	WC	Water fountain with cooler	CORR 100A	6/21/2016	0650	P	<1.00	P	<1.00							
BRO-01-CF-76	CF	Classroom faucets	104A	6/21/2016	0655	P	7.24	P	2.19							
BRO-01-CF-77	CF	Classroom faucets	107A	6/21/2016	0658	P	8.22	F	32.5	8/9/2016	0632	P	<1.00			
BRO-01-CF-78	CF	Classroom faucets	105A	6/21/2016	0703	P	4.66	P	3.42							
BRO-01-CF-79	CF	Classroom faucets	106A	6/21/2016	0706	P	7.18	P	1.03							
BRO-01-MS-80	MS	Miscellaneous sinks	115	6/21/2016	0715	P	1.51	P	<1.00							
BRO-02-WC-81	WC	Water fountain with cooler	200A	6/21/2016	0733	P	1.78	P	2.84							
BRO-02-WC-82	WC	Water fountain with cooler	200A	6/21/2016	0734	P	2.49	P	1.99							
BRO-02-CF-83	CF	Classroom faucets	206A	6/21/2016	0741	P	1.54	P	<1.00							
BRO-02-CF-84	CF	Classroom faucets	205A	6/21/2016	0744	P	6.46	P	1.13							
BRO-GF-WO-85	WO	Water fountain without cooler	DEMOUNTABLE CL	6/21/2016	0829	P	1.63	P	<1.00							
BRO-GF-CF-86	CF	Classroom faucets	DEMOUNTABLE CL	6/21/2016	0832	P	1.01	P	<1.00							
BRO-GF-WO-87	WO	Water fountain without cooler	DEMOUNTABLE CL	6/21/2016	0833	P	6.84	P	<1.00							
BRO-GF-WO-88	WO	Water fountain without cooler	ANNEX BUILDING	6/21/2016	0838	P	<1.00	P	<1.00							
BRO-GF-CF-89	CF	Classroom faucets	ANNEX BUILDING	6/21/2016	0841	P	4.36	P	<1.00							
BRO-GF-WO-90	WO	Water fountain without cooler	ANNEX BUILDING	6/21/2016	0842	P	1.00	P	1.70							
BRO-GF-WC-91	WC	Water fountain with cooler	CORR 1	6/21/2016	0606	P	<1.00	P	<1.00							
BRO-GF-WC-92	WC	Water fountain with cooler	CORR 1	6/21/2016	0607	P	<1.00	P	<1.00							
BRO-GF-CF-93	CF	Classroom faucets	13	6/21/2016	0617	P	1.27	P	<1.00							
BRO-GF-MS-94	MS	Miscellaneous sinks	11B	6/21/2016	0621	P	1.73	P	1.43							
BRO-GF-CF-95	CF	Classroom faucets	11F	6/21/2016	0625	P	1.92	P	1.32							
BRO-02-CF-96	CF	Classroom faucets	213	6/21/2016	0753	P	8.43	P	<1.00							
BRO-GF-KF-97	KF	Kitchen faucets	3D	6/21/2016	0612	P	1.05	P	<1.00							
BRO-GF-SL-98	SL	Service Line	STREET	6/21/2016	0813	P	1.05									
BRO-GF-WM-98	WM	Water Main	STREET	6/21/2016	0816	P	<1.00									
BRO-02-CF-102	CF	Classroom faucets	203A	6/21/2016												Cold Water Not Functioning

Pittsburgh Carrick High School

Drinking Water Sample Results

School: Pittsburgh Carrick High School

Address: 125 Parkfield Street, Pittsburgh PA, 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
CAR-02-WC-177	WC	Water fountain with cooler	CORR 400	7/6/2016	0842	P	< 1.00	P	< 1.00							
CAR-03-WC-228	WC	Water fountain with cooler	CORR 500	7/6/2016	0854	P	< 1.00	P	< 1.00							
CAR-03-WC-339	WC	Water fountain with cooler	CORR 500	7/6/2016	0855	P	2.57	P	1.23							
CAR-03-WC-340	WC	Water fountain with cooler	CORR 500	7/6/2016	0856	P	< 1.00	P	< 1.00							
CAR-03-MS-354	MS	Miscellaneous sinks	502	7/6/2016	0858	P	< 1.00	P	< 1.00							
CAR-03-TF-355	TF	Teacher's lounge sinks	601	7/6/2016	0902	P	1.52	P	< 1.00							
CAR-03-WC-357	WC	Water fountain with cooler	CORR 600	7/6/2016	0903	P	< 1.00	P	< 1.00							
CAR-03-WC-358	WC	Water fountain with cooler	CORR 600	7/6/2016	0904	P	< 1.00	P	< 1.00							
CAR-03-MS-362	MS	Miscellaneous sinks	613	7/6/2016	0908	P	8.09	P	< 1.00							
CAR-04-TF-366	TF	Teacher's lounge sinks	801	7/6/2016	0915	P	< 1.00	P	< 1.00							
CAR-04-WC-368	WC	Water fountain with cooler	CORR 800	7/6/2016	0917	P	< 1.00	P	< 1.00							
CAR-04-WC-369	WC	Water fountain with cooler	CORR 800	7/6/2016	0918	P	< 1.00	P	1.30							
CAR-B5-MS-375	MS	Miscellaneous sinks	B-6	7/6/2016	0631	P	2.41	P	< 1.00							
CAR-01-WO-376	WO	Water fountain without cooler	701	7/6/2016	0659	P	< 1.00	P	< 1.00							
CAR-01-WO-377	WO	Water fountain without cooler	703	7/6/2016	0655	P	1.77	P	< 1.00							
CAR-03-WC-388	WC	Water fountain with cooler	OUTSIDE 328	7/6/2016	0921	P	1.19	P	< 1.00							
CAR-01-KF-390	KF	Kitchen faucets	226	7/6/2016	0758	P	7.15	P	< 1.00							
CAR-02-CF-393	CF	Classroom faucets	335	7/6/2016	0827	P	< 1.00	P	< 1.00							
CAR-02-CF-394	CF	Classroom faucets	338	7/6/2016	0818	P	< 1.00	P	< 1.00							
CAR-02-CF-395	CF	Classroom faucets	338	7/6/2016	0817	P	< 1.00	P	< 1.00							
CAR-02-WC-396	WC	Water fountain with cooler	418	7/6/2016	0845	P	< 1.00	P	< 1.00							
CAR-02-CF-397	CF	Classroom faucets	418	7/6/2016	0846	P	< 1.00	P	< 1.00							

Pittsburgh Chartiers Early Childhood Center

Lead in Drinking Water Sample Results

School: Pittsburgh Chartiers Early Childhood Center

Address: 3799 Chartiers Avenue Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
CHA-01-WM-00	WM	Water Main	113	6/14/2016	0609	P	< 1.00									
CHA-01-SL-00	SL	Service Line	113	6/14/2016	0606	P	< 1.00									
CHA-01-CF-1	CF	Classroom faucets	105	6/14/2016	0620	P	1.85	P	< 1.00							
CHA-01-WO-3	WO	Water fountain without cooler	101	6/14/2016	0624	P	3.54	P	1.11							
CHA-01-CF-4	CF	Classroom faucets	101	6/14/2016	0625	P	< 1.00	P	< 1.00							
CHA-01-WO-5	WO	Water fountain without cooler	Cor 100	6/14/2016	0604	P	1.71	P	< 1.00							
CHA-01-NF-11	NF	Nurse's office sink faucets	102	6/14/2016	0616	P	6.13	P	2.24							
CHA-01-WFC-13	WFC	Water Filtering Chiller	Cor 100	6/14/2016	0613	P	1.72	P	1.01	8/11/2016	0608			P	<1.00	Water Filtering Chiller with Bottle Filler
CHA-01-KF-15	KF	Kitchen faucets	121-B	6/14/2016	0632	P	< 1.00	P	< 1.00							
CHA-01-WO-16	WO	Water fountain without cooler	121	6/14/2016	0635	P	3.23	P	1.35							
CHA-01-WFC-17	WFC	Water Filtering Chiller	121	6/14/2016	0638	F	34.6	P	11.5	8/11/2016	0604			P	<1.00	Water Filtering Chiller with Bottle Filler
CHA-01-TF-23	TF	Teacher's lounge sinks	124	6/14/2016	0646	P	4.13	P	1.04							
CHA-01-WFC-24	WFC	Water Filtering Chiller	ENTRY 101A	6/14/2016	0641	P	4.01	P	1.95	8/11/2016	0600			P	<1.00	Water Filtering Chiller with Bottle Filler
CHA-01-WO-25	WO	Water fountain without cooler	ENTRY 101A	6/14/2016	0642	P	1.62	P	1.44							
CHA-01-CF-31	CF	Classroom faucets	202	6/14/2016	0651	P	2.43	P	1.32							
CHA-01-CF-32	CF	Classroom faucets	201	6/14/2016	0648	P	12.9	P	4.02							
CHA-01-CF-33	CF	Classroom faucets	204	6/14/2016	0654	P	5.32	P	1.17							
CHA-01-CF-34	CF	Classroom faucets	206	6/14/2016	0656	P	1.37	P	< 1.00							

Pittsburgh Crescent Early Childhood Center

Drinking Water Sample Results

School: Pittsburgh Crescent Early Childhood Center Address: 8080 Bennett Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
CRE-BS-SL-00	SL	Service Line	Boiler Rm	6/17/2016	0602	P	2.00									
CRE-BS-WM-00	WM	Water Main	Boiler Rm	6/17/2016	0606	P	3.11									
CRE-BS-WC-1	WC	Water fountain with cooler	Corridor 9	6/17/2016	0600	P	14.2	P	6.63							
CRE-01-WO-8	WO	Water fountain without cooler	Corridor 100	6/17/2016	0623	P	1.05	P	<1.00							
CRE-01-WC-9	WC	Water fountain with cooler	Corridor 100	6/17/2016	0624	P	<1.00	P	<1.00							
CRE-01-WFC-10	WFC	Water Filtering Chiller	Corridor 100	6/17/2016	0635	P	1.20	P	<1.00	8/10/2016	0604			P	<1.00	Water Filtering Chiller with Bottle Filler
CRE-01-WC-11	WC	Water fountain with cooler	Corridor 100	6/17/2016	0637	P	<1.00	P	<1.00							
CRE-01-CF-15	CF	Classroom faucets	115	6/17/2016	0643	P	<1.00	P	1.54							
CRE-01-CF-16	CF	Classroom faucets	115	6/17/2016	0644	P	<1.00	P	<1.00							
CRE-01-CF-20	CF	Classroom faucets	105	6/17/2016	0617	P	<1.00	P	<1.00							
CRE-01-CF-23	CF	Classroom faucets	101	6/17/2016	0649	P	1.67	P	<1.00							
CRE-01-CF-24	CF	Classroom faucets	101	6/17/2016	0650	P	1.67	P	<1.00							
CRE-01-KF-28	KF	Kitchen faucets	Lobby	6/17/2016	0656	P	1.61	P	<1.00							
CRE-02-WO-34	WO	Water fountain without cooler	Corridor 200	6/17/2016	0700	P	1.25	P	<1.00							
CRE-02-WC-35	WC	Water fountain with cooler	Corridor 200	6/17/2016	0702	P	<1.00	P	<1.00							
CRE-02-CF-36	CF	Classroom faucets	Library	6/17/2016	0707	P	1.04	P	<1.00							
CRE-02-WO-37	WO	Water fountain without cooler	Corridor 200	6/17/2016	0704	P	<1.00	P	2.65							
CRE-02-WC-38	WC	Water fountain with cooler	Corridor 200	6/17/2016	0705	P	<1.00	P	<1.00							
CRE-02-CF-42	CF	Classroom faucets	207	6/17/2016	0710	P	3.20	P	<1.00							
CRE-03-WO-47	WO	Water fountain without cooler	Corridor 300	6/17/2016	0740	P	<1.00	P	<1.00							
CRE-03-WC-48	WC	Water fountain with cooler	Corridor 300	6/17/2016	0742	P	<1.00	P	<1.00							
CRE-03-CF-49	CF	Classroom faucets	304	6/17/2016	0758	P	3.63	P	1.59							
CRE-03-CF-50	CF	Classroom faucets	303	6/17/2016	0800	P	9.27	P	1.16							
CRE-03-WO-51	WO	Water fountain without cooler	Corridor 300	6/17/2016	0750	P	<1.00	P	<1.00							
CRE-03-WC-52	WC	Water fountain with cooler	Corridor 300	6/17/2016	0752	P	<1.00	P	<1.00							
CRE-02-CF-56	CF	Classroom faucets	207	6/17/2016	0711	P	5.97	P	1.04							
CRE-02-CF-57	CF	Classroom faucets	207	6/17/2016	0715	P	5.48	P	1.40							
CRE-03-CF-58	CF	Classroom faucets	303	6/17/2016	0801	P	<1.00	P	2.98							

Pittsburgh Cupples Stadium

Drinking Water Sample Results

School: Pittsburgh Cupples Stadium

Address: 800 E. Carson Street, Pittsburgh PA, 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
CUP-GF-SL-00	SL	Service Line	STORAGE 102	7/8/2016	0611	P	< 1.00									
CUP-GF-WM-00	WM	Water Main	STORAGE 102	7/8/2016	0614	P	< 1.00									
CUP-GF-WO-1	WO	Water fountain without cooler	MENS RR	7/8/2016	0615	P	8.83	P	1.02							
CUP-GF-WO-4	WO	Water fountain without cooler	WOMENS RR	7/8/2016	0617	P	9.93	P	1.15							
CUP-GF-MS-5	MS	Miscellaneous sinks	FIRST AID	7/8/2016	0609	P	4.66	P	1.09							
CUP-GF-WC-20	WC	Water fountain with cooler	LOCKER ROOM	7/8/2016	0630	P	< 1.00	P	< 1.00							
CUP-GF-IM-21	IM	Ice machines	LOCKER ROOM	7/8/2016												Not functioning
CUP-GF-WC-25	WC	Water fountain with cooler	CORR 109	7/8/2016	0633	P	< 1.00	P	< 1.00							
CUP-GF-IM-31	IM	Ice machines	LOCKER ROOM	7/8/2016												Not functioning
CUP-GF-IM-32	IM	Ice machines	115	7/8/2016	0705	P	< 1.00									
CUP-GF-WFC-34	WFC	Water Filtering Chiller	LOCKER ROOM	7/8/2016	0638	P	< 1.00	P	< 1.00	8/9/2016	0803			P	<1.00	Water Filtering Chiller with Bottle Filler
CUP-GF-WQ-47	WO	Water fountain without cooler	WOMENS RR	7/8/2016	0643	P	5.43	P	3.11							
CUP-GF-WO-50	WO	Water fountain without cooler	MENS RR	7/8/2016	0644	P	8.69	P	8.14							
CUP-DL-MS-53	MS	Miscellaneous sinks	PRESSBOX	7/8/2016	0700	P	3.15	P	< 1.00							
CUP-GF-IM-58	IM	Ice machines	CONCESSION	7/8/2016	0712	P	< 1.00									
CUP-GF-KF-59	KF	Kitchen faucets	CONCESSION	7/8/2016	0710	P	9.74	P	< 1.00							
CUP-GF-KF-60	KF	Kitchen faucets	CONCESSION	7/8/2016	0711	P	11.7	P	< 1.00							
CUP-GF-WO-65	WO	Water fountain without cooler	PUBLIC RR	7/8/2016	0724	F	64.8	F	24.2	8/9/2016	0809	P	<1.00			
CUP-GF-WO-66	WO	Water fountain without cooler	PUBLIC RR	7/8/2016	0725	F	45.1	P	8.14	8/9/2016	0810	P	<1.00			
CUP-GF-KF-71	KF	Kitchen faucets	GROUNDKEEPER	7/8/2016	0636	P	< 1.00	P	< 1.00							
CUP-GF-SL-72	SL	Service Line	PUBLIC RR	7/8/2016	0718	P	4.53									
CUP-GF-WM-73	WM	Water Main	PUBLIC RR	7/8/2016	0721	P	2.67									
CUP-GF-MS-74	MS	Miscellaneous sinks	OUTSIDE STADIUM	8/9/2016	0800	P	4.18	P	<1.00							

Pittsburgh Greenfield PreK-8

Lead in Drinking Water Sample Results

School: Pittsburgh Greenfield PreK-8

Address: 1 Alger Street, Pittsburgh PA, 15207

[illegible]

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (Fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (Bumping) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (E)	Retest First Draw Lead Concentration (ppb)	Comments
KIN-01-SL-0	SL	Service Line	134	6/21/2016	0636	P	2.02													
KIN-01-WM-0	WM	Water Main	134	6/21/2016	0619	P	1.47													
KIN-01-MS-5	MS	Miscellaneous sinks	123	6/21/2016	0631	P	1.69	P	3.03											
KIN-01-CF-6	CF	Classroom faucets	123	6/21/2016	0628	P	1.98	P	1.34											
KIN-01-CF-7	CF	Classroom faucets	119	6/21/2016	0637	P	3.29	P	<1.00											
KIN-01-CF-10	CF	Classroom faucets	111	6/21/2016	0633	P	8.29	P	7.13											
KIN-01-MS-11	MS	Miscellaneous sinks	138	6/21/2016	0644	P	1.94	P	<1.00											
KIN-01-WC-13	WC	Water fountain with cooler	GYM LOBBY	6/21/2016	0620	P	1.21	P	<1.00											
KIN-01-WC-14	WC	Water fountain with cooler	GYM LOBBY	6/21/2016	0620	P	1.30	P	1.17											
KIN-01-WC-15	WC	Water fountain with cooler	GYM LOBBY	6/21/2016	0623	P	<1.00	P	<1.00											
KIN-01-WFC-16	WFC	Water Filtering Chiller	GYM LOBBY	6/21/2016	0624	P	<1.00	P	<1.00	8/11/2016	0615			P	<1.00					Water Filtering Chiller with Bottle Filler
KIN-01-WC-28	WC	Water fountain with cooler	176A	6/21/2016	0657	P	<1.00	P	<1.00											
KIN-01-MS-29	MS	Miscellaneous sinks	180	6/21/2016	0655	F	24	P	10.5	8/11/2016	0612	F	26.4			8/23/2016	0613	P	14.4	
KIN-01-CF-30	CF	Classroom faucets	184	6/21/2016	0649	P	4.67	P	1.64											
KIN-01-WC-31	WC	Water fountain with cooler	CORRIDOR 183	6/21/2016	0650	P	<1.00	P	<1.00											
KIN-01-WC-32	WC	Water fountain with cooler	CORRIDOR 183	6/21/2016	0651	P	<1.00	P	<1.00											
KIN-01-MS-33	MS	Miscellaneous sinks	186	6/21/2016	0634	P	9.70	P	4.18											
KIN-02-WC-44	WC	Water fountain with cooler	223	6/21/2016	0707	P	<1.00	P	<1.00											
KIN-02-WC-45	WC	Water fountain with cooler	223	6/21/2016	0708	P	<1.00	P	<1.00											
KIN-02-WC-48	WC	Water fountain with cooler	221	6/21/2016	0725	P	1.13	P	1.21											
KIN-02-CF-49	CF	Classroom faucets	219																	Not Functioning
KIN-02-CF-50	CF	Classroom faucets	219	6/21/2016	0726	P	5.57	P	4.47											
KIN-02-CF-51	CF	Classroom faucets	217	6/21/2016	0731	P	9.20	P	3.42											
KIN-02-CF-52	CF	Classroom faucets	217	6/21/2016	0732	P	12.1	P	2.86											
KIN-02-KF-55	KF	Kitchen faucets	234	6/21/2016	0706	P	2.32	P	<1.00											
KIN-02-KF-57	KF	Kitchen faucets	OUTSIDE 224	6/21/2016	0707	P	3.92	P	1.66											
KIN-02-WC-58	WC	Water fountain with cooler	223	6/21/2016	0730	P	1.24	P	2.70											
KIN-02-WC-59	WC	Water fountain with cooler	223	6/21/2016	0711	P	<1.00	P	2.59											
KIN-02-MS-60	MS	Miscellaneous sinks	245	6/21/2016	0717	P	2.53	P	1.20											
KIN-02-TF-64	TF	Teacher's lounge sinks	252	6/21/2016	0718	F	46.4	P	5.19	8/11/2016	0610	F	47.6			8/23/2016	0610	F	23.4	
KIN-02-WC-66	WC	Water fountain with cooler	CORR 209	6/21/2016	0748	P	<1.00	P	<1.00											
KIN-02-WC-67	WC	Water fountain with cooler	CORR 209	6/21/2016	0749	P	<1.00	P	<1.00											
KIN-02-WO-69	WO	Water fountain without cooler	OUT MULT. RM 3	6/21/2016	0712	P	1.37	P	<1.00											
KIN-02-WO-75	WO	Water fountain without cooler	OUT MULT. RM 3	6/21/2016																Not Functioning
KIN-02-WC-76	WC	Water fountain with cooler	233	6/21/2016	0715	P	5.87	P	5.16											
KIN-02-WC-77	WC	Water fountain with cooler	CORR 209	6/21/2016																Not Functioning
KIN-02-WC-78	WC	Water fountain with cooler	CORR 209	6/21/2016	0744	P	<1.00	P	<1.00											
KIN-02-CF-80	CF	Classroom faucets	259	6/21/2016	0738	P	15.5	P	4.40											
KIN-02-CF-81	CF	Classroom faucets	259	6/21/2016	0739	P	5.26	P	2.57											
KIN-02-CF-83	CF	Classroom faucets	261	6/21/2016	0740	P	7.74	P	4.53											
KIN-02-CF-84	CF	Classroom faucets	261	6/21/2016	0741	P	12.4	P	3.05											
KIN-02-WC-87	WC	Water fountain with cooler	263	6/21/2016	0746	P	<1.00	P	<1.00											
KIN-02-WC-88	WC	Water fountain with cooler	266	6/21/2016	0747	P	3.08	P	1.08											
KIN-02-CF-91	CF	Classroom faucets	268	6/21/2016	0751	P	4.59	P	4.44											
KIN-02-CF-92	CF	Classroom faucets	270	6/21/2016	0757	P	3.67	P	1.40											
KIN-03-CF-96	CF	Classroom faucets	A1	6/21/2016	0817	P	2.75	P	3.54											
KIN-03-CF-97	CF	Classroom faucets	A2	6/21/2016	0819	P	3.22	P	1.97											
KIN-03-CF-98	CF	Classroom faucets	A3	6/21/2016	0819	P	2.25	P	1.70											
KIN-03-CF-99	CF	Classroom faucets	A4	6/21/2016	0821	P	2.40	P	2.98											
KIN-03-CF-100	CF	Classroom faucets	A6	6/21/2016	0820	P	10.4	P	3.08											
KIN-03-CF-101	CF	Classroom faucets	A7	6/21/2016	0822	P	2.24	P	5.61											
KIN-03-CF-102	CF	Classroom faucets	B1	6/21/2016	0809	P	2.00	P	<1.00											
KIN-03-CF-103	CF	Classroom faucets	B2	6/21/2016	0808	P	5.34	P	7.75											
KIN-03-CF-104	CF	Classroom faucets	B3	6/21/2016	0810	P	4.19	P	1.45											
KIN-03-CF-105	CF	Classroom faucets	B5	6/21/2016	0811	P	5.73	P	1.99											
KIN-03-CF-106	CF	Classroom faucets	B6	6/21/2016	0810	P	6.85	P	1.63											
KIN-03-CF-107	CF	Classroom faucets	B7	6/21/2016	0813	P	7.40	P	3.33											
KIN-03-WC-113	WC	Water fountain with cooler	CORR 335	6/21/2016	0826	P	2.36	P	2.61											
KIN-03-WC-114	WC	Water fountain with cooler	CORR 335	6/21/2016	0827	P	1.48	P	3.16											
KIN-03-CF-126	CF	Classroom faucets	F3	6/21/2016	0830	P	5.49	P	3.48											
KIN-03-CF-127	CF	Classroom faucets	F2	6/21/2016	0829	P	4.63	P	1.08											
KIN-03-CF-128	CF	Classroom faucets	F1	6/21/2016	0831	P	6.26	P	1.16											
KIN-03-WC-129	WC	Water fountain with cooler	CORR 335	6/21/2016	0832	P	1.27	P	<1.00											
KIN-03-WC-130	WC	Water fountain with cooler	CORR 335	6/21/2016	0833	P	<1.00	P	<1.00											
KIN-03-CF-134	CF	Classroom faucets	E1	6/21/2016	0910	P	3.88	P	2.81											
KIN-03-CF-135	CF	Classroom faucets	E2	6/21/2016	0909	P	5.11	P	1.81											
KIN-03-CF-136	CF	Classroom faucets	E3	6/21/2016	0912	P	4.57	P	3.47											
KIN-03-CF-137	CF	Classroom faucets	E5	6/21/2016	0913	P	8.19	P	6.69											
KIN-03-CF-138	CF	Classroom faucets	E6	6/21/2016	0916	P	13.4	P	17.0											
KIN-03-CF-139	CF	Classroom faucets	E7	6/21/2016	0914	P	12.4	P	5.66											
KIN-03-CF-140	CF	Classroom faucets	D1	6/21/2016	0848	P	3.04	P	2.27											
KIN-03-CF-141	CF	Classroom faucets	D3	6/21/2016	0851	P	3.41	P	2.14											
KIN-03-CF-142	CF	Classroom faucets	D5	6/21/2016	0853	P	3.46	P	1.85											
KIN-03-CF-143	CF	Classroom faucets	D6	6/21/2016	0854	P	1.72	P	1.81											
KIN-03-CF-144	CF	Classroom faucets	D6	6/21/2016	0859	P	5.39	P	2.62											
KIN-03-CF-145	CF	Classroom faucets	D7	6/21/2016	0856	P	9.83	P	4.32											
KIN-03-WC-146	WC	Water fountain with cooler	CORR 358	6/21/2016	0837	P	<1.00	P	<1.00											
KIN-03-WC-147	WC	Water fountain with cooler	CORR 358	6/21/2016	0838	P	<1.00	P	<1.00											
KIN-03-CF-159	CF	Classroom faucets	C1	6/21/2016	0839	P	7.73	P	5.57											
KIN-03-CF-160	CF	Classroom faucets	C2	6/21/2016	0840	P	8.19	P	2.75											

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (Return assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (gumming) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (E)	Retest First Draw Lead Concentration (ppb)	Comments
KIN-03-CF-161	CF	Classroom faucets	C3	6/23/2016	0841	P	9.70		2.54											
KIN-03-WC-166	WC	Water fountain with cooler	CD08R 358	6/23/2016	0837	P	1.61	P	1.11											
KIN-03-WC-167	WC	Water fountain with cooler	CD08R 358	6/23/2016	0838	P	1.00	P	<1.00											
KIN-01-WO-168	WO	Water fountain without cooler	111	6/23/2016																
KIN-01-WO-169	WO	Water fountain without cooler	119	6/23/2016	0638	P	<1.00	P	<1.00											Not Functioning
KIN-01-WO-170	WO	Water fountain without cooler	184	6/23/2016	0651	P	4.44	P	7.70											
KIN-01-MS-171	MS	Miscellaneous sinks	181	6/23/2016	0656	P	19.6	P	8.60											
KIN-02-WO-173	WO	Water fountain without cooler	219	6/23/2016	0727	P	2.94	P	1.41											
KIN-02-WO-174	WO	Water fountain without cooler	217	6/23/2016																Not Functioning
KIN-02-CF-175	CF	Classroom faucets	268	6/23/2016	0757	P	6.26	P	2.52											
KIN-02-WO-176	WO	Water fountain without cooler	268	6/23/2016																Not Functioning
KIN-02-CF-177	CF	Classroom faucets	270	6/23/2016	0758	P	7.38	P	2.20											
KIN-02-WO-178	WO	Water fountain without cooler	270	6/23/2016	0759	P	1.72	P	1.20											
KIN-03-WO-179	WO	Water fountain without cooler	B1	6/23/2016	0811	P	2.65	P	3.56											
KIN-03-WO-180	WO	Water fountain without cooler	B5	6/23/2016																Not Functioning
KIN-01-WO-181	WO	Water fountain without cooler	B6	6/23/2016																Not Functioning
KIN-03-WO-182	WO	Water fountain without cooler	B7	6/23/2016																Not Functioning
KIN-03-WO-183	WO	Water fountain without cooler	B1	6/23/2016																Not Functioning
KIN-03-WO-184	WO	Water fountain without cooler	B3	6/23/2016																Not Functioning
KIN-03-WO-185	WO	Water fountain without cooler	A1	6/23/2016																Not Functioning
KIN-03-WO-186	WO	Water fountain without cooler	A3	6/23/2016																Not Functioning
KIN-03-WO-187	WO	Water fountain without cooler	A3	6/23/2016																Not Functioning
KIN-03-WO-188	WO	Water fountain without cooler	A5	6/23/2016																Not Functioning
KIN-03-WO-189	WO	Water fountain without cooler	A6	6/23/2016	0822	P	3.40	P	1.77											
KIN-03-WO-190	WO	Water fountain without cooler	A7	6/23/2016																Not Functioning
KIN-03-WO-191	WO	Water fountain without cooler	F3	6/23/2016	0831	P	4.71	P	5.68											
KIN-01-WO-192	WO	Water fountain without cooler	F2	6/23/2016																Not Functioning
KIN-03-WO-193	WO	Water fountain without cooler	F1	6/23/2016	0832	P	4.95	P	2.87											
KIN-01-WO-194	WO	Water fountain without cooler	C1	6/23/2016																Not Functioning
KIN-03-WO-195	WO	Water fountain without cooler	C2	6/23/2016																Not Functioning
KIN-03-WO-196	WO	Water fountain without cooler	C3	6/23/2016																Not Functioning
KIN-03-WO-197	WO	Water fountain without cooler	D1	6/23/2016																Not Functioning
KIN-03-WO-198	WO	Water fountain without cooler	D2	6/23/2016	0852	P	2.30	P	1.18											
KIN-03-WO-199	WO	Water fountain without cooler	D3	6/23/2016																Not Functioning
KIN-01-WO-200	WO	Water fountain without cooler	D5	6/23/2016	0855	P	1.62	P	1.55											
KIN-03-WO-201	WO	Water fountain without cooler	D6	6/23/2016	0902	P	1.92	P	1.74											
KIN-03-WO-202	WO	Water fountain without cooler	D7	6/23/2016																Not Functioning
KIN-03-WO-203	WO	Water fountain without cooler	E1	6/23/2016	0910	P	2.28	P	1.84											
KIN-03-WO-204	WO	Water fountain without cooler	F2	6/23/2016																Not Functioning
KIN-03-WO-205	WO	Water fountain without cooler	E3	6/23/2016	0913	P	2.24	P	2.74											
KIN-03-WO-206	WO	Water fountain without cooler	E5	6/23/2016																Not Functioning
KIN-03-WO-207	WO	Water fountain without cooler	E6	6/23/2016																Not Functioning
KIN-03-WO-208	WO	Water fountain without cooler	E7	6/23/2016	0915	P	10.6	P	5.93											

Lead in Drinking Water Sample Results

School: Pittsburgh Langley K-8

Address: 2940 Sheraden Blvd. Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (Fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
LAN-GF-SL-00	SL	Service Line	4	7/8/2016	0617	P	<1.00									
LAN-GF-WM-00	WM	Water Main	4	7/8/2016	0620	P	<1.00									
LAN-GF-MS-3	MS	Miscellaneous sinks	5	7/8/2016	0621	P	1.36	P	<1.00							
LAN-GF-WC-16	WC	Water fountain with cooler	CORR 01	7/8/2016	0629	P	<1.00	P	<1.00							
LAN-GF-WC-17	WC	Water fountain with cooler	CORR 01	7/8/2016	0630	P	<1.00	P	<1.00							
LAN-GF-CF-18	CF	Classroom faucets	15	7/8/2016	0632	P	2.14	P	1.29							
LAN-GF-CF-19	CF	Classroom faucets	15	7/8/2016	0633	P	5.40	P	<1.00							
LAN-GF-WO-46	WO	Water fountain without cooler	23	7/8/2016	0643	P	1.79	P	1.00							
LAN-GF-WO-47	WO	Water fountain without cooler	21	7/8/2016	0640	P	2.59	P	2.40							
LAN-GF-WC-55	WC	Water fountain with cooler	COOR 25C													NOT FUNCTIONING
LAN-GF-WC-56	WC	Water fountain with cooler	COOR 25C													NOT FUNCTIONING
LAN-GF-WC-57	WC	Water fountain with cooler	25													REMOVED
LAN-GF-WC-58	WC	Water fountain with cooler	25													REMOVED
LAN-GF-WO-67	WO	Water fountain without cooler	33	7/8/2016	0652	P	2.52	P	<1.00							
LAN-GF-WO-68	WO	Water fountain without cooler	38	7/8/2016	0657	P	3.33	P	1.19							
LAN-01-MS-136	MS	Miscellaneous sinks	106	7/8/2016	0716	F	59.1	P	5.43	8/11/2016	0632	P	3.64			
LAN-01-WC-138	WC	Water fountain with cooler	145A	7/8/2016	0713	P	2.54	P	12.4							
LAN-01-WC-139	WC	Water fountain with cooler	CORR 101							8/11/2016	0634			P	<1.00	Water Filtering Chiller with Bottle Filler
LAN-01-WFC-140	WFC	Water Filtering Chiller	CORR 101													
LAN-01-MS-141	MS	Miscellaneous sinks	104D	7/8/2016	0719	P	6.86	P	1.48							
LAN-01-MS-142	MS	Miscellaneous sinks	107A	7/8/2016	0721	P	<1.00	P	<1.00							
LAN-01-WC-149	WC	Water fountain with cooler	CORR 101	7/8/2016	0728	P	<1.00	P	1.22							
LAN-01-WC-150	WC	Water fountain with cooler	CORR 101	7/8/2016	0729	P	<1.00	P	<1.00							
LAN-01-CF-151	CF	Classroom faucets	119	7/8/2016	0731	F	1.86	P	<1.00	8/11/2016	0637	P	4.9			
LAN-01-CF-152	CF	Classroom faucets	120	7/8/2016	0732	P	6.42	P	<1.00							
LAN-01-CF-156	CF	Classroom faucets	122													NOT FUNCTIONING
LAN-01-CF-157	CF	Classroom faucets	122	7/8/2016	0735	F	25.3	P	1.34	8/11/2016	0640	P	5.28			
LAN-01-CF-158	CF	Classroom faucets	122	7/8/2016	0736	P	19.7	P	5.09							
LAN-01-WC-162	WC	Water fountain with cooler	CORR 101C	7/8/2016	0738	P	<1.00	P	1.02							
LAN-01-WC-163	WC	Water fountain with cooler	CORR 101C	7/8/2016	0739	P	<1.00	P	<1.00							
LAN-01-WC-169	WC	Water fountain with cooler	131													NOT FUNCTIONING
LAN-01-CF-170	CF	Classroom faucets	131	7/8/2016	0750	F	31.7	P	17.0	8/11/2016	0643	P	7.15			
LAN-01-CF-171	CF	Classroom faucets	134	7/8/2016	0745	P	1.85	P	<1.00							
LAN-01-WC-173	WC	Water fountain with cooler	CORR 101B	7/8/2016	0742	P	<1.00	P	<1.00							
LAN-01-WC-174	WC	Water fountain with cooler	CORR 101B	7/8/2016	0743	P	<1.00	P	<1.00							
LAN-01-NF-177	NF	Nurse's office sink faucets	143	7/8/2016	0725	P	2.34	P	1.36							
LAN-GF-IM-192	IM	Ice machines	152A	7/8/2016	0802	P	<1.00									
LAN-01-WC-196	WC	Water fountain with cooler	CORR 146							8/11/2016	0647			P	<1.00	Water Filtering Chiller with Bottle Filler
LAN-01-WFC-197	WFC	Water Filtering Chiller	CORR 146													
LAN-01-KF-198	KF	Kitchen faucets	151A	7/8/2016	0801	P	5.38	P	1.76							
LAN-01-KF-273	KF	Kitchen faucets	151A	7/8/2016	0800	P	1.95	P	<1.00							
LAN-01-KF-200	KF	Kitchen faucets	151A	7/8/2016	0759	P	4.36	P	<1.00							
LAN-02-CF-202	CF	Classroom faucets	201	7/8/2016	0815	P	2.27	P	<1.00							
LAN-02-CF-203	CF	Classroom faucets	204	7/8/2016	0817	P	3.88	P	3.18							
LAN-02-CF-204	CF	Classroom faucets	204	7/8/2016	0818	P	4.91	P	1.81							
LAN-02-CF-210	CF	Classroom faucets	207	7/8/2016	0827	P	16.7	P	3.19							
LAN-02-CF-215	CF	Classroom faucets	210	7/8/2016	0830	P	2.28	P	<1.00							
LAN-02-CF-216	CF	Classroom faucets	210	7/8/2016	0831	P	4.19	P	1.03							
LAN-02-CF-217	CF	Classroom faucets	210	7/8/2016	0832	F	85.8	P	2.44	8/11/2016	0627	P	2.12			
LAN-02-CF-218	CF	Classroom faucets	210	7/8/2016	0833	P	8.56	P	1.48							
LAN-02-CF-219	CF	Classroom faucets	210	7/8/2016	0834	P	8.83	P	1.30							
LAN-02-WC-220	WC	Water fountain with cooler	CORR 200													REMOVED
LAN-02-WC-221	WC	Water fountain with cooler	CORR 200													REMOVED
LAN-02-CF-228	CF	Classroom faucets	216													NOT FUNCTIONING
LAN-02-MS-232	MS	Miscellaneous sinks	218	7/8/2016	0841	P	7.61	P	2.41							
LAN-02-CF-233	CF	Classroom faucets	219	7/8/2016	0844	P	3.36	P	<1.00							
LAN-02-CF-234	CF	Classroom faucets	219	7/8/2016	0845	P	6.48	P	1.29							
LAN-02-WC-239	WC	Water fountain with cooler	CORR 200C	7/8/2016	0846	P	5.21	P	3.75							
LAN-02-WC-240	WC	Water fountain with cooler	CORR 200C	7/8/2016	0847	P	2.59	P	2.26							
LAN-02-WC-245	WC	Water fountain with cooler	CORR 200B	7/8/2016	0851	P	<1.00	P	<1.00							
LAN-02-WC-246	WC	Water fountain with cooler	CORR 200B	7/8/2016	0852	P	<1.00	P	2.30							
LAN-02-TT-248	TT	Teacher's lounge sinks	234	7/8/2016	0855	P	<1.00	P	<1.00							
LAN-02-WC-250	WC	Water fountain with cooler	CORR 236A													REMOVED
LAN-02-WC-251	WC	Water fountain with cooler	CORR 236A													REMOVED
LAN-02-WC-259	WC	Water fountain with cooler	CORR 236E	7/8/2016	0858	P	<1.00	P	<1.00							
LAN-02-WC-260	WC	Water fountain with cooler	CORR 236E	7/8/2016	0859	P	<1.00	P	<1.00							
LAN-02-CF-261	CF	Classroom faucets	242	7/8/2016	0903	P	9.63	P	1.48							
LAN-02-CF-262	CF	Classroom faucets	242	7/8/2016	0904	P	3.12	P	1.79							
LAN-02-CF-263	CF	Classroom faucets	244	7/8/2016	0905	P	4.62	P	<1.00							
LAN-02-CF-264	CF	Classroom faucets	244	7/8/2016	0906	P	4.69	P	<1.00							

Lead in Drinking Water Sample Results

School: Pittsburgh Langley K-8

Address: 2940 Sheraden Blvd. Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (Fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
LAN-02-CF-265	CF	Classroom faucets	248	7/8/2016	0907	P	1.94	P	<1.00							
LAN-01-CF-266	CF	Classroom faucets	248	7/8/2016	0908	P	1.72	P	<1.00							
LAN-03-MS-267	MS	Miscellaneous sinks	301	7/8/2016	0914	P	18.5	P	<1.00							
LAN-02-CF-268	CF	Classroom faucets	217	7/8/2016	0843	P	1.17	P	9.48							
LAN-02-CF-270	CF	Classroom faucets	207	7/8/2016	0825	P	18.6	P	2.60							
LAN-02-WC-271	WC	Water fountain with cooler	CORR 200	7/8/2016	0822	F	112	F	161							Old Fountains removed, awaiting installation of new fountains
LAN-02-WC-272	WC	Water fountain with cooler	CORR 200	7/8/2016	0823	F	217	F	81.9							Old Fountains removed, awaiting installation of new fountains
LAN-01-CF-274	CF	Classroom faucets	131	7/8/2016	0751	F	20.8	P	17.2	8/11/2016	0645	P	4.69			
LAN-01-CF-275	CF	Classroom faucets	131	7/8/2016	0752	P	17.8	P	14.9							
LAN-GF-WC-277	WC	Water fountain with cooler	OUTSIDE 41	7/8/2016	0703	P	<1.00	P	<1.00							

Drinking Water Sample Results

School: Pittsburgh Linden K-5

Address: 725 S. Linden Avenue, Pittsburgh PA, 15208

[illegible]

Drinking Water Sample Results

School: Pittsburgh Manchester PreK-8

Address: 1612 Manhattan Street, Pittsburgh PA, 15233

						First Draw/Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time											
MAN-01-SL-0	SL	Service Line	BOILER ROOM	6/17/2016	0601	P	1.41									
MAN-01-WM-0	WM	Water Main	BOILER ROOM	6/17/2016	0604	P	1.41									
MAN-01-NF-3	NF	Nurse's office sink faucets	115	6/17/2016	0607	P	<1.00	P	<1.00							
MAN-01-WO-4	WO	Water fountain without cooler	CORRIDOR 120	6/17/2016	0610	P	1.47	P	1.53							
MAN-01-CF-5	CF	Classroom faucets	114	6/17/2016	0613	P	3.33	P	1.87							
MAN-01-CF-6	CF	Classroom faucets	113	6/17/2016	0615	P	9.62	P	1.89							
MAN-01-CF-10	CF	Classroom faucets	112	6/17/2016	0620	P	7.31	P	2.32							
MAN-01-CF-12	CF	Classroom faucets	106	6/17/2016	0625	P	7.63	P	5.4							
MAN-01-WC-22	WC	Water fountain with cooler	CORR 148	6/17/2016	0608	P	2.37	P	2.95							
MAN-01-CF-28	CF	Classroom faucets	128	6/17/2016	0650	P	2.51	P	<1.00							
MAN-01-CF-31	CF	Classroom faucets	128	6/17/2016	0612	P	4.07	P	<1.00							
MAN-01-CF-32	CF	Classroom faucets	127	6/17/2016	0617	P	1.94	P	1.46							
MAN-01-CF-33	CF	Classroom faucets	127	6/17/2016	0653	P	3.27	P	<1.00							
MAN-01-CF-34	CF	Classroom faucets	149	6/17/2016	0623	P	6.13	P	1.46							
MAN-01-CF-35	CF	Classroom faucets	150	6/17/2016	0627	P	5.6	P	1.33							
MAN-01-WO-36	WO	Water fountain without cooler	CORRIDOR 154	6/17/2016												Not Functioning
MAN-01-CF-37	CF	Classroom faucets	151	6/17/2016	0632	P	4.25	P	1.68							
MAN-01-CF-38	CF	Classroom faucets	152	6/17/2016	0635	P	9.48	P	2.27							
MAN-01-CF-39	CF	Classroom faucets	162	6/17/2016	0638	F	26.8	P	4.4	8/11/2016	0630	F	25.1			
MAN-01-MS-40	MS	Miscellaneous sinks	CORRIDOR 157	6/17/2016	0639	P	7.67	P	1.8							
MAN-01-WO-43	WO	Water fountain without cooler	CORRIDOR 108	6/17/2016	0646	P	3.88	P	1.41							
MAN-02-WO-45	WO	Water fountain without cooler	CORRIDOR 220	6/17/2016	0700	P	2.61	P	1.5							
MAN-02-CF-46	CF	Classroom faucets	212	6/17/2016	0705	P	10.5	P	1.99							
MAN-02-TF-48	TF	Teacher's lounge sinks	207	6/17/2016	0716	P	5.75	P	1.59							
MAN-02-CF-49	CF	Classroom faucets	201	6/17/2016	0719	P	15.2	P	3.26							
MAN-02-WO-51	WO	Water fountain without cooler	CORRIDOR 213	6/17/2016	0721	P	2.25	P	<1.00							
MAN-02-WC-58	WC	Water fountain with cooler	CORRIDOR 237	6/17/2016	0701	P	1.87	P	2.2							
MAN-02-CF-65	CF	Classroom faucets	239	6/17/2016	0709	P	6.18	P	2.73							
MAN-02-CF-66	CF	Classroom faucets	240	6/17/2016	0711	F	21.4	P	6.15	8/11/2016	0634	F	38.1			
MAN-02-CF-67	CF	Classroom faucets	241	6/17/2016	0714	P	16.3	P	3.17							
MAN-02-CF-68	CF	Classroom faucets	242	6/17/2016	0717	P	7.51	P	1.42							
MAN-02-WO-69	WO	Water fountain without cooler	CORRIDOR 244	6/17/2016	0719	P	5.32	P	1.38							
MAN-02-CF-70	CF	Classroom faucets	200	6/17/2016	0722	P	5.31	P	<1.00							
MAN-01-WO-72	WO	Water fountain without cooler	127	6/17/2016	0618	P	5.01	P	1.72							
MAN-01-WO-71	WO	Water fountain without cooler	128	6/17/2016	0614	P	1.51	P	2.81							
MAN-01-WO-73	WO	Water fountain without cooler	CORRIDOR 157	6/17/2016	0640	P	3.19	P	<1.00							
MAN-01-MS-42	MS	Miscellaneous sinks	163	6/17/2016	0634	P	1.55	P	<1.00							
MAN-01-MS-8	MS	Miscellaneous sinks	111	6/17/2016	0630	P	7.76	P	2.83							
MAN-02-MS-53	MS	Miscellaneous sinks	224	6/17/2016	0701	P	11.8	P	6.72							
MAN-02-CF-74	CF	Classroom faucets	225	6/17/2016	0703	P	8.31	P	1.74							
MAN-02-WO-75	WO	Water fountain without cooler	212	6/17/2016	0711	P	5.01	P	1.55							
MAN-02-CF-76	CF	Classroom faucets	205	6/17/2016	0725	P	2.66	P	1.71							
MAN-02-WO-77	WO	Water fountain without cooler	106	6/17/2016												Not Functioning
MAN-02-WO-78	WO	Water fountain without cooler	111	6/17/2016												Not Functioning
MAN-02-WO-79	WO	Water fountain without cooler	112	6/17/2016												Not Functioning
MAN-02-WO-80	WO	Water fountain without cooler	113	6/17/2016												Not Functioning
MAN-02-WO-81	WO	Water fountain without cooler	114	6/17/2016												Not Functioning
MAN-02-WO-82	WO	Water fountain without cooler	149	6/17/2016												Not Functioning
MAN-02-WO-83	WO	Water fountain without cooler	150	6/17/2016												Not Functioning
MAN-02-WO-84	WO	Water fountain without cooler	151	6/17/2016												Not Functioning
MAN-02-WO-85	WO	Water fountain without cooler	152	6/17/2016												Not Functioning
MAN-02-WO-86	WO	Water fountain without cooler	162	6/17/2016												Not Functioning
MAN-02-WO-87	WO	Water fountain without cooler	200	6/17/2016												Not Functioning
MAN-02-WO-88	WO	Water fountain without cooler	201	6/17/2016												Not Functioning
MAN-02-WO-89	WO	Water fountain without cooler	207	6/17/2016												Not Functioning
MAN-02-WO-90	WO	Water fountain without cooler	239	6/17/2016												Not Functioning
MAN-02-WO-91	WO	Water fountain without cooler	240	6/17/2016												Not Functioning
MAN-02-WO-92	WO	Water fountain without cooler	241	6/17/2016												Not Functioning

Pittsburgh Millions 6-12

Drinking Water Sample Results

School: Pittsburgh Milliones 6-12

Address: 3117 Centre Avenue, Pittsburgh PA, 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
MLO-02-SL-00	SL	Service Line	259	6/25/2016	0644	P	1.48									
MLO-02-WM-00	WM	Water Main	259	6/25/2016	0647	P	1.13									
MLO-02-NF-3	NF	Nurse's office sink faucets	251	6/25/2016	0650	F	21.0	P	2.05	8/12/2016	0610	P	11.5			
MLO-02-NF-4	NF	Nurse's office sink faucets	253	6/25/2016	0651	P	6.16	P	1.44							
MLO-02-WFC-09	WFC	Water Filtering Chiller	CORR 240	6/25/2016	0654	P	< 1.00	P	< 1.00	8/12/2016	0612			P	<1.00	Water Filtering Chiller with Bottle Filler
MLO-02-WC-13	WC	Water fountain with cooler	242	6/25/2016	0657	P	< 1.00	P	1.43							
MLO-02-CF-28	CF	Classroom faucets	223	6/25/2016	0700	P	4.05	P	< 1.00							
MLO-02-WC-36	WC	Water fountain with cooler	220	6/25/2016	0701	P	1.28	P	2.91							
MLO-02-WC-41	WC	Water fountain with cooler	CORR 240	6/25/2016	0705	P	< 1.00	P	< 1.00							
MLO-02-KF-45	KF	Kitchen faucets	234	6/25/2016	0710	P	7.42	P	1.54							
MLO-02-KF-47	KF	Kitchen faucets	234	6/25/2016	0712	P	2.09	P	< 1.00							
MLO-02-IM-49	IM	Ice machines	236	6/25/2016	0714	P	< 1.00									
MLO-01-MS-55	MS	Miscellaneous sinks	118	6/25/2016	0722	P	< 1.00	P	< 1.00							
MLO-01-WC-57	WC	Water fountain with cooler	129	6/25/2016	0720	P	2.35	P	4.47							
MLO-01-WC-64	WC	Water fountain with cooler	CORR 115	6/25/2016	0738	P	< 1.00	P	< 1.00							
MLO-01-CF-66	CF	Classroom faucets	110	6/25/2016	0733	P	2.44	P	< 1.00							
MLO-01-CF-67	CF	Classroom faucets	110	6/25/2016	0734	P	1.72	P	< 1.00							
MLO-01-CF-68	CF	Classroom faucets	110	6/25/2016	0735	P	3.13	P	1.44							
MLO-03-WC-80	WC	Water fountain with cooler	CORR 353	6/25/2016	0746	P	< 1.00	P	< 1.00							
MLO-03-WC-87	WC	Water fountain with cooler	CORR 329	6/25/2016	0748	P	< 1.00	P	1.25							
MLO-03-WC-114	WC	Water fountain with cooler	OUTSIDE 343	6/25/2016	0747	P	6.88	P	8.15							
MLO-04-TF-116	TF	Teacher's lounge sinks	437	6/25/2016	0756	P	< 1.00	P	< 1.00							
MLO-04-MS-119	MS	Miscellaneous sinks	430-A	6/25/2016	0759	P	< 1.00	P	< 1.00							
MLO-04-WC-123	WC	Water fountain with cooler	CORR 426	6/25/2016	0802	P	< 1.00	P	< 1.00							
MLO-04-WC-124	WC	Water fountain with cooler	CORR 415	6/25/2016	0804	P	< 1.00	P	1.02							
MLO-05-WC-149	WC	Water fountain with cooler	CORR 506B	6/25/2016	0810	P	< 1.00	P	< 1.00							
MLO-05-MS-154	MS	Miscellaneous sinks	519	6/25/2016	0812	P	1.01	P	< 1.00							
MLO-05-MS-155	MS	Miscellaneous sinks	519	6/25/2016	0813	P	1.70	P	3.79							
MLO-05-WC-156	WC	Water fountain with cooler	CORR 506A	6/25/2016	0815	P	< 1.00	P	< 1.00							
MLO-02-KF-161	KF	Kitchen faucets	234	6/25/2016	0713	P	2.00	P	< 1.00							

Lead in Drinking Water Sample Results

School: Pittsburgh Morrow PreK-8

Address: 1611 Davis Avenue Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
MOR-B5-SL-00	SL	Service Line	4A	6/15/2016	0556	P	1.35									
MOR-B5-WM-00	WM	Water Main	4A	6/15/2016	0558	P	1.41									
MOR-B5-WO-1	WO	Water fountain without cooler	1B	6/15/2016	0559	P	2.63	P	1.51							
MOR-B5-WC-8	WC	Water fountain with cooler	CORR 1	6/15/2016	0600	P	3.88	P	11							
MOR-B5-WC-9	WC	Water fountain with cooler	CORR 1	6/15/2016	0601	P	2.89	P	13.6							
MOR-B5-CF-12	CF	Classroom faucets	SHOP	6/15/2016	0608	P	4.12	P	<1.00							
MOR-B5-CF-13	CF	Classroom faucets	SHOP	6/15/2016	0609	P	2.95	P	<1.00							
MOR-B5-WC-17	WC	Water fountain with cooler	CORR 1G	6/15/2016	0611	P	<1.00	P	<1.00							
MOR-B5-WFC-18	WFC	Water Filtering Chiller	CORR 1G	6/15/2016	0612	P	<1.00	P	<1.00	8/11/2016	0710			P	<1.00	Water Filtering Chiller with Bottle Filler
MOR-B5-WO-19	WO	Water fountain without cooler	19B	6/15/2016	0616	P	2.36	P	1.31							
MOR-B5-CF-21	CF	Classroom faucets	19B Cloak Room	6/15/2016	0617	P	<1.00	P	<1.00							
MOR-01-CF-24	CF	Classroom faucets	105	6/15/2016	0626	P	6.02	P	<1.00							
MOR-01-CF-25	CF	Classroom faucets	104	6/15/2016	0629	P	9.37	P	1.74							
MOR-01-WO-26	WO	Water fountain without cooler	CORR 100A	6/15/2016	0632	P	2.71	P	<1.00							
MOR-01-WO-27	WO	Water fountain without cooler	CORR 100A	6/15/2016	0633	P	4.28	P	1.15							
MOR-01-CF-28	CF	Classroom faucets	102	6/15/2016	0636	P	7.33	P	1.89							
MOR-01-CF-29	CF	Classroom faucets	101	6/15/2016	0639	P	4.77	P	1.7							
MOR-01-WC-30	WC	Water fountain with cooler	CORR 100	6/15/2016	0639	P	<1.00	P	<1.00							
MOR-01-WC-31	WC	Water fountain with cooler	CORR 100	6/15/2016	0640	P	<1.00	P	<1.00							
MOR-01-NF-34	NF	Nurse's office sink faucets	109	6/15/2016	0642	P	5.51	P	1.39							
MOR-01-CF-37	CF	Classroom faucets	108	6/15/2016	0649	P	10.7	P	4.85							
MOR-01-CF-38	CF	Classroom faucets	110	6/15/2016	0652	F	21.6	P	2.68	8/11/2016	0712	F	30.2			
MOR-01-WC-41	WC	Water fountain with cooler	CORR 100	6/15/2016	0653	P	<1.00	P	1.23							
MOR-01-WC-42	WC	Water fountain with cooler	CORR 100	6/15/2016	0654	P	1.35	P	1.39							
MOR-01-MS-43	MS	Miscellaneous sinks	118	6/15/2016	0657	P	1.13	P	<1.00							
MOR-01-CF-44	CF	Classroom faucets	116	6/15/2016	0655	P	3.4	P	<1.00							
MOR-02-CF-45	CF	Classroom faucets	205	6/15/2016	0702	P	4.28	P	1.33							
MOR-02-CF-46	CF	Classroom faucets	204	6/15/2016	0703	P	3.42	P	1.17							
MOR-02-CF-47	CF	Classroom faucets	207	6/15/2016	0706	P	18.9	P	3.21							
MOR-02-CF-48	CF	Classroom faucets	201	6/15/2016	0707	P	4.59	P	2.58							
MOR-02-WC-49	WC	Water fountain with cooler	CORR 200	6/15/2016	0710	P	<1.00	P	1.03							
MOR-02-WC-50	WC	Water fountain with cooler	CORR 200	6/15/2016	0711	P	1.09	P	<1.00							
MOR-02-OF-53	OF	Office sink faucets	209	6/15/2016	0713	P	5.08	P	1.8							
MOR-02-OF-55	OF	Office sink faucets	213	6/15/2016	0714	F	34.8	P	6.3	8/11/2016	0715	F	68			
MOR-02-WC-58	WC	Water fountain with cooler	CORR 200	6/15/2016	0715	P	1.11	P	1.39							
MOR-02-WC-59	WC	Water fountain with cooler	CORR 200	6/15/2016	0716	P	1.47	P	1.57							
MOR-02-WO-61	WO	Water fountain without cooler	CORR 200F	6/15/2016	0720	P	4.55	P	3.44							
MOR-02-WO-62	WO	Water fountain without cooler	CORR 200F	6/15/2016	0721	P	5.17	P	3.22							
MOR-02-CF-63	CF	Classroom faucets	218	6/15/2016	0718	P	3.96	P	2.01							
MOR-B5-CF-69	CF	Classroom faucets	19B	6/15/2016	0619	P	<1.00	P	<1.00							
MOR-B5-MS-10	MS	Miscellaneous sinks	6	6/15/2016	0606	P	<1.00	P	<1.00							
MOR-01-CF-64	CF	Classroom faucets	106	6/15/2016	0645	P	4.48	P	2.22							
MOR-01-WO-66	WO	Water fountain without cooler	110	6/15/2016	0650	F	25.6	P	3.78							Removed
MOR-02-WO-67	WO	Water fountain without cooler	CORR 200A	6/15/2016	0705	P	2.99	P	<1.00							
MOR-02-WO-68	WO	Water fountain without cooler	CORR 200A	6/15/2016	0706	P	2.51	P	1.15							

Pittsburgh Morrow (Rooney)

Lead in Drinking Water Sample Results

School: Pittsburgh Morrow (Rooney)

Address: 3530 Fleming Avenue Pittsburgh PA, 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (Fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
MRN-BS-SL-00	SL	Service Line	018	6/30/2016	0613	P	<1.00									
MRN-BS-WM-00	WM	Water Main	018	6/30/2016	0616	P	<1.00									
MRN-BS-CF-1	CF	Classroom faucets	22	6/30/2016	0632	P	4.13	P	<1.00							
MRN-BS-CF-2	CF	Classroom faucets	2	6/30/2016	0631	P	1.44	P	<1.00							
MRN-BS-CF-3	CF	Classroom faucets	2	6/30/2016	0629	P	2.31	P	<1.00							
MRN-BS-CF-5	CF	Classroom faucets	1	6/30/2016	0612	P	1.89	P	<1.00							
MRN-BS-CF-6	CF	Classroom faucets	1	6/30/2016	0617	P	3.37	P	<1.00							
MRN-BS-CF-7	CF	Classroom faucets	1A	6/30/2016	0618	P	11.2	P	1.23							
MRN-BS-WFC-12	WFC	Water fountain without cooler	CORR 022	6/30/2016						8/11/2016	0650			P	<1.00	Water Filtering Chiller with Bottle Filler
MRN-BS-WO-14	WO	Water fountain without cooler	CORR 022	6/30/2016	0658	P	<1.00	P	<1.00							
MRN-BS-CF-18	CF	Classroom faucets	3	6/30/2016	0701	P	1.48	P	<1.00							
MRN-BS-CF-19	CF	Classroom faucets	3	6/30/2016	0702	P	<1.00	P	<1.00							
MRN-BS-CF-20	CF	Classroom faucets	3	6/30/2016												Not Observed
MRN-BS-KF-24	KF	Kitchen faucets	33	6/30/2016	0644	P	2.31	P	<1.00							
MRN-BS-KF-25	KF	Kitchen faucets	33	6/30/2016	0645	P	1.58	P	<1.00							
MRN-BS-IM-26	IM	Ice machines	31	6/30/2016	0646	P	<1.00	P								
MRN-BS-WO-37	WO	Water fountain without cooler	CORR B100	6/30/2016	0653	P	<1.00	P	<1.00							
MRN-BS-WO-38	WO	Water fountain without cooler	CORR B100	6/30/2016	0654	P	<1.00	P	<1.00							
MRN-01-WO-51	WO	Water fountain without cooler	CORR 114	6/30/2016	0716	P	1.62	P	<1.00							
MRN-01-WO-61	WO	Water fountain without cooler	CORR 114	6/30/2016	0706	P	<1.00	P	<1.00							
MRN-02-WO-65	WO	Water fountain without cooler	CORR 218	6/30/2016	0734	P	2.15	P	<1.00							
MRN-02-CF-68	CF	Classroom faucets	209	6/30/2016	0725	P	1.86	P	<1.00							
MRN-02-CF-69	CF	Classroom faucets	209	6/30/2016	0727	P	3.8	P	1.37							
MRN-02-CF-70	CF	Classroom faucets	209	6/30/2016	0728	P	4.08	P	<1.00							
MRN-02-CF-71	CF	Classroom faucets	209	6/30/2016	0729	P	3.87	P	<1.00							
MRN-02-MS-72	MS	Miscellaneous sinks	208A	6/30/2016	0731	P	1.08	P	1.15							
MRN-02-WO-76	WO	Water fountain without cooler	CORR 218	6/30/2016	0720	P	<1.00	P	<1.00							
MRN-03-WO-78	WO	Water fountain without cooler	CORR 312	6/30/2016	0739	P	2.4	P	<1.00							
MRN-03-WO-79	WO	Water fountain without cooler	CORR 303	6/30/2016	0743	P	1.29	P	<1.00							
MRN-03-MS-80	MS	Miscellaneous sinks	302	6/30/2016	0741	P	1.26	P	<1.00							
MRN-01-NF-85	NF		109	6/30/2016	0711	P	1.22	P	<1.00							
MRN-01-NF-86	NF		109B	6/30/2016	0712	P	1.91	P	1.03							

Pittsburgh Perry High School

Drinking Water Sample Results

School: Pittsburgh Perry High School

Address: 3875 Perrysville Avenue, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (Fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
PER-B5-SL-00	SL	Service Line	PIPE SPACE 035	7/7/2016	0515	P	<1.00									
PER-B5-WM-00	WM	Water Main	PIPE SPACE 035	7/7/2016	0518	P	<1.00									
PER-B5-WO-2	WO	Water fountain without cooler	HALL 021	7/7/2016	0519	P	4.52	P	4.67							
PER-B5-WO-3	WO	Water fountain without cooler	HALL 021	7/7/2016	0520	P	3.52	P	2.80							
PER-B5-MS-4	MS	Miscellaneous sinks	024A	7/7/2016	0523	F	38.1	P	5.70	8/11/2016	0732	P	5.18			
PER-B5-WC-5	WC	Water fountain with cooler	20	7/7/2016	0525	P	<1.00	P	<1.00							
PER-SB-MS-6	MS	Miscellaneous sinks	19	7/7/2016	0530	P	2.11	P	<1.00							
PER-SB-WC-8	WC	Water fountain with cooler	RO13	7/7/2016	0532	P	<1.00	P	<1.00							
PER-01-WC-10	WC	Water fountain with cooler	CORR 131B	7/7/2016	0536	P	<1.00	P	<1.00							
PER-01-WC-11	WC	Water fountain with cooler	CORR 131B	7/7/2016	0537	P	<1.00	P	<1.00							
PER-01-MS-25	MS	Miscellaneous sinks	140E	7/7/2016	0544	P	9.07	P	1.96							
PER-01-MS-26	MS	Miscellaneous sinks	142	7/7/2016	0548	P	<1.00	P	<1.00							
PER-01-WC-38	WC	Water fountain with cooler	CORR 131B	7/7/2016	0550	P	1.47	P	1.26							
PER-01-WC-39	WC	Water fountain with cooler	CORR 131B	7/7/2016	0551	P	<1.00	P	<1.00							
PER-01-MS-46	MS	Miscellaneous sinks	149	7/7/2016	0553	P	<1.00	P	<1.00							
PER-01-NF-49	NF	Nurse's office sink faucets	147D	7/7/2016	0555	P	2.54	P	<1.00							
PER-01-NF-50	NF	Nurse's office sink faucets	147A	7/7/2016	0556	P	8.37	P	6.53							
PER-01-KF-51	KF	Kitchen faucets	162	7/7/2016	0601	P	3.57	P	<1.00							
PER-01-KF-52	KF	Kitchen faucets	162	7/7/2016	0600	P	2.84	P	<1.00							
PER-01-WO-54	WO	Water fountain without cooler	160	7/7/2016	0606	P	3.27	P	2.66							
PER-01-WO-55	WO	Water fountain without cooler	160	7/7/2016	0607	P	2.99	P	3.94							
PER-02-WC-59	WC	Water fountain with cooler	CORR 200	7/7/2016	0613	P	<1.00	P	<1.00							
PER-02-WC-60	WC	Water fountain with cooler	CORR 200	7/7/2016	0614	P	<1.00	P	<1.00							
PER-02-WC-85	WC	Water fountain with cooler	CORR 200	7/7/2016	0616	P	<1.00	P	<1.00							
PER-02-WC-86	WC	Water fountain with cooler	CORR 200	7/7/2016	0617	P	<1.00	P	<1.00							
PER-02-WO-96	WO	Water fountain without cooler	CORR 200D	7/7/2016												
PER-02-CF-117	CF	Classroom faucets	267	7/7/2016	0621	P	1.12	P	<1.00							Not Functioning
PER-02-CF-118	CF	Classroom faucets	267	7/7/2016	0622	P	4.80	P	1.21							
PER-02-CF-119	CF	Classroom faucets	251	7/7/2016	0620	P	2.50	P	<1.00							
PER-02-CF-129	CF	Classroom faucets	269	7/7/2016												Not Functioning
PER-02-CF-130	CF	Classroom faucets	269C	7/7/2016												Not Functioning
PER-03-WC-131	WC	Water fountain with cooler	CORR 300	7/7/2016	0629	P	<1.00	P	<1.00							
PER-03-WC-132	WC	Water fountain with cooler	CORR 300	7/7/2016	0630	P	<1.00	P	<1.00							
PER-03-CF-134	CF	Classroom faucets	326	7/7/2016	0654	F	39.4	P	<1.00	8/11/2016	0721	P	7.08			
PER-03-CF-135	CF	Classroom faucets	326	7/7/2016	0655	P	7.28	P	<1.00							
PER-03-CF-142	CF	Classroom faucets	333	7/7/2016	0632	P	1.21	P	<1.00							
PER-03-CF-143	CF	Classroom faucets	333	7/7/2016	0633	P	1.48	P	<1.00							
PER-03-CF-144	CF	Classroom faucets	333	7/7/2016	0634	P	3.11	P	<1.00							
PER-03-CF-145	CF	Classroom faucets	333	7/7/2016	0635	P	<1.00	P	<1.00							
PER-03-CF-146	CF	Classroom faucets	338	7/7/2016	0640	P	2.61	P	<1.00							
PER-03-CF-147	CF	Classroom faucets	342	7/7/2016	0643	P	<1.00	P	1.38							
PER-03-CF-148	CF	Classroom faucets	342	7/7/2016	0644	P	1.37	P	<1.00							
PER-03-WC-149	WC	Water fountain with cooler	CORR 300	7/7/2016	0646	P	<1.00	P	<1.00							
PER-03-WC-150	WC	Water fountain with cooler	CORR 300	7/7/2016	0647	P	<1.00	P	<1.00							
PER-03-WFC-157	WFC	Water Filtering Chiller	CORR 300E	7/7/2016	0649	P	2.26	P	2.10	8/11/2016	0725			P	<1.00	Water Filtering Chiller with Bottle Filler
PER-02-SL-159	SL	Service Line	825	7/7/2016	0708	P	<1.00									
PER-02-WM-159	WM	Water Main	825	7/7/2016	0711	P	<1.00									
PER-02-WO-176	WO	Water fountain without cooler	CORR 800	7/7/2016	0721	P	<1.00	P	<1.00							
PER-02-WO-203	WO	Water fountain without cooler	8128	7/7/2016												Not Functioning
PER-02-WO-211	WO	Water fountain without cooler	POOL	7/7/2016												Not Functioning
PER-02-WO-236	WO	Water fountain without cooler	8188	7/7/2016	0730	P	<1.00	P	4.99							
PER-01-WO-246	WO	Water fountain without cooler	CORR 700	7/7/2016	0707	P	<1.00	P	<1.00							
PER-03-WO-250	WO	Water fountain without cooler	OUTSIDE 903	7/7/2016	0736	P	<1.00	P	<1.00							
PER-03-MS-251	MS	Miscellaneous sinks	903	7/7/2016	0738	P	4.67	P	1.93							
PER-01-KF-256	KF	Kitchen faucets	162	7/7/2016	0602	P	1.45	P	<1.00							
PER-02-MS-258	MS	Miscellaneous sinks	823	7/7/2016	0723	P	4.63	P	1.12							
PER-02-IM-259	IM	Ice Machines	823	7/7/2016	0725	P	<1.00									

Drinking Water Sample Results

School: Pittsburgh Pioneer

Address: 775 Dunster Street, Pittsburgh PA, 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (Fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
PIO-BS-SL-00	SL	Service Line	BOILER ROOM	6/29/2016	0607	P	<1.00									
PIO-BS-WM-00	WM	Water Main	BOILER ROOM	6/29/2016	0609	P	<1.00									
PIO-01-CF-5	CF	Classroom faucets	A108	6/29/2016	0616	P	3.36	P	1.28							
PIO-01-MS-6	MS	Miscellaneous sinks	A107	6/29/2016	0613	P	1.11	P	<1.00							
PIO-01-MS-7	MS	Miscellaneous sinks	A107	6/29/2016	0614	P	<1.00	P	1.03							
PIO-01-MS-9	MS	Miscellaneous sinks	HALL	6/29/2016	0606	P	1.09	P	1.08							
PIO-01-WC-12	WC	Water fountain with cooler	CORR D	6/29/2016	0621	P	1.05	P	1.40							
PIO-01-CF-17	CF	Classroom faucets	A118	6/29/2016	0622	P	1.62	P	<1.00							
PIO-01-CF-20	CF	Classroom faucets	B107	6/29/2016	0625	P	1.58	P	<1.00							
PIO-01-CF-21	CF	Classroom faucets	B104	6/29/2016	0628	P	1.86	P	<1.00							
PIO-01-WFC-22	WFC	Water Filtering Chiller	CORR C	6/29/2016	0629	P	<1.00	P	1.06	8/9/2016	0611			P	<1.00	Water Filtering Chiller with Bottle Filler
PIO-01-CF-23	CF	Classroom faucets	B107	6/29/2016	0626	P	<1.00	P	<1.00							
PIO-01-MS-25	MS	Miscellaneous sinks	B112	6/29/2016	0631	P	4.76	P	<1.00							
PIO-01-NF-28	NF	Nurse's office sink faucets	B114	6/29/2016	0632	P	2.64	P	1.31							
PIO-01-CF-33	CF	Classroom faucets	B151	6/29/2016	0635	P	1.41	P	<1.00							
PIO-01-CF-34	CF	Classroom faucets	B151	6/29/2016												Not Observed
PIO-01-CF-36	CF	Classroom faucets	B154	6/29/2016	0636	P	2.39	P	<1.00							
PIO-01-CF-37	CF	Classroom faucets	B146	6/29/2016	0644	P	3.02	P	<1.00							
PIO-01-CF-40	CF	Classroom faucets	B144	6/29/2016	0646	P	3.49	P	<1.00							
PIO-01-WC-43	WC	Water fountain with cooler	CORR E	6/29/2016	0648	P	<1.00	P	<1.00							
PIO-01-KF-46	KF	Kitchen faucets	B131	6/29/2016	0651	P	7.03	P	<1.00							
PIO-01-MS-47	MS	Miscellaneous sinks	B131	6/29/2016	0652	P	3.82	P	<1.00							
PIO-01-KF-48	KF	Kitchen faucets	B131	6/29/2016	0653	P	2.57	P	<1.00							
PIO-01-CF-49	CF	Classroom faucets	B142	6/29/2016	0657	P	1.90	P	<1.00							
PIO-01-CF-50	CF	Classroom faucets	B139	6/29/2016	0654	P	2.97	P	<1.00							
PIO-01-CF-51	CF	Classroom faucets	B132	6/29/2016	0655	P	4.00	P	<1.00							
PIO-01-CF-52	CF	Classroom faucets	B133	6/29/2016	0659	P	3.96	P	<1.00							
PIO-01-CF-53	CF	Classroom faucets	B134	6/29/2016	0701	P	4.11	P	<1.00							
PIO-01-CF-54	CF	Classroom faucets	B137	6/29/2016	0700	P	4.89	P	<1.00							
PIO-01-CF-55	CF	Classroom faucets	B136	6/29/2016	0702	P	3.67	P	<1.00							

Pittsburgh South Annex (Online)

Drinking Water Sample Results

School: Pittsburgh South Annex (Online)

Address: 93 S 10th Street, Pittsburgh PA, 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
SOU-BS-SL-00	SL	Service Line	5	6/28/2016	0611	P	<1.00									
SOU-BS-WM-00	WM	Water Main	5	6/28/2016	0614	P	1.41									
SOU-01-CF-2	CF	Classroom faucets	104	6/28/2016	0619	F	48.2	P	4.29							Disconnected Completely
SOU-01-CF-3	CF	Classroom faucets	104	6/28/2016	0620	F	122	P	3.78							Disconnected Completely
SOU-01-CF-4	CF	Classroom faucets	104	6/28/2016	0621	P	17.6	P	3.08							
SOU-01-CF-5	CF	Classroom faucets	103	6/28/2016	0627	F	27.2	P	1.43							Disconnected Completely
SOU-01-WFC-15	WFC	Water Filtering Chiller	CORR 100A	6/28/2016	0634	P	2.41	P	1.2	8/12/2016	0710			P	<1.00	New Filtering Chiller With Bottle Filler
SOU-01-MS-18	MS	Miscellaneous sinks	108	6/28/2016	0636	P	2.86	P	1.04							
SOU-02-WC-44	WC	Water fountain with cooler	207	6/28/2016	0643	P	<1.00	P	1.05							
SOU-01-WO-41	WO	Water fountain without cooler	104	6/28/2016	0623	F	24.6	P	4.79							Disconnected Completely
SOU-02-MS-40	MS	Miscellaneous sinks	201	6/28/2016	0728	P	12	P	1.57							

Pittsburgh South Brook 6-8

Drinking Water Sample Results

School: Pittsburgh South Brook 6-8

779 Dunster Street, Pittsburgh PA, 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
SBK-01-NF-37	NF	Nurse's office sink faucets	109	6/29/2016	0712	P	<1.00	P	<1.00							
SBK-01-IM-39	IM	Ice machines	121	6/29/2016	0725	P	<1.00									
SBK-01-WC-41	WC	Water fountain with cooler	101	6/29/2016	0716	P	<1.00	P	<1.00							
SBK-01-WC-42	WC	Water fountain with cooler	101	6/29/2016	0717	P	<1.00	P	<1.00							
SBK-01-KF-45	KF	Kitchen faucets	119	6/29/2016	0728	P	<1.00	P	<1.00							
SBK-01-TF-46	TF	Teacher's lounge sinks	122	6/29/2016	0729	P	1.03	P	<1.00							
SBK-01-CF-47	CF	Classroom faucets	131	6/29/2016	0730	P	1.33	P	<1.00							
SBK-01-CF-48	CF	Classroom faucets	132	6/29/2016	0731	P	<1.00	P	<1.00							
SBK-01-CF-49	CF	Classroom faucets	133	6/29/2016	0733	P	<1.00	P	<1.00							
SBK-01-CF-50	CF	Classroom faucets	133	6/29/2016	0734	P	<1.00	P	<1.00							
SBK-01-CF-51	CF	Classroom faucets	127	6/29/2016	0732	P	<1.00	P	<1.00							
SBK-01-CF-52	CF	Classroom faucets	128	6/29/2016	0735	P	<1.00	P	<1.00							
SBK-01-CF-53	CF	Classroom faucets	129	6/29/2016	0736	P	<1.00	P	<1.00							
SBK-01-WC-58	WC	Water fountain with cooler	GYM LOBBY	6/29/2016	0737	P	<1.00	P	<1.00							
SBK-01-WC-59	WC	Water fountain with cooler	GYM LOBBY	6/29/2016	0738	P	<1.00	P	<1.00							
SBK-02-CF-69	CF	Classroom faucets	217	6/29/2016	0743	P	1.28	P	<1.00							
SBK-02-CF-70	CF	Classroom faucets	218	6/29/2016	0744	P	<1.00	P	<1.00							
SBK-02-CF-71	CF	Classroom faucets	225	6/29/2016	0745	P	<1.00	P	<1.00							
SBK-02-CF-72	CF	Classroom faucets	225	6/29/2016	0746	P	<1.00	P	<1.00							
SBK-02-CF-73	CF	Classroom faucets	222	6/29/2016	0747	P	<1.00	P	<1.00							
SBK-02-CF-74	CF	Classroom faucets	223	6/29/2016	0748	P	<1.00	P	<1.00							
SBK-02-CF-75	CF	Classroom faucets	224	6/29/2016	0749	P	1.39	P	<1.00							
SBK-02-WC-80	WC	Water fountain with cooler	219	6/29/2016	0750	P	<1.00	P	<1.00							
SBK-02-WFC-81	WFC	Water Filtering Chiller	219	6/29/2016	0751	P	1.04	P	1.83	8/9/2016	0615			P	<1.00	Water Filtering Chiller with Bottle Filler

Drinking Water Sample Results

School: Pittsburgh Sterrett 6-8

Address: 7100 Reynolds Street, Pittsburgh PA, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
STE-GF-SL-00	SL	Service Line	JAN. OFFICE	6/30/2016	0644	P	< 1.00									
STE-GF-WM-00	WM	Water Main	JAN. OFFICE	6/30/2016	0647	P	< 1.00									
STE-GF-US-1	US	Utility sinks	BOILER ROOM	6/30/2016	0643	P	1.25	P	1.01							
STE-GF-CF-3	CF	Classroom faucets	E104	6/30/2016	0649	P	< 1.00	P	< 1.00							
STE-GF-WO-4	WO	Water fountain without cooler	OUTSIDE STAIRS	6/30/2016	0651	P	3.97	P	1.01							
STE-GF-WO-5	WO	Water fountain without cooler	OUTSIDE STAIRS	6/30/2016	0652	P	3.83	P	1.87							
STE-GF-CF-6	CF	Classroom faucets	881 SF	6/30/2016	0655	P	1.37	P	< 1.00							
STE-GF-CF-7	CF	Classroom faucets	881 SF	6/30/2016	0656	P	3.21	P	< 1.00							
STE-GF-WC-31	WC	Water fountain with cooler	OUTSIDE STAFF	6/30/2016	0657	P	1.06	P	< 1.00							
STE-GF-WC-32	WC	Water fountain with cooler	OUTSIDE STAFF	6/30/2016	0658	P	< 1.00	P	< 1.00							
STE-GF-WC-38	WC	Water fountain with cooler	115	6/30/2016	0701	P	< 1.00	P	< 1.00							
STE-GF-WC-39	WC	Water fountain with cooler	115	6/30/2016	0702	P	< 1.00	P	< 1.00							
STE-GF-KF-40	KF	Kitchen faucets	116	6/30/2016	0706	P	1.37	P	< 1.00							
STE-GF-KF-42	KF	Kitchen faucets	116	6/30/2016	0704	P	2.47	P	< 1.00							
STE-01-WO-45	WO	Water fountain without cooler	OUTSIDE RR	6/30/2016												Not Functioning
STE-01-WFC-46	WFC	Water Filtering Chiller	OUTSIDE RR	6/30/2016	0710	P	< 1.00	P	< 1.00	8/10/2016	0612			P	< 1.00	Water Filtering Chiller with Bottle Filler
STE-01-WO-49	WO	Water fountain without cooler	ACROSS FROM RM 104	6/30/2016	0713	P	< 1.00	P	< 1.00							
STE-01-WO-50	WO	Water fountain without cooler	ACROSS FROM RM 104	6/30/2016												Not Functioning
STE-01-CF-52	CF	Classroom faucets	105	6/30/2016	0716	P	4.06	P	< 1.00							
STE-01-TF-53	TF	Teacher's lounge sinks	E202	6/30/2016	0711	P	1.21	P	< 1.00							
STE-01-NF-54	NF	Nurse's office sink faucets	201	6/30/2016	0718	P	< 1.00	P	1.35							
STE-01-WC-62	WC	Water fountain with cooler	OUTSIDE 205	6/30/2016	0721	P	< 1.00	P	< 1.00							
STE-01-WC-63	WC	Water fountain with cooler	OUTSIDE 205	6/30/2016	0722	P	< 1.00	P	< 1.00							
STE-02-WO-69	WO	Water fountain without cooler	OUTSIDE BOYS RR	6/30/2016												Not Functioning
STE-02-WO-70	WO	Water fountain without cooler	OUTSIDE BOYS RR	6/30/2016	0738	P	< 1.00	P	< 1.00							
STE-02-TF-75	TF	Teacher's lounge sinks	NEXT TO 207	6/30/2016	0740	F	24.6	P	2.34	8/10/2016	0610	F	23.5			
STE-02-WO-76	WO	Water fountain without cooler	OUTSIDE GIRLS RR	6/30/2016	0735	P	< 1.00	P	< 1.00							
STE-02-WO-77	WO	Water fountain without cooler	OUTSIDE GIRLS RR	6/30/2016	0736	P	< 1.00	P	< 1.00							
STE-02-CF-85	CF	Classroom faucets	203	6/30/2016	0733	P	15.0	P	1.42							
STE-GF-KF-86	KF	Kitchen faucets	116	6/30/2016	0705	P	2.00	P	< 1.00							
STE-01-MS-87	MS	Miscellaneous sinks	LIBRARY	6/30/2016	0725	P	1.71	P	< 1.00							

Pittsburgh Sunnyside PreK-8

Lead in Drinking Water Sample Results

School: Pittsburgh Sunnyside PreK-8

Address: 4801 Stanton Avenue, Pittsburgh PA, 15201

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
SUN-BS-SL-0	SL	Service Line	BOILER ROOM	6/17/2016	0609	P	<1.00									
SUN-BS-WM-0	WM	Water Main	BOILER ROOM	6/17/2016	0615	P	<1.00									
SUN-01-CF-2	CF	Classroom faucets	124	6/17/2016	0624	P	<1.00	P	<1.00							
SUN-01-WO-5	WO	Water fountain without cooler	CORR 103	6/17/2016	0619	P	2.21	P	1.14							
SUN-01-WO-6	WO	Water fountain without cooler	CORR 103	6/17/2016	0620	P	1.45	P	<1.00							
SUN-01-MS-15	MS	Miscellaneous sinks	115	6/17/2016	0721	P	1.84	P	<1.00							
SUN-01-TF-17	TF	Teacher's lounge sinks	112	6/17/2016	0720	P	6.53	P	<1.00							
SUN-01-MS-18	MS	Miscellaneous sinks	111	6/17/2016	0722	P	3.42	P	<1.00							
SUN-01-NF-19	NF	Nurse's office sink faucets	110	6/17/2016	0724	P	<1.00	P	<1.00							
SUN-01-WC-28	WC	Water fountain with cooler	190	6/17/2016	0734	P	<1.00	P	<1.00							
SUN-01-WC-29	WC	Water fountain with cooler	190	6/17/2016	0735	P	<1.00	P	<1.00							
SUN-01-KF-31	KF	Kitchen faucets	192	6/17/2016	0741	P	3.39	P	1.36							
SUN-01-KF-32	KF	Kitchen faucets	192	6/17/2016	0742	P	2.31	P	1.88							
SUN-01-WO-54	WO	Water fountain without cooler	CORR 102	6/17/2016	0750	P	2.97	P	1.47							
SUN-01-WFC-55	WFC	Water Filtering Chiller	CORR 102	6/17/2016	0751	P	1.62	P	<1.00	8/10/2016	0718			P	<1.00	Water Filtering Chiller with Bottle Filler
SUN-01-CF-61	CF	Classroom faucets	149	6/17/2016	0754	P	2.65	P	<1.00							
SUN-01-CF-62	CF	Classroom faucets	147	6/17/2016	0755	P	9.2	P	2.06							
SUN-01-CF-63	CF	Classroom faucets	145	6/17/2016	0758	F	48.7	P	4.16	8/10/2016	0715	P	17.3			
SUN-01-CF-64	CF	Classroom faucets	146	6/17/2016	0800	P	5.77	P	3.09							
SUN-01-WO-65	WO	Water fountain without cooler	CORR 102	6/17/2016	0802	P	5.25	P	1.9							
SUN-01-WO-66	WO	Water fountain without cooler	CORR 102	6/17/2016	0803	P	1.62	P	<1.00							
SUN-01-CF-67	CF	Classroom faucets	126	6/17/2016	0626	P	1.86	P	<1.00							
SUN-01-CF-68	CF	Classroom faucets	127	6/17/2016	0628	P	1.14	P	<1.00							
SUN-01-CF-69	CF	Classroom faucets	128	6/17/2016	0632	P	<1.00	P	<1.00							
SUN-01-CF-70	CF	Classroom faucets	129	6/17/2016	0634	P	<1.00	P	<1.00							
SUN-01-WO-71	WO	Water fountain without cooler	CORR 103													Not Functioning
SUN-01-WO-72	WO	Water fountain without cooler	CORR 103	6/17/2016	0637	P	6.79	P	1.32							
SUN-01-CF-73	CF	Classroom faucets	131	6/17/2016	0639	P	2.79	P	<1.00							
SUN-01-CF-75	CF	Classroom faucets	132	6/17/2016	0642	P	<1.00	P	<1.00							
SUN-01-CF-76	CF	Classroom faucets	132	6/17/2016	0643	P	9.75	P	1.65							
SUN-01-CF-79	CF	Classroom faucets	136	6/17/2016	0647	P	<1.00	P	<1.00							
SUN-01-CF-85	CF	Classroom faucets	140	6/17/2016	0654	P	<1.00	P	1.08							
SUN-01-WC-86	WC	Water fountain with cooler	CORR 160	6/17/2016	0650	P	10	P	8.59							
SUN-01-WC-87	WC	Water fountain with cooler	CORR 160	6/17/2016	0651	P	7.92	P	9.06							
SUN-01-CF-88	CF	Classroom faucets	140	6/17/2016	0659	P	16.5	P	3.29							
SUN-01-CF-89	CF	Classroom faucets	140	6/17/2016	0702	P	9.49	P	5.47							
SUN-01-CF-91	CF	Classroom faucets	142	6/17/2016	0708	P	<1.00	P	2.83							
SUN-01-CF-92	CF	Classroom faucets	142	6/17/2016	0709	P	1.9	P	<1.00							
SUN-01-CF-95	CF	Classroom faucets	140	6/17/2016	0700	P	11.4	P	4.49							
SUN-01-CF-96	CF	Classroom faucets	140	6/17/2016	0703	P	3.48	P	6.31							
SUN-01-WC-93	WC	Water fountain with cooler	180	6/17/2016	0727	P	<1.00	P	<1.00							
SUN-01-WC-94	WC	Water fountain with cooler	172	6/17/2016	0738	P	<1.00	P	<1.00							
SUN-01-KF-97	KF	Kitchen faucets	192	6/17/2016	0743	P	2.8	P	1.68							

Lead in Drinking Water Sample Results

School: Pittsburgh Weil PreK-5

Address: 2250 Centre Avenue, Pittsburgh PA, 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
WEI-BS-SL-0	SL	Service Line	12	6/16/2016	0612	P	<1.00									
WEI-BS-WM-0	WM	Water Main	12	6/16/2016	0615	P	<1.00									
WEI-BS-MS-1	MS	Miscellaneous sinks	7	6/16/2016	0610	P	<1.00	P	1.33							
WEI-01-WFC-9	WFC	Water Filtering Chiller	CORRIDOR 100	6/16/2016	0620	P	<1.00	P	1.02	8/12/2016	0633			P	<1.00	Water Filtering Chiller with Bottle Filler
WEI-02-WO-10	WO	Water fountain without cooler	CORRIDOR 100	6/16/2016	0622	P	1.17	P	1.36							
WEI-01-NF-11	NF	Nurse's office sink faucets	102	6/16/2016	0637	P	<1.00	P	<1.00							
WEI-01-CF-15	CF	Classroom faucets	111A	6/16/2016	0649	P	4.71	P	<1.00							
WEI-01-WO-17	WO	Water fountain without cooler	111B	6/16/2016	0650	P	<1.00	P	1.03							
WEI-01-WFC-18	WFC	Water Filtering Chiller	CORRIDOR 100	6/16/2016	0645	P	<1.00	P	1.35	8/12/2016	0630			P	<1.00	Water Filtering Chiller with Bottle Filler
WEI-01-WO-19	WO	Water fountain without cooler	CORRIDOR 100	6/16/2016	0646	P	1.21	P	1.17							
WEI-01-CF-24	CF	Classroom faucets	112	6/16/2016	0643	P	<1.00	P	<1.00							
WEI-01-CF-25	CF	Classroom faucets	113	6/16/2016	0641	P	1.41	P	<1.00							
WEI-01-CF-26	CF	Classroom faucets	114	6/16/2016	0639	P	12.4	P	2.63							
WEI-01-CF-27	CF	Classroom faucets	115	6/16/2016	0635	P	<1.00	P	<1.00							
WEI-01-CF-28	CF	Classroom faucets	120	6/16/2016	0630	P	<1.00	P	<1.00							
WEI-01-CF-31	CF	Classroom faucets	121	6/16/2016	0634	P	<1.00	P	<1.00							
WEI-01-KF-32	KF	Kitchen faucets	130	6/16/2016	0626	P	<1.00	P	<1.00							
WEI-02-TF-35	TF	Teacher's lounge sinks	209	6/16/2016	0658	P	<1.00	P	<1.00							
WEI-02-WFC-38	WFC	Water Filtering Chiller	CORRIDOR 200	6/16/2016	0656	P	<1.00	P	1.21	8/12/2016	0628			P	<1.00	Water Filtering Chiller with Bottle Filler
WEI-02-WO-39	WO	Water fountain without cooler	CORRIDOR 200	6/16/2016	0657	P	1.05	P	1.4							
WEI-02-WO-40	WO	Water fountain without cooler	CORRIDOR 200B	6/16/2016	0702	P	1.47	P	1.11							
WEI-02-WO-41	WO	Water fountain without cooler	CORRIDOR 200B	6/16/2016	0703	P	2.01	P	<1.00							
WEI-02-CF-42	CF	Classroom faucets	210	6/16/2016	0705	P	4.43	P	1.02							
WEI-02-CF-43	CF	Classroom faucets	210	6/16/2016	0706	P	2.11	P	1.05							
WEI-02-CF-44	CF	Classroom faucets	208	6/16/2016	0709	P	8.18	P	1.26							
WEI-02-CF-45	CF	Classroom faucets	207	6/16/2016	0712	F	20.8	P	1.71	8/12/2016	0625	P	8.39			
WEI-02-CF-46	CF	Classroom faucets	206	6/16/2016	0713	P	1.94	P	1.47							
WEI-02-WO-51	WO	Water fountain without cooler	CORRIDOR 200	6/16/2016	0716	P	<1.00	P	<1.00							
WEI-02-WO-52	WO	Water fountain without cooler	CORRIDOR 200	6/16/2016	0717	P	<1.00	P	<1.00							
WEI-03-WO-55	WO	Water fountain without cooler	CORRIDOR 300A	6/16/2016	0719	P	1.78	P	1.03							
WEI-03-WO-56	WO	Water fountain without cooler	CORRIDOR 300A	6/16/2016	0720	P	1.87	P	<1.00							
WEI-03-WO-61	WO	Water fountain without cooler	CORRIDOR 300A	6/16/2016	0723	P	<1.00	P	<1.00							
WEI-03-WO-62	WO	Water fountain without cooler	CORRIDOR 300A	6/16/2016	0724	P	<1.00	P	<1.00							

Pittsburgh West Liberty K-5

Drinking Water Sample Results

School: Pittsburgh West Liberty K-5

Address: 785 Dunster Street, Pittsburgh PA, 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (Fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
WLB-B5-SL-00	SL	Service Line	BOILER ROOM	6/29/2016	0609	P	<1.00									
WLB-B5-WM-00	WM	Water Main	BOILER ROOM	6/29/2016	0612	P	<1.00									
WLB-B5-MS-3	MS	Miscellaneous sinks	B-11	6/29/2016	0613	P	2.31	P	<1.00							
WLB-01-WO-7	WO	Water fountain without cooler	CORR 100	6/29/2016	0627	P	1.01	P	<1.00							
WLB-01-WO-8	WO	Water fountain without cooler	CORR 100	6/29/2016	0628	P	1.87	P	<1.00							
WLB-01-NF-13	NF	Nurse's office sink faucets	113	6/29/2016	0635	P	6.60	P	<1.00							
WLB-01-NF-15	NF	Nurse's office sink faucets	117	6/29/2016	0636	F	47.4	P	8.25							Disconnected Completely
WLB-02-WO-17	WO	Water fountain without cooler	139	6/29/2016	0618	P	<1.00	P	<1.00							
WLB-01-KF-20	KF	Kitchen faucets	138	6/29/2016	0620	P	2.82	P	<1.00							
WLB-01-IM-21	IM	Ice machines	138	6/29/2016		P		P								Not Functioning
WLB-01-CF-23	CF	Classroom faucets	123	6/29/2016	0640	P	<1.00	P	<1.00							
WLB-01-CF-24	CF	Classroom faucets	123	6/29/2016	0641	P	5.83	P	<1.00							
WLB-01-WO-27	WO	Water fountain without cooler	CORR 100	6/29/2016	0649	P	1.27	P	1.50							
WLB-01-WO-28	WO	Water fountain without cooler	CORR 100	6/29/2016	0650	P	<1.00	P	<1.00							
WLB-02-WO-33	WO	Water fountain without cooler	CORR 200	6/29/2016	0702	P	1.38	P	<1.00							
WLB-02-WFC-34	WFC	Water Filtering Chiller	CORR 200	6/29/2016	0703	P	2.51	P	<1.00	8/9/2016	0603			P	<1.00	Water Filtering Chiller with Bottle Filler
WLB-02-CF-38	CF	Classroom faucets	218	6/29/2016	0656	P	2.59	P	<1.00							
WLB-02-MS-40	MS	Miscellaneous sinks	207	6/29/2016	0707	P	2.31	P	<1.00							
WLB-02-WO-41	WO	Water fountain with filter & cooler	CORR 200	6/29/2016	0712	P	1.03	P	<1.00							
WLB-02-WO-42	WO	Water fountain with filter & cooler	CORR 200	6/29/2016	0713	P	<1.00	P	<1.00							
WLB-02-CF-46	CF	Classroom faucets	208	6/29/2016	0711	P	5.06	P	2.71							
WLB-01-KF-47	KF	Kitchen faucets	138	6/29/2016	0621	P	<1.00	P	<1.00							
WLB-01-CF-48	CF	Classroom faucets	128	6/29/2016	0645	P	<1.00	P	1.28							
WLB-02-CF-49	CF	Classroom faucets	218	6/29/2016	0657	F	23.3	P	2.83	8/9/2016	0600	P	1.16			

Pittsburgh Westinghouse 6-12

School: Pittsburgh Westinghouse 6-12 Address: 1101 N. Murtland Street, Pittsburgh PA, 15208

Pittsburgh Westinghouse 6-12

Address: 1101 N. Murtland Street, Pittsburgh PA, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
WES-BS-SL-0	SL	Service Line	921	6/14/2016	0536	P	<1.00									
WES-BS-WM-0	WM	Water Main	921	6/14/2016	0538	P	<1.00									
WES-BS-WO-1	WO	Water fountain without cooler	DINING AREA	6/14/2016	0546	P	<1.00	P	<1.00							
WES-BS-WO-2	WO	Water fountain without cooler	DINING AREA	6/14/2016	0547	P	<1.00	P	<1.00							
WES-BS-KF-5	KF	Kitchen faucets	935	6/14/2016	0539	P	<1.00	P	<1.00							
WES-BS-KF-7	KF	Kitchen faucets	935	6/14/2016	0541	P	1.95	P	<1.00							
WES-BS-KF-8	KF	Kitchen faucets	935	6/14/2016	0542	P	1.44	P	<1.00							
WES-BS-KF-9	KF	Kitchen faucets	935	6/14/2016	0543	P	2.36	P	<1.00							
WES-BS-WO-13	WO	Water fountain without cooler	977	6/14/2016	0605	P	<1.00	P	<1.00							
WES-BS-IM-25	IM	Ice machines	976	6/14/2016	0606	P	<1.00	P								
WES-BS-WO-29	WO	Water fountain without cooler	975	6/14/2016	0604	P	1.17	P	<1.00							
WES-BS-WO-41	WO	Water fountain without cooler	CORR F	6/14/2016	0555	P	4.19	P	2.01							
WES-SB-MS-45	MS	Miscellaneous sinks	875B	6/14/2016	0848	P	1.28	P	<1.00							
WES-SB-WO-66	WO	Water fountain without cooler	872 POOL	6/14/2016	0612	P	<1.00	P	<1.00							
WES-SB-WO-67	WO	Water fountain without cooler	873 POOL	6/14/2016												Not Functioning
WES-GF-WO-74	WO	Water fountain without cooler	CORR B	6/14/2016												Not Functioning
WES-GF-WO-75	WO	Water fountain without cooler	CORR B	6/14/2016	0638	P	<1.00	P	<1.00							
WES-GF-CF-76	CF	Classroom faucets	11	6/14/2016	0637	P	<1.00	P	<1.00							
WES-GF-WO-80	WO	Water fountain without cooler	CORR B	6/14/2016	0641	P	3.13	P	<1.00							
WES-GF-WO-81	WO	Water fountain without cooler	CORR B	6/14/2016	0642	P	<1.00	P	<1.00							
WES-GF-CF-82	CF	Classroom faucets	67	6/14/2016	0644	P	<1.00	P	<1.00							
WES-GF-MS-83	MS	Miscellaneous sinks	67	6/14/2016	0842	P	6.51	P	1.12							
WES-GF-CF-102	CF	Classroom faucets	22	6/14/2016	0647	P	<1.00	P	<1.00							
WES-GF-NF-105	NF	Nurse's office sink faucets	046C	6/14/2016	0702	P	1.33	P	1.03							
WES-GF-NF-106	NF	Nurse's office sink faucets	046D	6/14/2016	0703	F	35.2	P	1.98	8/10/2016	0633	P	1.72			
WES-GF-NF-107	NF	Nurse's office sink faucets	046E	6/14/2016	0659	P	11.3	P	2.61							
WES-GF-NF-117	NF	Nurse's office sink faucets	52D	6/14/2016	0653	P	16	P	1.15							
WES-GF-NF-118	NF	Nurse's office sink faucets	52C	6/14/2016	0654	P	11.1	P	1.97							
WES-GF-WO-128	WO	Water fountain without cooler	CORR D	6/14/2016	0650	P	<1.00	P	<1.00							
WES-GF-WO-129	WO	Water fountain without cooler	CORR D	6/14/2016	0651	P	<1.00	P	<1.00							
WES-GF-WO-163	WO	Water fountain without cooler	GYM	6/14/2016	0614	P	<1.00	P	<1.00							
WES-GF-WO-169	WO	Water fountain without cooler	77	6/14/2016	0619	P	1.40	P	1.83							
WES-GF-WO-172	WO	Water fountain with cooler	GYM	6/14/2016	0615	P	<1.00	P	<1.00							
WES-GF-WC-173	WC	Water fountain with cooler	LOBBY	6/14/2016												Not Functioning
WES-GF-WC-174	WC	Water fountain with cooler	LOBBY	6/14/2016												Not Functioning
WES-GF-MS-183	MS	Miscellaneous sinks	67	6/14/2016	0624	P	<1.00	P	<1.00							
WES-GF-KF-185	KF	Kitchen faucets	69	6/14/2016	0627	P	<1.00	P	<1.00							
WES-GF-KF-186	KF	Kitchen faucets	69	6/14/2016												Not Functioning
WES-GF-KF-187	KF	Kitchen faucets	69	6/14/2016	0628	P	1.11	P	<1.00							
WES-GF-KF-188	KF	Kitchen faucets	69	6/14/2016	0629	P	3.32	P	<1.00							
WES-GF-KF-190	KF	Kitchen faucets	69	6/14/2016	0629	P	<1.00	P	<1.00							
WES-GF-KF-191	KF	Kitchen faucets	69	6/14/2016	0630	P	3.69	P	<1.00							
WES-GF-IM-192	IM	Ice machines	69	6/14/2016	0632	P	<1.00	P								
WES-01-WO-198	WO	Water fountain without cooler	CORR B	6/14/2016	0710	P	<1.00	P	<1.00							
WES-01-WFC-199	WFC	Water Filtering Chiller	CORR B	6/14/2016	0711	P	<1.00	P	<1.00	8/10/2016	0636			P	<1.00	Water Filtering Chiller with Bottle Filler
WES-01-TF-205	TF	Teacher's lounge sinks	111	6/14/2016	0708	P	2.26	P	<1.00							
WES-01-MS-206	MS	Miscellaneous sinks	121	6/14/2016	0727	F	24.0	P	1.88	8/10/2016	0637	P	1.85			
WES-01-CF-207	CF	Classroom faucets	125A	6/14/2016	0714	P	12.5	P	<1.00							
WES-01-CF-208	CF	Classroom faucets	125A	6/14/2016	0715	P	3.53	P	<1.00							
WES-01-WO-209	WO	Water fountain without cooler	125A	6/14/2016												Not Functioning
WES-01-MS-212	MS	Miscellaneous sinks	125B	6/14/2016	0718	P	12.6	P	<1.00							
WES-01-WO-216	WO	Water fountain without cooler	CORR D	6/14/2016	0730	P	<1.00	P	<1.00							
WES-01-WO-217	WO	Water fountain without cooler	CORR D	6/14/2016	0731	P	<1.00	P	<1.00							
WES-01-WO-243	WO	Water fountain without cooler	149	6/14/2016	0733	P	<1.00	P	<1.00							
WES-01-WO-244	WO	Water fountain without cooler	147	6/14/2016	0736	P	<1.00	P	<1.00							
WES-01-CF-245	CF	Classroom faucets	147	6/14/2016	0735	P	1.14	P	<1.00							
WES-01-CF-246	CF	Classroom faucets	168	6/14/2016	0741	P	<1.00	P	<1.00							
WES-02-CF-273	CF	Classroom faucets	242	6/14/2016												Sink Removed

Pittsburgh Westinghouse Field House

Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse Field House

Address: 1102 N. Murtland Street, Pittsburgh PA, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Locations	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Retest Sample Date	Retest Sample Time	Retest First Draw Pass/Fail (C)	Retest First Draw Lead Concentration (ppb)	Retest First Draw Pass/Fail (N)	Retest First Draw Lead Concentration (ppb)	Comments
WFH-GF-SL-0	SL	Service Line	Mechanical Room	6/14/2016	1651	P	<1.00									
WFH-GF-WM-0	WM	Water Main	Mechanical Room	6/14/2016	1654	P	<1.00									
WFH-GF-MS-1	MS	Miscellaneous sinks	Mechanical Room	6/14/2016	1650	P	<1.00	P	<1.00							
WFH-GF-IM-2	IM	Ice machines	Mechanical Room	6/14/2016	1655	P	<1.00									
WFH-GF-MS-3	MS	Miscellaneous sinks	Office	6/14/2016	1657	P	2.58	P	<1.00							
WFH-GF-MS-9	MS	Miscellaneous sinks	Concession Room	6/14/2016	1700	P	16.6	P	1.35							
WFH-GF-MS-10	MS	Miscellaneous sinks	Concession Room	6/14/2016	1701	F	24.9	P	1.38	8/10/2016	0709	P	17.4			