

LEAD IN DRINKING WATER SAMPLING

of

Pittsburgh Public Schools Drinking Water Quality Initiative 2022

Survey Date: April 12 – August 25, 2022

Prepared for:

**PITTSBURGH PUBLIC SCHOOLS
FACILITIES
1305 MURIEL STREET
PITTSBURGH, PENNSYLVANIA 15203**

Prepared by:

SKELLY AND LOY

A  Terracon Company

**SKELLY and LOY, Inc., A Terracon Company
Engineers-Consultants
Pittsburgh, PA**

December 20, 2022

Table of Content

1.	INTRODUCTION	1
2.	SAMPLING METHODOLOGY	1
3.	LEAD IN DRINKING WATER RESULTS AND DISCUSSION	2
4.	BUILDING SUMMARY OF NUMBERS OF FIXTURES AND WATER SAMPLES.....	11
5.	RECOMMENDATIONS	12

APPENDICES:

APPENDIX A	DRINKING WATER RESULTS TABLE
APPENDIX B	LABORATORY RESULTS
APPENDIX C	FIXTURE MAPS

1. INTRODUCTION

Skelly and Loy, a Terracon Company was retained by Pittsburgh Public School's (PPS) to test for the presence of lead in drinking water at 33 buildings, including 29 academic school buildings, 3 athletic field houses, and the District Administration Building.

Fixture verification and water sample collection were conducted at the 33 PPS buildings from April 12 through August 25, 2022. The objective of the drinking water sampling and analytical testing was to screen the designated drinking water for lead concentrations from drinking water fountains; to include ceramic/porcelain fountains, water fountains with coolers, water fountains without coolers, and glass/bottle filler stations.

Additional fixtures were tested to include classroom faucets, field house sinks, home economics faucets, ice machines, kitchen faucets, multi-purpose room/cafeteria faucets, nurse's office sink faucets, office sink faucets, teacher's lounge faucets, miscellaneous sink faucets and water from the main service line supplying water to the building.

Fixtures that were not in operation, had insufficient water flow, or were observed to have "Handwash Only" signage were not sampled as part of this survey.

2. SAMPLING METHODOLOGY

Water sampling collection, delivery and analysis was conducted according to the Environmental Protection Agency's (EPA's) "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002," April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance," October 2018.

The Pennsylvania Public School Code, Act 39 - Section 742; as amended on June 22, 2018, states that the lead levels in drinking water should not exceed the EPA's National Primary Drinking Water Regulations, Action Level for lead, currently 15 parts per billion (ppb). The purpose of this water sampling effort is to help minimize exposure to school students and staff to lead in drinking water at PPS facilities.

All water samples were collected in 250 mL plastic containers that were prepackaged by the analytical laboratory. At each water sample location, the first draw water sample was collected

after the water in the plumbing lines had been standing in the plumbing system for greater than eight (8) hours, but less than eighteen (18) hours. Each school building's water system was used the evening before the first-draw samples to follow the 3Ts water sampling protocols.

A second draw water sample was collected after the water from each fixture was discharged for 30 seconds after the first draw sample. This is called a purged-line or flushed sample. This water sample will show the lead content of water that has not been in contact with the fixture for an extended period of time.

All drinking water samples were analyzed for lead content by R.J. Lee, Inc., 350 Hochberg Road, Monroeville, Pennsylvania using EPA method 200.8 - Determination of Trace Elements in Waters and Wastes by Inductively Coupled Plasma - Mass Spectrometry (ICP-MS)." R.J. Lee is an independent Pennsylvania (PA) laboratory certified for drinking water analysis (PADEP Lab ID 02-00396 – NELAP).

3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION

Analytic results of the water samples were received and reviewed by Skelly and Loy in relation to EPA's "EPA's National Primary Drinking Water Regulations, Action Level for lead of 15 parts per billion (ppb). Lead concentrations above 15 ppb were considered to be elevated and response actions recommended to PPS to reduce the lead in the affected fixture. Following mitigation of the fixtures that exceeded the lead in Drinking Water Action Level, retesting of the drinking water was conducted. Mitigation of the fixtures included replacement of aerators, replacement of the fixture, or flushing water lines in areas of buildings where use of the fixtures was infrequent.

If the retest of the drinking water indicated lead levels below the Drinking Water Action Level, no further actions were taken. If the retesting of the drinking water indicated lead levels above the Drinking Water Action Level, affected fixtures were posted with "**Handwash Only**" signage. Where fixtures were deemed unnecessary by PPS, the fixtures were shut off or removed. The results of the drinking water retesting can be found in the 2022 Retest of Lead in Drinking Water Sampling report.

Below is a summary of the initial testing of fixtures at the 33 surveyed PPS buildings.

Administration Building:

At the PPS Administration Building, a total of 69 drinking water samples were collected from 36 drinking water and cooking use fixtures and faucets. **The results of six (6) water samples collected: 22-ADM-02-WB-39A (water fountain), 22-ADM-02-WO-49A (water fountain), 22-ADM-02-OF-50A (office sink faucet), 22-ADM-02-OF-51A (office sink faucet), 22-ADM-02-OF-51B (office sink faucet), and ADM-04-OF-69A (office sink faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Allderdice Field House:

At Pittsburgh Allderdice Field House, a total of 4 drinking water samples were collected from 3 drinking water and cooking use fixtures and faucets. **The result of one (1) water sample collected: 22-AFH-01-MS-08A (miscellaneous sink) indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Allderdice High School:

At Allderdice High School, a total of 150 drinking water samples were collected from 77 drinking water and cooking use fixtures and faucets. **The results of seven (7) water samples collected: 22-ALD-01-OF-29A (office sink), 22-ALD-01-WB-48A (water fountain), 22-ALD-01-CF-51A (classroom faucet), 22-ALD-02-WO-122A (water fountain), 22-ALD-03-WO-141A (water fountain), 22-ALD-03-CF-148A (classroom faucet), and 22-ALD-04-HF-296A (home economics faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Allegheny Annex:

At Pittsburgh Allegheny Annex, a total of 18 drinking water samples were collected from 10 drinking water and cooking use fixtures and faucets. **The results of three (3) water samples collected: 22-ALX-03-CF-22A (classroom faucet), 22-ALX-02-CF-33A (classroom faucet), and 22-ALX-02-CF-33B (classroom faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Allegheny K-5/6-8:

At Pittsburgh Allegheny K-5/6-8, a total of 86 drinking water samples were collected from 44 drinking water and cooking use fixtures and faucets. **None of the collected water samples indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Arsenal PreK-5/6-8:

At Pittsburgh Arsenal PreK-5/6-8, a total of 116 drinking water samples were collected from 59 drinking water and cooking use fixtures and faucets. **The results of four (4) water samples collected: 22-ARS-03-CF-115A (classroom faucet), 22-ARS-03-CF-106A (classroom faucet), 22-ARS-03-CF-106B (classroom faucet), and 22-ARS-03-CF-107A (classroom faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Beechwood PreK-5:

At Pittsburgh Beechwood PreK-5, a total of 68 drinking water samples were collected from 36 drinking water and cooking use fixtures and faucets. **The result of one (1) water sample collected: 22-BEE-BS-CF-05B (classroom faucet) indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Brashear High School/South Hills 6-8:

At Pittsburgh Brashear High School/South Hills 6-8, a total of 163 drinking water samples were collected from 83 drinking water and cooking use fixtures and faucets. **None of the collected water samples indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

CAPA 6-12:

At Pittsburgh CAPA 6-12, a total of 104 drinking water samples were collected from 54 drinking water and cooking use fixtures and faucets. **None of the collected water samples indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Carmalt PreK-8:

At Pittsburgh Carmalt PreK-8, a total of 80 drinking water samples were collected from 41 drinking water and cooking use fixtures and faucets. **The results of one (1) water sample collected: 22-CAR-02-TF-92A (teacher's lounge faucet) indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Colfax K-8:

At Pittsburgh Colfax K-8, a total of 100 drinking water samples were collected from 51 drinking water and cooking use fixtures and faucets. **The results of ten (10) water samples collected: 22-COL-BS-CF-01A (classroom faucet), 22-COL-BS-CF-16A (classroom faucet), 22-COL-01-CF-20A (classroom faucet), and 22-COL-01-CF-20B (classroom faucet), 22-COL-01-CF-41A (classroom faucet), 22-COL-01-CF-42A (classroom faucet), 22-COL-02-CF-59A (classroom faucet), 22-COL-02-CF-60A (classroom faucet), 22-COL-02-CF-81B (classroom faucet), and 22-COL-03-CF-99A (classroom faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Concord PreK-5:

At Pittsburgh Concord PreK-5, a total of 70 drinking water samples were collected from 34 drinking water and cooking use fixtures and faucets. **The result of one (1) water sample collected: 22-CON-02-CF-85A (classroom faucet) indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Conroy Education Center:

At Conroy Education Center, a total of 80 drinking water samples were collected from 41 drinking water and cooking use fixtures and faucets. **The results of three (3) water samples collected: 22-CNY-03-CF-100A (classroom faucet), 22-CNY-GF-WO-122A (water fountain), and 22-CNY-GF-WO-123A (water fountain) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Dilworth PreK-5:

At Pittsburgh Dilworth PreK-5, a total of 62 drinking water samples were collected from 32 drinking water and cooking use fixtures and faucets. **None of the collected water samples indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Fulton PreK-5:

At Pittsburgh Fulton PreK-5, a total of 38 drinking water samples were collected from 20 drinking water and cooking use fixtures and faucets. **The results of three (3) water samples collected: 22-FUL-BS-MS-03A (miscellaneous sink), 22-FUL-BS-MS-03B (miscellaneous sink), and 22-FUL-02-CF-40A (classroom faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Grandview K-5:

At Pittsburgh Grandview K-5, a total of 58 drinking samples were collected from 30 drinking water and cooking use fixtures and faucets. **The results of six (6) water samples collected: 22-GRD-01-CF-22A (classroom faucet), 22-GRD-01-CF-25A (classroom faucet), 22-GRD-01-CF-33A (classroom faucet), 22-GRD-01-CF-43A (classroom faucet), 22-GRD-01-CF-50A (classroom faucet), and 22-GRD-02-CF-77A (classroom faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Greenway (Classical-Gifted Center):

At Greenway Classical Gifted Center, a total of 138 drinking water samples were collected from 70 drinking water and cooking use fixtures and faucets. **The results of three (3) water samples collected: 22-GNW-2.4-CF-78A (classroom faucet), 22-GNW-2.4-CF-78B (classroom faucet), and 22-GNW-1.1-CF-135B (classroom faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Langley Field House

At Langley field House, a total of 9 drinking water samples were collected from 7 drinking water and cooking use fixtures and faucets. **None of the collected water samples indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Liberty K-5:

At Pittsburgh Liberty K-5, a total of 51 drinking samples were collected from 27 drinking water and cooking use fixtures and faucets. **None of the collected water samples indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Mifflin PreK-8:

At Pittsburgh Mifflin Pre K-8, a total of 84 drinking water samples were collected from 43 drinking water and cooking use fixtures and faucets. **The results of three (3) water samples collected: 22-MIF-GF-CF-14A (classroom faucet), 22-MIF-01-CF-88A (classroom faucet), and 22-MIF-01-CF-88B (classroom faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Minadeo PreK-5:

At Pittsburgh Minadeo PreK-5, a total of 108 drinking water samples were collected from 55 drinking water and cooking use fixtures and faucets. **None of the collected water samples indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Obama 6-12, ECC:

At Pittsburgh Obama 6-12, ECC, a total of 157 drinking water samples were collected from 80 drinking water and cooking use fixtures and faucets. **The results of nine (9) water samples collected: 22-OBA-GF-CF-11A (classroom faucet), OBA-01-OF-51A (office sink faucet), OBA-01-HF-63A (home economics faucet), OBA-01-HF-66A (home economics faucet), OBA-01-KF-76A (kitchen faucet), OBA-01-CF-111A (classroom faucet), OBA-01-KF-112A (kitchen faucet), OBA-02-CF-119A (classroom faucet), and OBA-03-CF-193A (classroom faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Oliver Field House:

At Pittsburgh Oliver Field House, a total of 8 drinking water samples were collected from 5 drinking water and cooking use fixtures and faucets. **None of the collected water samples indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Oliver:

At Pittsburgh Oliver, a total of 128 drinking water samples were collected from 65 drinking water and cooking use fixtures and faucets. **The results of six (6) water samples collected: 22-OLI-BS-MS-15A (miscellaneous sink), 22-OLI-GF-CF-41A (classroom faucet), 22-OLI-GF-CF-41B (classroom faucet), 22-OLI-GF-OF-122A (office sink), 22-OLI-01-CF-130A (classroom faucet), and 22-OLI-GF-KF-128A (kitchen faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Phillips K-5:

At Pittsburgh Phillips K-5, a total of 28 drinking water samples were collected from 15 drinking water and cooking use fixtures and faucets. **None of the collected water samples indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Roosevelt Pre K-1:

At Pittsburgh Roosevelt PreK-1, a total of 14 drinking water samples were collected from 8 drinking water and cooking use fixtures and faucets. **None of the collected water samples indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Schiller 6-8:

At Pittsburgh Schiller 6-8, a total of 42 drinking water samples were collected from 22 drinking water and cooking use fixtures and faucets. **The result of one (1) water sample collected: 22-SCH-01-OF-46A (office sink faucet) indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Spring Garden ECC:

At Pittsburgh Spring Garden ECC, a total of 36 drinking water samples were collected from 19 drinking water and cooking use fixtures and faucets. **The result of one (1) water sample collected: 22-SPG-01-CF-35A (classroom faucet) indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Spring Hill K-5:

At Pittsburgh Spring Hill K-5, a total of 42 drinking water samples were collected from 22 drinking water and cooking use fixtures and faucets. **The result of one (1) water sample collected: 22-SRG-02-CF-35A (classroom faucet) indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Student Achievement Center:

At Pittsburgh Student Achievement Center, a total of 48 drinking water samples were collected from 25 drinking water and cooking use fixtures and faucets. **The results of three (3) water samples collected: 22-SAC-02-CF-36A (classroom faucet), 22-SAC-02-CF-40A (classroom faucet), and 22-SAC-03-WC-54B (water fountain) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Westwood PreK-5:

At Pittsburgh Westwood PreK-5, a total of 62 drinking water samples were collected from 32 drinking water and cooking use fixtures and faucets. **The result of one (1) water sample collected: 22-WWD-GF-CF-13A (classroom faucet) indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Whittier K-5:

At Pittsburgh Whittier K-5, a total of 48 drinking water samples were collected from 25 drinking water and cooking use fixtures and faucets. **The results of two (2) water samples collected: 22-WHI-01-CF-29A (classroom faucet) and 22-WHI-01-CF-30A (classroom faucet) indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Woolslair K-5:

At Pittsburgh Woolslair K-5, a total of 54 drinking water samples were collected from 28 drinking water and cooking use fixtures and faucets. **The result of one (1) water sample collected: 22-WOL-02-CF-34A (classroom faucet) indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

4. BUILDING SUMMARY OF NUMBERS OF FIXTURES AND WATER SAMPLES

The below table lists the date sampled, building, the total number of the fixtures sampled, and the total number of drinking water samples collected. Floor plans for fixture locations are provided in Appendix C.

Date Sampled	School/Building	Total # of Fixtures	# of Samples Collected
7/12/2022	Administration Building	36	69
4/12/2022	Allderdice Field House	3	4
4/12/2022	Allderdice High School	77	150
8/25/2022	Allegheny Annex	10	18
8/25/2022	Allegheny K-5/6-8	44	86
6/21/2022	Arsenal PreK-5/6-8	59	116
4/21/2022	Beechwood PreK-5	36	68
6/17/2022	Brashear High School/ South Hills 6-8	83	163
6/23/2022	CAPA 6-12	54	104
5/10/2022	Carmalt PreK-8	41	80
8/8/2022	Colfax K-8	51	100
5/5/2022	Concord PreK-5	34	70
5/17/2022	Conroy	41	80
5/3/2022	Dilworth PreK-5	32	62
5/26/2022	Fulton PreK-5	20	38
8/24/2022	Grandview K-5	30	58
6/30/2022	Greenway (Classical-Gifted Center)	70	138
6/30/2022	Langley Field House	7	9
8/10/2022	Liberty K-5	27	51
6/1/2022	Mifflin PreK-8	43	84
5/24/2022	Minadeo PreK-5	55	108
4/14/2022	Obama 6-12, ECC	80	157
8/19/2022	Oliver Citywide Academy	65	128
8/19/2022	Oliver Field House	5	8
6/9/2022	Phillips K-5	15	28
4/28/2022	Roosevelt PreK-1	8	14
6/28/2022	Schiller 6-8	22	42
4/19/2022	Spring Garden ECC	19	36
6/3/2022	Spring Hill K-5	22	42
6/14/2022	Student Achievement Center	25	48
4/26/2022	Westwood PreK-5	32	62
6/7/2022	Whittier K-5	25	48
5/12/2022	Woolslair K-5	28	54

Date Sampled	School/Building	Total # of Fixtures	# of Samples Collected
4/12/2020 - 8/25/2022	33 Buildings	1,199	2,323

In the 33 schools/buildings sampled; a total of 2,323 water samples were collected from 1,199 drinking water and cooking use fixtures and faucets.

The results of the water sample testing indicate that only **5.8%** of the fixtures tested had elevated lead concentrations above 15 ppb. This low percentage of fixtures with lead concentrations above 15 ppb indicates that the water supply into the buildings, from the various water authorities, is not elevated for lead, nor is there a District wide lead concern.

Based on water sample testing, our professional opinion is that the sources of the elevated lead concentrations exceeding 15 ppb can be attributed to several key factors such as the lack of routine fixture use, fixtures not routinely cleaned, and/or older outdated fixtures. Corrective actions, which included the removal or replacement of any fixture that exceeded the recommended action level of 15 ppb from service, were conducted by the School District. Following remediation of these fixtures that exceeded the recommended lead concentration, additional verification retesting was conducted to verify that lead concentrations in drinking water was reduced below 15 ppb.

5. RECOMMENDATIONS

Skelly and Loy recommend that Pittsburgh Public Schools follow good drinking water practices and follow the guidelines established in the EPA’s “Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002”, April 1994 and “3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance”, October 2018.

Based on the results of this drinking water sampling report, our recommendations, related to the fixtures, are as follows:

1. All fixtures with lead concentration at or above the EPA Action Limit of 15 ppb are to be replaced or the fixture shut off from use by the District.
2. Post signage stating that the non-filtered fixtures are to be used for only as a “**Handwash Only**” water source.

REPORT DISCLAIMER:

This Skelly and Loy report is based on information supplied by the client, occupants, and on conditions readily observable or measurable on the date or dates of this study. The results and recommendations presented herein should not be relied upon exclusively for the prevention of all possible illnesses, injuries, or losses. These services are a supplement to, and not a substitute for, the client’s responsibility for protecting the health and safety of the occupants of the facility, and others, and for complying with applicable laws and regulations.

This report and the associated attachments and appendices have been produced and developed for, and at the request of, Pittsburgh Board of Public Education. This report conveys the findings of Skelly and Loy, Inc. as of the date(s) noted herein. This report is intended for the exclusive use of Pittsburgh Board of Public Education (including its management, officers, and the School Board).

APPENDIX A
DRINKING WATER RESULTS TABLES

Administration Building

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Administration Building

Address: 341 S. Bellefield Ave., Pittsburgh, PA, 15213

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-ADM-GF-WM-00	WM	Water Main	031	7/9/2022	7:19	P	<1.00	N/A	N/A
22-ADM-GF-SL-00	SL	Service Line	031	7/9/2022	7:24	P	<1.00	N/A	N/A
22-ADM-GF-KF-02	KF	Kitchen faucets	023	7/9/2022	7:12	P	7.87	P	2.12
22-ADM-GF-KF-03	KF	Kitchen faucets	022	7/9/2022	7:27	P	<1.00	P	<1.00
22-ADM-GF-KF-04	KF	Kitchen faucets	022	7/9/2022	7:28	P	3.01	P	<1.00
22-ADM-GF-WF-05	WF	Water fountain with filter & cooler	021	7/9/2022	7:31	P	<1.00	P	<1.00
22-ADM-GF-IM-07	IM	Ice machines	021	7/9/2022	7:33	P	<1.00	N/A	N/A
22-ADM-GF-WB-13	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	7:35	P	14	P	4.02
22-ADM-GF-WO-15	WO	Water fountain without cooler	Corridor	7/9/2022	7:41	P	7.96	P	2.57
22-ADM-01-OF-20	OF	Office sink faucets	OFF 107	7/9/2022	7:50	P	<1.00	P	<1.00
22-ADM-01-WB-21	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	7:53	P	12.1	P	9.74
22-ADM-01-OF-24	OF	Office sink faucets	123	7/9/2022	7:55	P	8.34	P	<1.00
22-ADM-01-WB-26	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	7:59	P	5.3	P	3.73
22-ADM-01-WB-29	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	8:03	P	7.03	P	5.23
22-ADM-01-WB-34	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	8:06	P	5.59	P	2.09
22-ADM-02-WB-39	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	8:10	F	17.4	P	5.65
22-ADM-02-WB-43	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	8:14	P	14.4	P	5.26
22-ADM-02-WB-46	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	8:17	P	9.25	P	1.52
22-ADM-02-OF-47	OF	Office sink faucets	215	7/9/2022	8:19	P	13	P	9.63
22-ADM-02-WO-49	WO	Water fountain without cooler	Corridor	7/9/2022	8:22	F	42.3	P	6.47
22-ADM-02-OF-50	OF	Office sink faucets	208	7/9/2022	8:30	F	31.2	P	10.3
22-ADM-02-OF-51	OF	Office sink faucets	207	7/9/2022	8:24	F	67.6	F	47.1
22-ADM-03-WB-56	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	8:35	P	6.65	P	5.86
22-ADM-03-OF-58	OF	Office sink faucets	353A	7/9/2022	8:41	P	7.98	P	5.2
22-ADM-03-WO-61	WO	Water fountain without cooler	Corridor	7/9/2022	8:42	P	2.25	P	2.24
22-ADM-03-WO-64	WO	Water fountain without cooler	Corridor	7/9/2022	8:46	P	<1.00	P	<1.00
22-ADM-03-OF-65	OF	Office sink faucets	326	7/9/2022	8:48	P	1.22	P	<1.00
22-ADM-03-WB-67	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	8:51	P	10.2	P	3.47
22-ADM-04-OF-69	OF	Office sink faucets	460	7/9/2022	8:58	F	15.2	P	2.7
22-ADM-04-WO-70	WO	Water fountain without cooler	Corridor	7/9/2022	8:59	P	3.31	P	<1.00
22-ADM-04-WB-76	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	9:03	P	3.56	P	2.87
22-ADM-04-OF-77	OF	Office sink faucets	440A	7/9/2022	9:04	P	5.46	P	2.78

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-ADM-04-WB-82	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	9:10	P	2.67	P	2.33
22-ADM-04-WB-86	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/9/2022	9:11	P	2.39	P	1.27
22-ADM-GF-OF-14	OF	Office sink faucets	1	7/9/2022	7:40	P	<1.00	P	<1.00
22-ADM-03-OF-55	OF	Office sink faucets	355	7/9/2022	8:38	P	9.66	P	5.15

P - Passed water sample result

F - Failed water sample result

Allderdice Field House

Lead in Drinking Water Sample Results
 Drinking Water Quality Initiative 2022

School: Pittsburgh Allderdice - Field House

Address: 2409 Shady Avenue, Pittsburgh, PA, 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-AFH-BS-WM-00	WM	Water main	Mechanical Room	4/12/2022	7:48	P	<1.00	P	N/A
22-AFH-BS-SL-00	SL	Service line connection	Mechanical Room	4/12/2022	7:53	P	<1.00	P	N/A
22-AFH-01-MS-08	MS	Miscellaneous Fixture	Men's Locker Room	4/12/2022	7:56	F	47.00	P	3.14

P - Passed water sample result

F - Failed water sample result

Allderdice High School

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Allderdice High School

Address: 2409 Shady Avenue, Pittsburgh, PA, 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-ALD-GF-WM-00	WM	Water Main	Crawlspace	4/12/2022	8:35	P	< 1.00	N/A	N/A
22-ALD-GF-SL-00	SL	Service Line	Crawlspace	4/12/2022	8:40	P	< 1.00	N/A	N/A
22-ALD-GF-WF-07	WF	Water fountain with cooler	026	4/12/2022	8:46	P	< 1.00	P	< 1.00
22-ALD-GF-WF-07.1	WF	Water fountain with cooler	26	4/12/2022	8:47	P	< 1.00	P	< 1.00
22-ALD-GF-NF-08	NF	Nurse's office sink faucets	028	4/12/2022	0:00	P	8.06	P	2
22-ALD-GF-IM-8.1	IM	Nurse's office icemaker	028	4/12/2022	8:57	P	< 1.00	N/A	N/A
22-ALD-GF-MS-8.2	MS	Miscellaneous sinks	028	4/12/2022	8:58	P	7.71	P	< 1.00
22-ALD-GF-WC-09	WC	Water fountain with cooler	026	4/12/2022	9:02	P	4.96	P	< 1.00
22-ALD-GF-WF-27	WF	Water fountain with cooler	004	4/12/2022	9:06	P	< 1.00	P	< 1.00
22-ALD-GF-WF-27.1	WF	Water fountain with cooler	004	4/12/2022	9:08	P	< 1.00	P	< 1.00
22-ALD-01-OF-29	OF	Office sink faucets	176	4/12/2022	9:31	F	25.2	P	< 1.00
22-ALD-01-IM-30	IM	Ice machines	173	4/12/2022	9:35	P	< 1.00	N/A	N/A
22-ALD-01-KF-32	KF	Kitchen faucets	173	4/12/2022	9:38	P	13.3	P	< 1.00
22-ALD-01-KF-33	KF	Kitchen faucets	173	4/12/2022	9:40	P	7.99	P	< 1.00
22-ALD-01-KF-34	KF	Kitchen faucets	173	4/12/2022	9:42	P	3.55	P	< 1.00
22-ALD-01-KF-35	KF	Kitchen faucets	173	4/12/2022	9:44	P	3.12	P	< 1.00
22-ALD-01-KF-36	KF	Kitchen faucets	173	4/12/2022	9:46	P	4.75	P	< 1.00
22-ALD-01-KF-37	KF	Kitchen faucets	173	4/12/2022	9:48	P	2.39	P	< 1.00
22-ALD-01-WF-38	WF	Water fountain with cooler	170	4/12/2022	9:52	P	< 1.00	P	< 1.00
22-ALD-01-WF-39	WF	Water fountain with cooler	170	4/12/2022	9:55	P	< 1.00	P	< 1.00
22-ALD-01-WB-48	WB	Water Bubbler	118	4/12/2022	10:03	F	24.9	P	4.78
22-ALD-01-CF-50	CF	Classroom faucets	129	4/12/2022	10:06	P	13.3	P	3.17
22-ALD-01-CF-51	CF	Classroom faucets	127	4/12/2022	10:07	F	56.6	P	2.98
22-ALD-01-WF-54	WF	Water fountain with cooler	100	4/12/2022	10:12	P	< 1.00	P	< 1.00
22-ALD-01-WF-55	WF	Water fountain with cooler	100	4/12/2022	10:13	P	< 1.00	P	< 1.00
22-ALD-01-MS-56	MS	Miscellaneous sinks	113	4/12/2022	10:18	P	6.59	P	1.15
22-ALD-01-TF-60	TF	Teacher's lounge sinks	Boiler Room	4/12/2022	10:21	P	< 1.00	P	< 1.00
22-ALD-01-TF-61	TF	Teacher's lounge sinks	Nurse Area	4/12/2022	10:26	P	3.93	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-ALD-01-NF-63	NF	Nurse's office sink faucets	Nurse Area	4/12/2022	10:26	P	12.2	P	< 1.00
22-ALD-01-WF-64	WF	Water fountain with cooler	Hallway	4/12/2022	10:31	P	< 1.00	P	< 1.00
22-ALD-01-WF-65	WF	Water fountain with cooler	Hallway	4/12/2022	10:31	P	< 1.00	P	< 1.00
22-ALD-01-WF-74	WF	Water fountain with cooler	185	4/12/2022	10:37	P	< 1.00	P	< 1.00
22-ALD-01-WF-75	WF	Water fountain with cooler	185	4/12/2022	10:38	P	< 1.00	P	< 1.00
22-ALD-01-CF-82	CF	Classroom faucets	188	4/12/2022	10:40	P	< 1.00	P	< 1.00
22-ALD-01-KF-83	KF	Kitchen faucets	188	4/12/2022	10:38	P	< 1.00	P	< 1.00
22-ALD-02-CF-84	CF	Classroom faucets	201	4/12/2022	10:53	P	5.68	P	< 1.00
22-ALD-02-WF-85	WF	Water fountain with cooler	200	4/12/2022	10:55	P	< 1.00	P	< 1.00
22-ALD-02-WF-86	WF	Water fountain without cooler	200	4/12/2022	10:57	P	< 1.00	P	< 1.00
22-ALD-02-TF-101	TF	Teacher's lounge sinks	244	4/12/2022	11:08	P	8.4	P	1.2
22-ALD-02-WC-106	WC	Water fountain with cooler	267	4/12/2022	11:12	P	2.04	P	3.15
22-ALD-02-WC-108	WC	Water fountain with cooler	263	4/12/2022	11:12	P	1.48	P	< 1.00
22-ALD-02-WC-110	WC	Water fountain with cooler	255	4/12/2022	11:13	P	< 1.00	P	1.61
22-ALD-02-WO-115	WO	Water fountain without cooler	200	4/12/2022	11:21	P	5.61	P	< 1.00
22-ALD-02-WF-117	WF	Water fountain with cooler	Hallway	4/12/2022	11:26	P	< 1.00	P	< 1.00
22-ALD-02-WF-118	WF	Water fountain with cooler	Hallway	4/12/2022	11:26	P	< 1.00	P	< 1.00
22-ALD-02-WO-122	WO	Water fountain without cooler	Hallway	4/12/2022	11:59	F	18.2	P	13.9
22-ALD-02-OF-126	OF	Office sink faucets	285	4/12/2022	11:35	P	9.7	P	5.8
22-ALD-03-WO-132	WO	Water fountain without cooler	380	4/12/2022	11:44	P	< 1.00	P	< 1.00
22-ALD-03-WF-137	WF	Water fountain with cooler	Hallway	4/12/2022	11:45	P	< 1.00	P	< 1.00
22-ALD-03-WF-138	WF	Water fountain with cooler	Hallway	4/12/2022	11:46	P	< 1.00	P	< 1.00
22-ALD-03-OF-139	OF	Office sink faucets	343	4/12/2022	11:49	P	12.3	P	1.46
22-ALD-03-WO-141	WO	Water fountain without cooler	300	4/12/2022	11:51	F	15.9	P	1.9
22-ALD-03-MS-142	MS	Miscellaneous sinks	342	4/12/2022	11:53	P	10.2	P	< 1.00
22-ALD-03-CF-148	CF	Classroom faucets	301	4/12/2022	11:58	F	15.5	P	1.97
22-ALD-03-CF-149	CF	Classroom faucets	303	4/12/2022	11:59	P	13.1	P	6.8
22-ALD-03-CF-155	CF	Classroom faucets	308	4/12/2022	12:03	P	11.3	P	6.91
22-ALD-03-WF-156	WF	Water fountain with cooler	Hallway	4/12/2022	12:06	P	< 1.00	P	< 1.00
22-ALD-03-WF-157	WF	Water fountain with cooler	Hallway	4/12/2022	12:07	P	< 1.00	P	< 1.00
22-ALD-03-TF-158	TF	Teacher's lounge sinks	309	4/12/2022	12:09	P	12.2	P	1.87
22-ALD-04-WF-162	WF	Water fountain with cooler	440	4/12/2022	12:17	P	< 1.00	P	< 1.00
22-ALD-04-WF-163	WF	Water fountain with cooler	440	4/12/2022	12:18	P	< 1.00	P	< 1.00
22-ALD-04-WO-250	WO	Water fountain without cooler	Hallway	4/12/2022	12:25	P	< 1.00	P	< 1.00
22-ALD-04-WO-251	WO	Water fountain without cooler	Hallway	4/12/2022	12:26	P	4.24	P	1.44
22-ALD-04-CF-278	CF	Classroom faucets	401	4/12/2022	12:26	P	6.04	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-ALD-04-CF-279	CF	Classroom faucets	401	4/12/2022	12:27	P	1.23	P	< 1.00
22-ALD-04-WO-284	WO	Water fountain without cooler	400	4/12/2022	12:32	P	6.57	P	1.37
22-ALD-04-CF-287	CF	Classroom faucets	425	4/12/2022	12:36	P	6.44	P	1.9
22-ALD-04-CF-288	CF	Classroom faucets	427	4/12/2022	12:43	P	3.6	P	1.61
22-ALD-04-CF-290	CF	Classroom faucets	430	4/12/2022	12:49	P	1.59	P	< 1.00
22-ALD-04-CF-293	CF	Classroom faucets	422	4/12/2022	12:55	P	2.11	P	5.05
22-ALD-04-HF-294	HF	Home economics faucets (with cooking)	418	4/12/2022	12:57	P	4.88	P	7.13
22-ALD-04-HF-295	HF	Home economics faucets (with cooking)	418	4/12/2022	13:00	P	5.96	P	5.51
22-ALD-04-HF-296	HF	Home economics faucets (with cooking)	418	4/12/2022	13:02	F	17.3	P	4.17
22-ALD-04-HF-297	HF	Home economics faucets (with cooking)	418	4/12/2022	13:04	P	4.44	P	3.76
22-ALD-04-HF-298	HF	Home economics faucets (with cooking)	418	4/12/2022	13:06	P	5.05	P	8.02
22-ALD-04-WF-369	WF	Water fountain with cooler	400	4/12/2022	13:10	P	< 1.00	P	< 1.00
22-ALD-04-WF-370	WF	Water fountain with cooler	400	4/12/2022	13:11	P	< 1.00	P	< 1.00

P- Passed water sample result

F - Failed water sample result

Allegheny Annex

Lead in Drinking Water Sample Results
 Drinking Water Quality Initiative 2022

School: Pittsburgh Allegheny Annex

Address: 811 Arch Street Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-ALX-BS-SL-00	SL	Service Line	064	8/25/2022	09:20	P	1.48	N/A	N/A
22-ALX-BS-WM-00	WM	Water Main	064	8/25/2022	09:15	P	4.12	N/A	N/A
22-ALX-01-WF-07	WF	Water fountain with filter & cooler	Corridor 157	8/25/2022	09:27	P	< 1.00	P	< 1.00
22-ALX-01-WF-7.5	WF	Water fountain with filter & cooler	Corridor 157	8/25/2022	09:28	P	< 1.00	P	< 1.00
22-ALX-02-WF-12	WF	Water fountain with filter & cooler	Corridor 252	8/25/2022	09:29	P	< 1.00	P	< 1.00
22-ALX-02-CF-16	CF	Classroom faucets	258	8/25/2022	09:30	P	3.10	P	1.03
22-ALX-03-WF-20	WF	Water fountain with filter & cooler	Corridor 350	8/25/2022	09:41	P	< 1.00	P	< 1.00
22-ALX-03-CF-22	CF	Classroom faucets	358	8/25/2022	09:42	F	51.5	P	7.27
22-ALX-03-CF-25	CF	Classroom faucets	360	8/25/2022	09:43	P	2.58	P	< 1.00
22-ALX-02-CF-33	CF	Classroom Faucets	256	8/25/2022	09:38	F	42.4	F	26.2

P - Passed water sample result
 F - Failed water sample result

Allegheny K-5, 6-8

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Allegheny K-5/6-8

Address: 810 Arch Street, Pittsburgh, PA, 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-AGL-BS-WM-00	WM	Water Main	008	8/25/2022	7:12	P	< 1.00	N/A	N/A
22-AGL-BS-SL-01	SL	Service Line	004	8/25/2022	7:17	P	< 1.00	N/A	N/A
22-AGL-GF-WF-08	WF	Water fountain with cooler	010	8/25/2022	7:18	P	< 1.00	P	< 1.00
22-AGL-GF-WF-09	WF	Water fountain with cooler	010	8/25/2022	7:19	P	< 1.00	P	< 1.00
22-AGL-GF-CF-10	CF	Classroom faucets	12	8/25/2022	7:20	P	1.23	P	< 1.00
22-AGL-GF-CF-13	CF	Classroom faucets	011	8/25/2022	7:21	P	3.81	P	1.53
22-AGL-GF-CF-15	CF	Classroom faucets	030	8/25/2022	7:25	P	< 1.00	P	< 1.00
22-AGL-GF-CF-16	CF	Classroom faucets	030	8/25/2022	7:26	P	< 1.00	P	< 1.00
22-AGL-GF-KF-18	KF	Kitchen faucets	041	8/25/2022	7:30	P	1.1	P	< 1.00
22-AGL-GF-KF-19	KF	Kitchen faucets	041	8/25/2022	7:31	P	1.75	P	< 1.00
22-AGL-GF-KF-20	KF	Kitchen faucets	041	8/25/2022	7:32	P	1.83	P	< 1.00
22-AGL-GF-KF-21	KF	Kitchen faucets	041	8/25/2022	7:33	P	1.03	P	< 1.00
22-AGL-GF-KF-22	KF	Kitchen faucets	041	8/25/2022	7:34	P	1.39	P	< 1.00
22-AGL-GF-MC-24	MC	Multipurpose room faucet	37	8/25/2022	7:39	P	4.57	P	2.85
22-AGL-GF-WF-26	WF	Water fountain with filter & cooler	039	8/25/2022	7:40	P	< 1.00	P	< 1.00
22-AGL-01-CF-30	CF	Classroom faucets	113	8/25/2022	7:50	P	4.68	P	< 1.00
22-AGL-01-WF-32	WF	Water fountain with cooler	100	8/25/2022	7:51	P	< 1.00	P	< 1.00
22-AGL-01-WF-33	WF	Water fountain with cooler	100	8/25/2022	7:52	P	< 1.00	P	< 1.00
22-AGL-01-CF-34	CF	Classroom faucets	105	8/25/2022	7:53	P	3.46	P	1.07
22-AGL-01-NF-38	NF	Nurse's office sink faucets	101	8/25/2022	7:57	P	< 1.00	P	< 1.00
22-AGL-01-GF-38.5	GF	Glass filler with filter	101	8/25/2022	7:58	P	< 1.00	P	< 1.00
22-AGL-01-CF-44	CF	Classroom faucets	134	8/25/2022	8:04	P	1.37	P	< 1.00
22-AGL-01-WC-47	WC	Water fountain with cooler	131	8/25/2022	8:05	P	< 1.00	P	< 1.00
22-AGL-01-WC-48	WC	Water fountain with cooler	131	8/25/2022	8:06	P	< 1.00	P	< 1.00
22-AGL-02-CF-49	CF	Classroom faucets	219	8/25/2022	8:10	P	1.25	P	1.05
22-AGL-02-CF-53	CF	Classroom faucets	228	8/25/2022	8:12	P	2.68	P	< 1.00
22-AGL-02-WC-56	WC	Water fountain with cooler	Outside 217	8/25/2022	8:13	P	< 1.00	P	< 1.00
22-AGL-02-WC-57	WC	Water fountain with cooler	Outside 217	8/25/2022	8:14	P	< 1.00	P	< 1.00
22-AGL-02-WC-60	WC	Water fountain with cooler	200	8/25/2022	8:17	P	< 1.00	P	< 1.00
22-AGL-02-WC-61	WC	Water fountain with cooler	200	8/25/2022	8:18	P	< 1.00	P	< 1.00
22-AGL-02-WF-66	WF	Water fountain bubbler (Ceramic or Porcelain)	204	8/25/2022	8:22	P	< 1.00	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-AGL-03-WF-70	WF	Water fountain with cooler	Outside 329	8/25/2022	8:31	P	< 1.00	P	< 1.00
22-AGL-03-WF-71	WF	Water fountain with cooler	Outside 329	8/25/2022	8:32	P	< 1.00	P	< 1.00
22-AGL-03-WF-85	WF	Water fountain with cooler	Corridor 300	8/25/2022	8:33	P	< 1.00	P	< 1.00
22-AGL-03-WF-86	WF	Water fountain with cooler	Corridor 300	8/25/2022	8:34	P	< 1.00	P	< 1.00
22-AGL-03-CF-87	CF	Classroom faucets	305	8/25/2022	8:34	P	< 1.00	P	< 1.00
22-AGL-04-WF-95	WF	Water fountain bubbler (Ceramic or Porcelain)	Outside 416	8/25/2022	8:44	P	< 1.00	P	< 1.00
22-AGL-04-WF-96	WF	Water fountain bubbler (Ceramic or Porcelain)	Outside 416	8/25/2022	8:45	P	< 1.00	P	< 1.00
22-AGL-04-WF-105	WF	Water fountain with cooler	414	8/25/2022	8:47	P	< 1.00	P	< 1.00
22-AGL-04-WF-106	Wf	Water fountain with cooler	414	8/25/2022	8:48	P	< 1.00	P	< 1.00
22-AGL-04-TF-110	TF	Teacher's lounge sinks	401	8/25/2022	8:49	P	6.58	P	< 1.00
22-AGL-04-WF-111	WF	Water fountain with cooler	400	8/25/2022	8:53	P	< 1.00	P	< 1.00
22-AGL-04-WF-112	WF	Water fountain with cooler	400	8/25/2022	8:54	P	< 1.00	P	< 1.00
22-AGL-GF-WF-119	WF	Water fountain with filter & cooler	39	8/25/2022	7:41	P	< 1.00	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Arsenal Pre-K-5, 6-8

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Arsenal Pre K-5/6-8

Address: 215 39th Street, Pittsburgh, PA 15201

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-ARS-BS-SL-04	SL	Service Line	B-3	6/22/2022	7:23	P	<1.00	N/A	N/A
22-ARS-BS-WM-04	WM	Water Main	B-3	6/22/2022	7:28	P	<1.00	N/A	N/A
22-ARS-GF-OF-01	OF	Office faucet	11A	6/22/2022	7:18	P	1.62	P	<1.00
22-ARS-GF-WF-02	WF	Water fountain with filter & cooler	1	6/22/2022	7:33	P	<1.00	P	<1.00
22-ARS-GF-WF-03	WF	Water fountain with filter & cooler	1	6/22/2022	7:34	P	<1.00	P	<1.00
22-ARS-BS-WF-07	WF	Water fountain with filter & cooler	B-6	6/22/2022	7:39	P	<1.00	P	<1.00
22-ARS-GF-CF-10	CF	Classroom faucets	9	6/22/2022	7:40	P	3.96	P	<1.00
22-ARS-GF-WF-14	WF	Water fountain with filter & cooler	1G	6/22/2022	7:46	P	<1.00	P	<1.00
22-ARS-GF-WF-15	WF	Water fountain with filter & cooler	1G	6/22/2022	7:47	P	<1.00	P	<1.00
22-ARS-GF-NF-17	NF	Nurse's office sink faucets	26B	6/22/2022	7:50	P	10.3	P	2.09
22-ARS-GF-WF-21	WF	Water fountain with filter & cooler	1G	6/22/2022	7:53	P	<1.00	P	<1.00
22-ARS-GF-WF-22	WF	Water fountain with filter & cooler	1G	6/22/2022	7:54	P	<1.00	P	<1.00
22-ARS-GF-KF-23	KF	Kitchen faucets	32	6/22/2022	7:58	P	4.73	P	<1.00
22-ARS-GF-KF-24	KF	Kitchen faucets	32	6/22/2022	8:00	P	5	P	<1.00
22-ARS-GF-KF-25	KF	Kitchen faucets	32	6/22/2022	8:02	P	2.46	P	<1.00
22-ARS-GF-KF-26	KF	Kitchen faucets	32	6/22/2022	8:03	P	3.66	P	<1.00
22-ARS-GF-CF-30	CF	Classroom faucets	34	6/22/2022	8:08	P	2.6	P	<1.00
22-ARS-GF-WF-41	WF	Water fountain with filter & cooler	1-0	6/22/2022	8:10	P	<1.00	P	<1.00
22-ARS-GF-WF-42	WF	Water fountain with filter & cooler	1-0	6/22/2022	8:11	P	<1.00	P	<1.00
22-ARS-01-CF-60	CF	Classroom faucets	131	6/22/2022	8:40	P	<1.00	P	<1.00
22-ARS-01-WF-62	WF	Water fountain with filter & cooler	100B	6/22/2022	8:41	P	<1.00	P	<1.00
22-ARS-01-WF-63	WF	Water fountain with filter & cooler	100B	6/22/2022	8:42	P	<1.00	P	<1.00
22-ARS-01-CF-72	CF	Classroom faucets	141	6/22/2022	8:47	P	10.5	P	<1.00
22-ARS-01-NF-73	NF	Nurse's office sink faucets	143A	6/22/2022	8:49	P	2.59	P	<1.00
22-ARS-01-WF-74	WF	Water fountain with filter & cooler	100	6/22/2022	8:50	P	<1.00	P	<1.00
22-ARS-01-WF-75	WF	Water fountain with filter & cooler	100	6/22/2022	8:51	P	<1.00	P	<1.00
22-ARS-01-CF-76	CF	Classroom faucets	122	6/22/2022	8:55	P	3.3	P	<1.00
22-ARS-01-CF-77	CF	Classroom faucets	122	6/22/2022	8:56	P	1.87	P	<1.00
22-ARS-01-CF-78	CF	Classroom faucets	120	6/22/2022	8:56	P	4.57	P	<1.00
22-ARS-01-CF-79	CF	Classroom faucets	120	6/22/2022	8:57	P	2.49	P	<1.00
22-ARS-01-WF-81	WF	Water fountain with filter & cooler	100	6/22/2022	9:06	P	<1.00	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-ARS-01-WF-82	WF	Water fountain with filter & cooler	100	6/22/2022	9:07	P	<1.00	P	<1.00
22-ARS-01-HF-83	HF	Home economics faucets (with cooking)	112	6/22/2022	9:08	P	3.18	P	2.39
22-ARS-01-HF-84	HF	Home economics faucets (with cooking)	112	6/22/2022	9:12	P	3.55	P	1.33
22-ARS-01-HF-85	HF	Home economics faucets (with cooking)	112	6/22/2022	9:13	P	3.51	P	1.4
22-ARS-01-HF-86	HF	Home economics faucets (with cooking)	112	6/22/2022	9:14	P	9.74	P	2.18
22-ARS-01-HF-87	HF	Home economics faucets (with cooking)	112	6/22/2022	9:15	P	6.43	P	<1.00
22-ARS-02-WF-96	WF	Water fountain with filter & cooler	200	6/22/2022	9:24	P	<1.00	P	<1.00
22-ARS-02-WF-97	WF	Water fountain with filter & cooler	200	6/22/2022	9:25	P	<1.00	P	<1.00
22-ARS-02-WF-100	WF	Water fountain with filter & cooler	200	6/22/2022	9:28	P	<1.00	P	<1.00
22-ARS-02-WF-101	WF	Water fountain with filter & cooler	200	6/22/2022	9:29	P	<1.00	P	<1.00
22-ARS-03-CF-115	CF	Classroom faucets	312	6/22/2022	9:42	F	20.3	P	2.21
22-ARS-03-WF-116	WF	Water fountain with filter & cooler	300	6/22/2022	9:44	P	<1.00	P	<1.00
22-ARS-03-WF-117	WF	Water fountain with filter & cooler	300	6/22/2022	9:45	P	<1.00	P	<1.00
22-ARS-03-CF-120	CF	Classroom faucets	302	6/22/2022	9:46	P	7.24	P	4.78
22-ARS-03-WF-121	WF	Water fountain with filter & cooler	300	6/22/2022	9:47	P	<1.00	P	<1.00
22-ARS-03-WF-122	WF	Water fountain with filter & cooler	300	6/22/2022	9:48	P	<1.00	P	<1.00
22-ARS-02-CF-123	CF	Classroom faucets	210	6/22/2022	9:26	P	3.69	P	3.17
22-ARS-BS-WF-124	WF	Water fountain with filter & cooler	M-4	6/22/2022	7:41	P	<1.00	P	<1.00
22-ARS-BS-WF-131	WF	Water fountain with filter & cooler	B-20	6/22/2022	8:23	P	<1.00	P	<1.00
22-ARS-BS-WF-132	WF	Water fountain with filter & cooler	B-20	6/22/2022	8:24	P	<1.00	P	<1.00
22-ARS-BS-CF-138	CF	Classroom faucets	B-30	6/22/2022	8:22	P	1.03	P	<1.00
22-ARS-BS-CF-144	CF	Classroom faucets	B-6	6/22/2022	8:25	P	5.28	P	<1.00
22-ARS-01-GF-73.5	GF	Filtered Glass Filler	143A	6/22/2022	8:49	P	<1.00	P	<1.00
22-ARS-BS-GF-144.5	GF	Filtered Glass Filler	B-6	6/22/2022	8:26	P	<1.00	P	<1.00
22-ARS-BS-WF-125	WF	Water fountain with filter & cooler	M-4	6/22/2022	7:42	P	<1.00	P	<1.00
22-ARS-GF-CF-31	CF	Classroom faucets	34	6/22/2022	8:09	P	4.93	P	<1.00
22-ARS-03-CF-106	CF	Classroom faucets	301	6/22/2022	9:37	F	36.3	F	22.8
22-ARS-03-CF-107	CF	Classroom faucets	301	6/22/2022	9:38	F	41.4	P	12.9

P - Passed water sample result

F - Failed water sample result

Beechwood PreK-5

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Beechwood Pre K-5

Address: 810 Rockland Avenue Pittsburgh, PA 15216

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-BEE-BS-SL-01	SL	Service Line	16	4/21/2022	06:53	P	< 1.00	N/A	N/A
22-BEE-BS-WM-01	WM	Water Main	16	4/21/2022	06:58	P	< 1.00	N/A	N/A
22-BEE-BS-WC-03	WC	Water fountain with cooler	Corr-1	4/21/2022	06:57	P	< 1.00	P	< 1.00
22-BEE-BS-WC-04	WC	Water fountain with cooler	Corr-1	4/21/2022	06:58	P	< 1.00	P	< 1.00
22-BEE-BS-CF-05	CF	Classroom faucets	14	4/21/2022	07:04	P	8.37	F	18.7
22-BEE-BS-SF-08	SF	Science lab faucets	14	4/21/2022	07:05	P	4.53	P	< 1.00
22-BEE-BS-WC-09	WC	Water fountain with cooler	Corr-1	4/21/2022	07:08	P	< 1.00	P	< 1.00
22-BEE-BS-WC-10	WC	Water fountain with cooler	Corr-1	4/21/2022	07:09	P	< 1.00	P	< 1.00
22-BEE-BS-CF-11	CF	Classroom faucets	12C	4/21/2022	07:12	P	3.67	P	< 1.00
22-BEE-BS-NF-21	NF	Nurse's office sink faucets	3	4/21/2022	07:16	P	1.97	P	< 1.00
22-BEE-01-WC-25	WC	Water fountain with cooler	Corr-100	4/21/2022	07:22	P	< 1.00	P	< 1.00
22-BEE-01-WC-26	WC	Water fountain with cooler	Corr-100	4/21/2022	07:23	P	< 1.00	P	< 1.00
22-BEE-01-KF-27	KF	Kitchen faucets	100C	4/21/2022	07:24	P	1.08	P	< 1.00
22-BEE-01-WC-28	WC	Water fountain with cooler	Corr-100	4/21/2022	07:28	P	< 1.00	P	< 1.00
22-BEE-01-CF-29	CF	Classroom faucets	109	4/21/2022	7:29	P	< 1.00	P	< 1.00
22-BEE-01-OF-37	OF	Office sink faucets	102	4/21/2022	07:30	P	1.65	P	< 1.00
22-BEE-02-CF-38	CF	Classroom faucets	216	4/21/2022	07:38	P	2.94	P	3.69
22-BEE-02-WC-39	WC	Water fountain with cooler	Corr-200	4/21/2022	07:39	P	< 1.00	P	< 1.00
22-BEE-02-WC-40	WC	Water fountain with cooler	Corr-200	4/21/2022	07:40	P	< 1.00	P	< 1.00
22-BEE-02-CF-41	CF	Classroom faucets	215	4/21/2022	07:41	P	2.22	P	< 1.00
22-BEE-02-TF-42	TF	Teacher's lounge sinks	214	4/21/2022	07:42	P	< 1.00	P	< 1.00
22-BEE-02-WC-43	WC	Water fountain with cooler	Corr-200	4/21/2022	07:45	P	< 1.00	P	< 1.00
22-BEE-02-WC-44	WC	Water fountain with cooler	Corr-200	4/21/2022	07:46	P	< 1.00	P	< 1.00
22-BEE-02-CF-49	CF	Classroom faucets	204	4/21/2022	07:47	P	3.39	P	< 1.00
22-BEE-DB-CF-53	CF	Classroom faucets	P-01	4/21/2022	07:58	P	< 1.00	P	2.32
22-BEE-DB-WM-57	WM	Water Main	P-02	4/21/2022	08:12	P	< 1.00	N/A	N/A
22-BEE-BD-SL-57	SL	Service Line	P-02	4/21/2022	08:17	P	< 1.00	N/A	N/A

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-BEE-DB-CF-58	CF	Classroom faucets	P-03	4/21/2022	08:17	P	2.22	P	< 1.00
22-BEE-DB-CF-59	CF	Classroom faucets	P-04	4/21/2022	08:20	P	< 1.00	P	1.21
22-BEE-DB-CF-64	CF	Classroom faucets	P-06	4/21/2022	08:25	P	1.02	P	1.85
22-BEE-DB-GF-53.1	GF	Filtered Glass Filler	P-01	4/21/2022	07:59	P	< 1.00	P	< 1.00
22-BEE-DB-GF-58.1	GF	Filtered Glass Filler	P-02	4/21/2022	08:18	P	< 1.00	P	< 1.00
22-BEE-DB-GF-59.1	GF	Filtered Glass Filler	P-03	4/21/2022	08:21	P	< 1.00	P	< 1.00
22-BEE-DB-GF-64.1	GF	Filtered Glass Filler	P-04	4/21/2022	08:26	P	< 1.00	P	< 1.00
22-BEE-DB-WC-65	WC	Water fountain with cooler	P-01	4/21/2022	08:27	P	< 1.00	P	< 1.00
22-BEE-DB-WC-66	WC	Water fountain with cooler	P-03	4/21/2022	08:28	P	2.76	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Brashear High School
South Hills 6-8

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Brashear South Hills 6-8

Address: 590 Crane Ave., Pittsburgh, PA, 15216

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-BRA-BS-WM-00	WM	Water Main	Crawlspace	6/18/2022	7:30	P	< 1.00	N/A	N/A
22-BRA-BS-SL-00	SL	Service Line	Crawlspace	6/18/2022	7:35	P	< 1.00	N/A	N/A
22-BRA-BS-WF-01	WF	Water fountain with filter & cooler	Main Hallway	6/18/2022	7:39	P	< 1.00	P	< 1.00
22-BRA-BS-WF-02	WF	Water fountain with filter & cooler	Main Hallway	6/18/2022	7:40	P	< 1.00	P	< 1.00
22-BRA-BS-MS-09	MS	Miscellaneous fixture	G3	6/18/2022	7:50	P	2.96	P	1.58
22-BRA-BS-WC-17	WC	Water fountain with cooler	Automotive	6/18/2022	7:45	P	9.59	P	2.17
22-BRA-BS-CF-24	CF	Classroom faucets	G5	6/18/2022	07:51	P	3.18	P	< 1.00
22-BRA-BS-WC-26	WC	Water fountain with cooler	G6	6/18/2022	08:00	P	< 1.00	P	< 1.00
22-BRA-BS-CF-28	CF	Classroom faucets	G2	6/18/2022	07:59	P	1.72	P	< 1.00
22-BRA-BS-WC-32	WC	Water fountain with cooler	G1	6/18/2022	08:02	P	3.16	P	2.71
22-BRA-BS-KF-37	KF	Kitchen faucets	G14	6/18/2022	08:04	P	1.59	P	< 1.00
22-BRA-BS-GF-37.5	GF	Glass filler with filter	G14	6/18/2022	8:05	P	< 1.00	P	< 1.00
22-BRA-BS-CF-38	CF	Classroom faucets	G14A	6/18/2022	08:06	P	9.94	P	1.66
22-BRA-BS-GF-38.5	GF	Glass filler with filter	G14A	6/18/2022	8:07	P	< 1.00	P	< 1.00
22-BRA-BS-CF-45	CF	Classroom faucets	G23	6/18/2022	08:10	P	7.70	P	3.48
22-BRA-BS-WF-46	WF	Water fountain with filter & cooler	Hallway	6/18/2022	08:16	P	< 1.00	P	< 1.00
22-BRA-BS-WF-47	WF	Water fountain with filter & cooler	Hallway	6/18/2022	08:17	P	< 1.00	P	< 1.00
22-BRA-BS-WC-48	WC	Water fountain with cooler	Hallway	6/18/2022	08:19	P	4.15	P	< 1.00
22-BRA-BS-OF-60	OF	Office sink faucets	G42M	6/18/2022	08:19	P	< 1.00	P	< 1.00
22-BRA-BS-MS-61	MS	Miscellaneous sinks	G45M	6/18/2022	08:23	P	5.83	P	< 1.00
22-BRA-BS-WC-64	WC	Water fountain with cooler	Hallway	6/18/2022	08:24	P	1.69	P	1.42
22-BRA-BS-WC-65	WC	Water fountain with cooler	Hallway	6/18/2022	08:25	P	1.32	P	< 1.00
22-BRA-01-KF-68	KF	Kitchen faucets	102	6/18/2022	08:36	P	1.10	P	< 1.00
22-BRA-01-KF-69	KF	Kitchen faucets	102	6/18/2022	08:37	P	1.42	P	< 1.00
22-BRA-01-KF-70	KF	Kitchen faucets	102	6/18/2022	8:38	P	3.82	P	< 1.00
22-BRA-01-KF-71	KF	Kitchen faucets	102	6/18/2022	08:38	P	< 1.00	P	< 1.00
22-BRA-01-KF-72	KF	Kitchen faucets	102	6/18/2022	08:40	P	< 1.00	P	< 1.00
22-BRA-01-TF-76	TF	Teacher's lounge sinks	111	6/18/2022	08:41	P	< 1.00	P	< 1.00
22-BRA-01-WF-85	WF	Water fountain with filter & cooler	Hallway	6/18/2022	08:45	P	< 1.00	P	< 1.00
22-BRA-01-WF-86	WF	Water fountain with filter & cooler	Hallway	6/18/2022	08:45	P	< 1.00	P	< 1.00
22-BRA-01-OF-95	OF	Office sink faucets	134	6/18/2022	08:51	P	< 1.00	P	< 1.00
22-BRA-01-TF-98	TF	Teacher's lounge sinks	138	6/18/2022	09:00	P	< 1.00	P	< 1.00
22-BRA-01-GF-98.5	GF	Glass filler with filter	138	6/18/2022	9:01	P	< 1.00	P	< 1.00
22-BRA-01-TF-102	TF	Teacher's lounge sinks	125	6/18/2022	09:06	P	< 1.00	P	< 1.00
22-BRA-01-OF-104	OF	Office sink faucets	128	6/18/2022	09:08	P	6.80	P	< 1.00
22-BRA-01-WF-106	WF	Water fountain with filter & cooler	LOBBY	6/18/2022	09:12	P	< 1.00	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-BRA-01-WF-107	WF	Water fountain with filter & cooler	LOBBY	6/18/2022	09:12	P	< 1.00	P	< 1.00
22-BRA-01-OF-118	OF	Office sink faucets	113A	6/18/2022	09:16	P	1.79	P	1.03
22-BRA-01-TF-127	TF	Teacher's lounge sinks	108	6/18/2022	09:19	P	< 1.00	P	< 1.00
22-BRA-01-KF-128	KF	Kitchen faucets	109	6/18/2022	09:24	P	< 1.00	P	< 1.00
22-BRA-01-KF-129	KF	Kitchen faucets	109	6/18/2022	09:25	P	< 1.00	P	< 1.00
22-BRA-01-KF-130	KF	Kitchen faucets	109	6/18/2022	09:24	P	< 1.00	P	< 1.00
22-BRA-01-KF-131	KF	Kitchen faucets	109	6/18/2022	09:25	P	2.91	P	< 1.00
22-BRA-01-KF-134	KF	Kitchen faucets	109	6/18/2022	09:27	P	2.58	P	< 1.00
22-BRA-02-WF-164	WF	Water fountain with filter & cooler	LOBBY	6/18/2022	09:35	P	< 1.00	P	< 1.00
22-BRA-02-WF-165	WF	Water fountain with filter & cooler	LOBBY	6/18/2022	09:35	P	< 1.00	P	< 1.00
22-BRA-02-IM-177	IM	Ice machines	269	6/18/2022	09:46	P	< 1.00	P	< 1.00
22-BRA-02-WC-179	WC	Water fountain with cooler	265A	6/18/2022	09:49	P	3.40	P	< 1.00
22-BRA-02-WC-186	WC	Water fountain with cooler	263	6/18/2022	09:57	P	5.40	P	< 1.00
22-BRA-02-WC-187	WC	Water fountain with cooler	Hallway	6/18/2022	09:57	P	1.86	P	< 1.00
22-BRA-02-WC-191	WC	Water fountain with cooler	259	6/18/2022	10:03	P	5.27	P	2.33
22-BRA-02-WC-192	WC	Water fountain with cooler	259	6/18/2022	10:04	P	1.93	P	1.03
22-BRA-02-CF-194	CF	Classroom faucets	237	6/18/2022	10:04	P	4.14	P	< 1.00
22-BRA-02-WF-203	WF	Water fountain with filter & cooler	Hallway	6/18/2022	10:10	P	< 1.00	P	< 1.00
22-BRA-02-WF-204	WF	Water fountain with filter & cooler	Hallway	6/18/2022	10:11	P	< 1.00	P	< 1.00
22-BRA-03-WF-269	WF	Water fountain with filter & cooler	Hallway	6/18/2022	10:29	P	< 1.00	P	< 1.00
22-BRA-03-WF-270	WF	Water fountain with filter & cooler	Hallway	6/18/2022	10:30	P	< 1.00	P	< 1.00
22-BRA-03-CF-288	CF	Classroom faucets	340	6/18/2022	10:49	P	8.23	P	< 1.00
22-BRA-03-CF-289	CF	Classroom faucets	340	6/18/2022	10:50	P	1.38	P	< 1.00
22-BRA-03-CF-290	CF	Classroom faucets	344	6/18/2022	10:56	P	1.71	P	< 1.00
22-BRA-03-CF-291	CF	Classroom faucets	344	6/18/2022	10:57	P	2.64	P	< 1.00
22-BRA-03-CF-292	CF	Classroom faucets	344	6/18/2022	10:58	P	1.94	P	< 1.00
22-BRA-03-CF-293	CF	Classroom faucets	341	6/18/2022	11:00	P	2.52	P	< 1.00
22-BRA-03-CF-294	CF	Classroom faucets	341	6/18/2022	11:01	P	1.82	P	< 1.00
22-BRA-03-CF-295	CF	Classroom faucets	342	6/18/2022	11:02	P	1.93	P	< 1.00
22-BRA-03-CF-296	CF	Classroom faucets	342	6/18/2022	11:03	P	1.25	P	< 1.00
22-BRA-03-CF-297	CF	Classroom faucets	343	6/18/2022	11:02	P	6.07	P	< 1.00
22-BRA-03-CF-298	CF	Classroom faucets	343	6/18/2022	11:03	P	5.28	P	1.02
22-BRA-03-TF-299	TF	Teacher's lounge sinks	328	6/18/2022	11:08	P	1.06	P	< 1.00
22-BRA-03-HF-303	HF	Home economics faucets (with cooking)	336	6/18/2022	11:12	P	3.30	P	< 1.00
22-BRA-03-HF-304	HF	Home economics faucets (with cooking)	336	6/18/2022	11:13	P	7.45	P	< 1.00
22-BRA-03-HF-305	HF	Home economics faucets (with cooking)	336	6/18/2022	11:15	P	7.35	P	< 1.00
22-BRA-03-HF-306	HF	Home economics faucets (with cooking)	336	6/18/2022	11:14	P	5.02	P	< 1.00
22-BRA-03-HF-308	HF	Home economics faucets (with cooking)	336	6/18/2022	11:17	P	9.48	P	< 1.00
22-BRA-03-HF-309	HF	Home economics faucets (with cooking)	336	6/18/2022	11:18	P	6.85	P	< 1.00
22-BRA-03-HF-310	HF	Home economics faucets (with cooking)	337	6/18/2022	11:22	P	< 1.00	P	< 1.00
22-BRA-03-HF-311	HF	Home economics faucets (with cooking)	337	6/18/2022	11:23	P	< 1.00	P	< 1.00
22-BRA-03-HF-312	HF	Home economics faucets (with cooking)	337	6/18/2022	11:23	P	< 1.00	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-BRA-03-HF-313	HF	Home economics faucets (with cooking)	337	6/18/2022	11:25	P	1.33	P	< 1.00
22-BRA-03-HF-314	HF	Home economics faucets (with cooking)	337	6/18/2022	11:25	P	< 1.00	P	< 1.00
22-BRA-03-WF-318	WF	Water fountain with filter & cooler	Hallway	6/18/2022	11:32	P	< 1.00	P	< 1.00
22-BRA-03-WF-319	WF	Water fountain with filter & cooler	Hallway	6/18/2022	11:33	P	< 1.00	P	< 1.00
22-BRA-02-WC-357	WC	Water fountain with cooler	Outside 265 A	6/18/2022	9:50	P	2.98	P	< 1.00

P - Passed water sample result

F - Failed water sample result

CAPA 6-12

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh CAPA

Address: 111 Ninth St. Pittsburgh, PA 15222

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-CAP-BS-WM-00	WM	Water Main	Parking Garage	6/24/2022	7:15	P	<1.00	N/A	N/A
22-CAP-BS-SL-00	SL	Service Line	Parking Garage	6/24/2022	7:20	P	<1.00	N/A	N/A
22-CAP-01-KF-12	KF	Kitchen faucets	Kitchen	6/24/2022	7:47	P	<1.00	P	<1.00
22-CAP-01-KF-13	KF	Kitchen faucets	Kitchen	6/24/2022	7:48	P	<1.00	P	<1.00
22-CAP-01-KF-14	KF	Kitchen faucets	Kitchen	6/24/2022	7:52	P	1.26	P	<1.00
22-CAP-01-KF-15	KF	Kitchen faucets	Kitchen	6/24/2022	7:53	P	5.66	P	2.62
22-CAP-01-KF-16	KF	Kitchen faucets	Kitchen	6/24/2022	7:54	P	<1.00	P	<1.00
22-CAP-01-KF-17	KF	Kitchen faucets	Kitchen	6/24/2022	7:55	P	<1.00	P	<1.00
22-CAP-01-WF-22	WF	Water fountain with filter & cooler	Hallway	6/24/2022	7:59	P	<1.00	P	<1.00
22-CAP-02-WF-42	WF	Water fountain with filter & cooler	Hallway	6/24/2022	8:05	P	<1.00	P	<1.00
22-CAP-02-CF-47	CF	Classroom faucets	214	6/24/2022	8:10	P	<1.00	P	<1.00
22-CAP-03-WF-53	WF	Water fountain with filter & cooler	Hallway	6/24/2022	8:20	P	<1.00	P	<1.00
22-CAP-03-WF-54	WF	Water fountain with filter & cooler	Hallway	6/24/2022	8:21	P	<1.00	P	<1.00
22-CAP-03-CF-60	CF	Classroom faucets	311	6/24/2022	8:25	P	<1.00	P	<1.00
22-CAP-04-OF-65	OF	Office sink faucets	417	6/24/2022	8:33	P	<1.00	P	<1.00
22-CAP-04-WF-66	WF	Water fountain with filter & cooler	Hallway	6/24/2022	8:34	P	<1.00	P	<1.00
22-CAP-04-WF-67	WF	Water fountain with filter & cooler	Hallway	6/24/2022	8:35	P	<1.00	P	<1.00
22-CAP-04-CF-73	CF	Classroom faucets	412	6/24/2022	8:43	P	1.62	P	<1.00
22-CAP-04-KF-80	KF	Kitchen faucets	408	6/24/2022	8:44	P	<1.00	P	<1.00
22-CAP-04-KF-81	KF	Kitchen faucets	408	6/24/2022	8:45	P	2.39	P	<1.00
22-CAP-04-KF-82	KF	Kitchen faucets	407	6/24/2022	8:48	P	1.01	P	6.41
22-CAP-04-KF-83	KF	Kitchen faucets	401	6/24/2022	8:49	P	<1.00	P	<1.00
22-CAP-04-KF-84	KF	Kitchen faucets	401	6/24/2022	8:54	P	1.4	P	<1.00
22-CAP-04-KF-85	KF	Kitchen faucets	401	6/24/2022	8:55	P	1.02	P	<1.00
22-CAP-04-KF-86	KF	Kitchen faucets	401	6/24/2022	8:57	P	<1.00	P	<1.00
22-CAP-04-KF-87	KF	Kitchen faucets	401	6/24/2022	8:58	P	<1.00	P	<1.00
22-CAP-05-WF-98	WF	Water fountain with filter & cooler	Hallway	6/24/2022	9:11	P	<1.00	P	<1.00
22-CAP-05-WF-99	WF	Water fountain with filter & cooler	Hallway	6/24/2022	9:12	P	<1.00	P	<1.00
22-CAP-06-CF-139	CF	Classroom faucets	604	6/24/2022	9:23	P	<1.00	P	<1.00
22-CAP-06-CF-140	CF	Classroom faucets	603A	6/24/2022	9:24	P	<1.00	P	<1.00
22-CAP-06-CF-141	CF	Classroom faucets	602	6/24/2022	9:25	P	<1.00	P	<1.00
22-CAP-06-CF-142	CF	Classroom faucets	606	6/24/2022	9:24	P	<1.00	P	<1.00
22-CAP-06-CF-143	CF	Classroom faucets	606	6/24/2022	9:25	P	<1.00	P	<1.00
22-CAP-06-CF-144	CF	Classroom faucets	607	6/24/2022	9:29	P	<1.00	P	1.06
22-CAP-06-WF-146	WF	Water fountain with filter & cooler	Hallway	6/24/2022	9:31	P	<1.00	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-CAP-06-WF-147	WF	Water fountain with filter & cooler	Hallway	6/24/2022	9:32	P	<1.00	P	<1.00
22-CAP-06-CF-156	CF	Classroom faucets	624	6/24/2022	9:37	P	<1.00	P	<1.00
22-CAP-06-CF-157	CF	Classroom faucets	624-625	6/24/2022	9:38	P	<1.00	P	<1.00
22-CAP-06-CF-158	CF	Classroom faucets	625	6/24/2022	9:39	P	<1.00	P	<1.00
22-CAP-06-CF-159	CF	Classroom faucets	620	6/24/2022	9:40	P	<1.00	P	<1.00
22-CAP-06-CF-160	CF	Classroom faucets	620	6/24/2022	9:41	P	<1.00	P	<1.00
22-CAP-07-WF-162	WF	Water fountain with filter & cooler	714	6/24/2022	9:56	P	<1.00	P	<1.00
22-CAP-07-WF-163	WF	Water fountain with filter & cooler	714	6/24/2022	9:57	P	<1.00	P	<1.00
22-CAP-07-CF-164	CF	Classroom faucets	719	6/24/2022	9:58	P	<1.00	P	2.84
22-CAP-08-TF-172	TF	Teacher's lounge sinks	Teachers Room	6/24/2022	10:02	P	<1.00	P	<1.00
22-CAP-08-OF-173	OF	Office sink faucets	Teachers Room	6/24/2022	10:03	P	4.79	P	1.82
22-CAP-08-WF-177	WF	Water fountain with filter & cooler	Hallway	6/24/2022	10:05	P	<1.00	P	<1.00
22-CAP-08-WF-178	WF	Water fountain with filter & cooler	Hallway	6/24/2022	10:06	P	<1.00	P	<1.00
22-CAP-09-WF-185	WF	Water fountain with filter & cooler	Hallway	6/24/2022	10:12	P	<1.00	P	<1.00
22-CAP-09-WF-186	WF	Water fountain with filter & cooler	Hallway	6/24/2022	10:13	P	<1.00	P	<1.00
22-CAP-04-KF-196	KF	Kitchen faucets	407	6/24/2022	8:56	P	<1.00	P	<1.00
22-CAP-06-CF-197	CF	Classroom faucets	617	6/24/2022	9:49	P	1.83	P	<1.00
22-CAP-06-CF-198	CF	Classroom faucets	617	6/24/2022	9:50	P	13.3	P	6.69

P - Passed water sample result

F - Failed water sample result

Carmalt PreK-8

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Carmalt Pre K-8

Address: 1550 Breining Street, Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-CAR-GF-SL-00	SL	Service Line	G143	5/10/2022	6:24	P	< 1.00	N/A	N/A
22-CAR-GF-WM-00	WM	Water Main	G143	5/10/2022	6:19	P	< 1.00	N/A	N/A
22-CAR-GF-CF-06	CF	Classroom faucets	G132	5/10/2022	6:30	P	< 1.00	P	< 1.00
22-CAR-GF-CF-07	CF	Classroom faucets	G133	5/10/2022	6:31	P	1.45	P	< 1.00
22-CAR-GF-CF-08	CF	Classroom faucets	G127	5/10/2022	6:32	P	1.62	P	2.27
22-CAR-GF-WC-17	WC	Water fountain with cooler	Outside Boys	5/10/2022	6:45	P	< 1.00	P	< 1.00
22-CAR-GF-WF-18	WF	Water fountain with filter & cooler	Outside Girls	5/10/2022	6:46	P	< 1.00	P	< 1.00
22-CAR-GF-WF-18.5	WF	Water fountain with filter & cooler		5/10/2022	6:47	P	< 1.00	P	< 1.00
22-CAR-GF-CF-23	CF	Classroom faucets	G120	5/10/2022	6:55	P	< 1.00	P	< 1.00
22-CAR-GF-MC-25	MC	Multi-Purpose Room/Cafeteria faucets	G104	5/10/2022	6:56	P	1.07	P	< 1.00
22-CAR-GF-CF-26	CF	Classroom faucets	N/A	5/10/2022	6:58	P	< 1.00	P	< 1.00
22-CAR-GF-GF-27	GF	Glass Filler with Filter	N/A	5/10/2022	6:59	P	< 1.00	P	< 1.00
22-CAR-01-WF-30	WF	Water fountain with filter & cooler	Outside 179	5/10/2022	7:07	P	< 1.00	P	< 1.00
22-CAR-01-WF-30.5	WF	Water fountain with filter & cooler		5/10/2022	7:07	P	< 1.00	P	< 1.00
22-CAR-01-WC-31	WC	Water fountain with cooler	Outside 177	5/10/2022	7:09	P	< 1.00	P	< 1.00
22-CAR-01-WC-32	WC	Water fountain with cooler	Outside E115	5/10/2022	7:12	P	< 1.00	P	< 1.00
22-CAR-01-KF-35.5	KF	Kitchen faucets	loyees' Breakr	5/10/2022	7:14	P	< 1.00	P	< 1.00
22-CAR-01-CF-37	CF	Classroom faucets	E105	5/10/2022	7:16	P	3.15	P	< 1.00
22-CAR-01-CF-38	CF	Classroom faucets	E105	5/10/2022	7:17	P	1.46	P	< 1.00
22-CAR-01-TF-49	TF	Teacher's lounge sinks	160	5/10/2022	7:18	P	< 1.00	P	< 1.00
22-CAR-01-WF-57	WF	Water fountain with filter & cooler	Outside 154	5/10/2022	7:22	P	< 1.00	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-CAR-01-WF-57.5	WF	Water fountain with filter & cooler		5/10/2022	7:23	P	< 1.00	P	< 1.00
22-CAR-01-WF-58	WF	Water fountain with filter & cooler	Outside 152	5/10/2022	7:24	P	< 1.00	P	< 1.00
22-CAR-01-CF-59	CF	Classroom faucets	127	5/10/2022	7:32	P	1.44	P	< 1.00
22-CAR-01-WF-73	WF	Water fountain with filter & cooler	106	5/10/2022	7:37	P	< 1.00	P	< 1.00
22-CAR-01-KF-74	KF	Kitchen faucets	113	5/10/2022	7:39	P	< 1.00	P	< 1.00
22-CAR-01-KF-75	KF	Kitchen faucets	113	5/10/2022	7:40	P	< 1.00	P	< 1.00
22-CAR-01-KF-75.5	KF	Kitchen faucets		5/10/2022	7:41	P	1.98	P	< 1.00
22-CAR-01-WF-76	WF	Water fountain with filter & cooler	Outside 109	5/10/2022	7:38	P	< 1.00	P	< 1.00
22-CAR-01-CF-82	CF	Classroom faucets	172	5/10/2022	7:47	P	< 1.00	P	< 1.00
22-CAR-02-WF-83	WF	Water fountain with filter & cooler	Across Stair E	5/10/2022	7:55	P	< 1.00	P	< 1.00
22-CAR-02-WF-83.1	WF	Water fountain with filter & cooler		5/10/2022	7:55	P	< 1.00	P	< 1.00
22-CAR-02-TF-92	TF	Teacher's lounge sinks	E209	5/10/2022	7:56	F	108	P	< 1.00
22-CAR-02-WF-98	WF	Water fountain with filter & cooler	Outside Boys	5/10/2022	8:02	P	< 1.00	P	< 1.00
22-CAR-02-TF-102	TF	Teacher's lounge sinks	228	5/10/2022	8:03	P	< 1.00	P	< 1.00
22-CAR-02-WF-103	WF	Water fountain with filter & cooler	Outside Girls	5/10/2022	8:07	P	< 1.00	P	< 1.00
22-CAR-02-WF-103.5	WF	Water fountain with filter & cooler		5/10/2022	8:08	P	< 1.00	P	< 1.00
22-CAR-02-WF-111	WF	Water fountain with filter & cooler	Outside Boys	5/10/2022	8:09	P	< 1.00	P	< 1.00
22-CAR-02-CF-112	CF	Classroom faucets	211A	5/10/2022	8:12	P	7.30	P	< 1.00
22-CAR-02-CF-113	CF	Classroom faucets	209	5/10/2022	8:13	P	< 1.00	P	< 1.00
22-CAR-02-CF-114	CF	Classroom faucets	209	5/10/2022	8:14	P	< 1.00	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Colfax K-8

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Colfax K-8

Address: 2332 Beechwood Blvd., Pittsburgh, PA 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-COL-BS-WM-00	WM	Water Main	7A	8/9/22	8:19	P	6.85	N/A	N/A
22-COL-BS-SL-00	SL	Service Line	7A	8/9/22	8:24	P	6.19	N/A	N/A
22-COL-BS-CF-01	CF	Classroom faucets	6	8/9/22	8:14	F	15.1	P	11.5
22-COL-BS-WF-04	WF	Water fountain with filter	Stair A	8/9/22	8:27	P	< 1.00	P	< 1.00
22-COL-BS-WF-05	WF	Water fountain with filter	Stair A	8/9/22	8:28	P	< 1.00	P	< 1.00
22-COL-BS-TF-08	TF	Teacher's faculty faucet	12	8/9/22	8:32	P	< 1.00	P	< 1.00
22-COL-BS-GF-08.5	GF	Glass filler with filter	12	8/9/22	8:33	P	< 1.00	P	< 1.00
22-COL-BS-CF-11	CF	Classroom faucets	17	8/9/22	8:40	P	< 1.00	P	< 1.00
22-COL-BS-KF-13	KF	Kitchen faucet	Custodian	8/9/22	8:43	P	3.56	P	< 1.00
22-COL-BS-CF-15	CF	Classroom faucets	15	8/9/22	8:50	P	3.75	P	9.4
22-COL-BS-CF-16	CF	Classroom faucets	16	8/9/22	8:52	F	20.3	P	1.1
22-COL-01-CF-17	CF	Classroom faucets	105A	8/9/22	9:06	P	11.5	P	1.45
22-COL-01-CF-18	CF	Classroom faucets	104A	8/9/22	9:08	P	7.59	P	3.07
22-COL-01-CF-19	CF	Classroom faucets	106A	8/9/22	9:10	P	9.73	P	3.07
22-COL-01-CF-20	CF	Classroom faucets	103	8/9/22	9:18	F	468	F	23.8
22-COL-01-WO-21	WO	Water fountain without filter	Corridor 100	8/9/22	9:10	P	< 1.00	P	< 1.00
22-COL-01-WO-22	WO	Water fountain without filter	Corridor 100	8/9/22	9:12	P	< 1.00	P	< 1.00
22-COL-01-CF-28	CF	Classroom faucets	102	8/9/22	9:25	P	3.77	P	< 1.00
22-COL-01-NF-29	NF	Nurse's office faucet	101B	8/9/22	9:18	P	1.24	P	< 1.00
22-COL-BS-GF-29.5	GF	Glass filler with filter	Nurse	8/9/22	9:19	P	< 1.00	P	< 1.00
22-COL-01-WF-39	WF	Water fountain with filter	Corridor 100	8/9/22	9:25	P	< 1.00	P	< 1.00
22-COL-01-WF-40	WF	Water fountain with filter	Corridor 100	8/9/22	9:26	P	< 1.00	P	< 1.00
22-COL-01-CF-41	CF	Classroom faucets	113A	8/9/22	9:30	F	16.5	P	< 1.00
22-COL-01-CF-42	CF	Classroom faucets	110A	8/9/22	9:32	F	17.1	P	< 1.00
22-COL-01-CF-43	CF	Classroom faucets	112A	8/9/22	9:33	P	9.26	P	1.62
22-COL-01-CF-44	CF	Classroom faucets	111A	8/9/22	9:25	P	4.69	P	5.62
22-COL-01-WC-52	WC	Water fountain with cooler	Corridor A	8/9/22	10:33	P	< 1.00	P	< 1.00
22-COL-01-WC-53	WC	Water fountain with cooler	Corridor A	8/9/22	10:34	P	< 1.00	P	< 1.00
22-COL-01-WF-54	WF	Water fountain with filter	Cafeteria	8/9/22	10:35	P	< 1.00	P	< 1.00
22-COL-01-WF-55	WF	Water fountain with filter	Cafeteria	8/9/22	10:36	P	< 1.00	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-COL-01-KF-56	KF	Kitchen faucet	Servery	8/9/22	10:39	P	3.81	P	< 1.00
22-COL-01-KF-57	KF	Kitchen faucet	Servery	8/9/22	10:40	P	3.17	P	< 1.00
22-COL-01-KF-58	KF	Kitchen faucet	Servery	8/9/22	10:41	P	1.93	P	< 1.00
22-COL-02-CF-59	CF	Classroom faucets	204A	8/9/22	9:45	F	20.8	P	1.67
22-COL-02-CF-60	CF	Classroom faucets	205A	8/9/22	9:46	F	23.3	P	1.92
22-COL-02-CF-61	CF	Classroom faucets	203A	8/9/22	9:48	P	9.88	P	1.87
22-COL-02-CF-62	CF	Classroom faucets	206A	8/9/22	9:50	P	9.22	P	1.05
22-COL-02-WF-63	WF	Water fountain with filter	Corridor 200	8/9/22	9:54	P	< 1.00	P	< 1.00
22-COL-02-WF-64	WF	Water fountain with filter	Corridor 200	8/9/22	9:55	P	< 1.00	P	< 1.00
22-COL-02-CF-70	CF	Classroom faucets	201	8/9/22	10:00	P	5.21	P	< 1.00
22-COL-02-CF-73	CF	Classroom faucets	214A	8/9/22	10:05	P	9.1	P	< 1.00
22-COL-02-WF-77	WF	Water fountain with filter	Corridor 200	8/9/22	10:08	P	< 1.00	P	< 1.00
22-COL-02-WF-78	WF	Water fountain with filter	Corridor 200	8/9/22	10:09	P	< 1.00	P	< 1.00
22-COL-02-CF-79	CF	Classroom faucets	213A	8/9/22	10:12	P	1.75	P	< 1.00
22-COL-02-CF-80	CF	Classroom faucets	210A	8/9/22	10:17	P	3.63	P	1.16
22-COL-02-CF-81	CF	Classroom faucets	212A	8/9/22	10:19	P	7.52	F	137
22-COL-02-CF-82	CF	Classroom faucets	211A	8/9/22	10:20	P	9.13	P	4.33
22-COL-02-WF-94	WF	Water fountain with filter	227	8/9/22	10:42	P	< 1.00	P	< 1.00
22-COL-02-WF-95	WF	Water fountain with filter	227	8/9/22	10:43	P	< 1.00	P	< 1.00
22-COL-02-OF-97	OF	Office faucet	Nurse	8/9/22	10:44	P	3.52	P	< 1.00
22-COL-03-CF-99	CF	Classroom faucets	301	8/9/22	10:25	F	134	P	8.07

P - Passed water sample result

F - Failed water sample result

Concord PreK-5

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Concord Pre K-5

Address: 2350 Brownsville Road, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-CON-BS-SL-00	SL	Service Line	000 Storage	5/5/2022	6:20	P	< 1.00	N/A	N/A
22-CON-BS-WM-00	WM	Water Main	000 Storage	5/5/2022	6:15	P	1.12	N/A	N/A
22-CON-BS-WF-07	WF	Water fountain with filter & cooler	Outside Restroom	5/5/2022	6:24	P	< 1.00	P	< 1.00
22-CON-BS-WF-08	WF	Water fountain with filter & cooler	Outside Restroom	5/5/2022	6:25	P	< 1.00	P	< 1.00
22-CON-BS-TF-16	TF	Teacher's lounge sinks	Lounge	5/5/2022	6:26	P	< 1.00	P	< 1.00
22-CON-GF-WF-25	WF	Water fountain with filter & cooler	Outside Restroom	5/5/2022	6:33	P	< 1.00	P	< 1.00
22-CON-GF-WF-26	WF	Water fountain with filter & cooler	Outside Restroom	5/5/2022	6:34	P	< 1.00	P	< 1.00
22-CON-GF-WF-29	WF	Water fountain with filter & cooler	Outside Cafeteria	5/5/2022	6:36	P	< 1.00	P	< 1.00
22-CON-GF-KF-30	KF	Kitchen faucets	3	5/5/2022	6:38	P	1.68	P	< 1.00
22-CON-GF-KF-31	KF	Kitchen faucets	3	5/5/2022	6:39	P	< 1.00	P	< 1.00
22-CON-GF-KF-32	KF	Kitchen faucets	3	5/5/2022	6:40	P	< 1.00	P	< 1.00
22-CON-GF-KF-33	KF	Kitchen faucets	3	5/5/2022	6:42	P	< 1.00	P	< 1.00
22-CON-GF-WF-35	WF	Water fountain with filter & cooler	Outside Restroom	5/5/2022	6:43	P	< 1.00	P	< 1.00
22-CON-GF-WF-36	WF	Water fountain with filter & cooler	Outside Restroom	5/5/2022	6:44	P	< 1.00	P	< 1.00
22-CON-01-NF-43	NF	Nurse's office sink faucets	102B	5/5/2022	6:49	P	2.09	P	< 1.00
22-CON-01-CF-45	CF	Classroom faucets	X104	5/5/2022	6:52	P	3.53	P	< 1.00
22-CON-01-WF-46	WF	Water fountain with filter & cooler	X104	5/5/2022	6:53	P	< 1.00	P	< 1.00
22-CON-01-WF-48	WF	Water fountain with filter & cooler	Outside Boys	5/5/2022	6:57	P	< 1.00	P	< 1.00
22-CON-01-WF-49	WF	Water fountain with filter & cooler	Outside Boys	5/5/2022	6:58	P	< 1.00	P	< 1.00
22-CON-01-CF-54	CF	Classroom faucets	X117	5/5/2022	6:59	P	< 1.00	P	< 1.00
22-CON-01-CF-55	CF	Classroom faucets	X117	5/5/2022	7:00	P	5.45	P	1.16
22-CON-01-CF-57	CF	Classroom faucets	X118	5/5/2022	7:05	P	4.25	P	1.04
22-CON-01-TF-60	TF	Teacher's lounge sinks	X119	5/5/2022	7:09	P	< 1.00	P	< 1.00
22-CON-01-CF-62	CF	Classroom faucets	X123	5/5/2022	7:12	P	< 1.00	P	< 1.00
22-CON-01-CF-63	CF	Classroom faucets	X123	5/5/2022	7:13	P	1.67	P	< 1.00
22-CON-01-CF-65	CF	Classroom faucets	X120	5/5/2022	7:14	P	< 1.00	P	< 1.00
22-CON-01-CF-68	CF	Classroom faucets	X122	5/5/2022	7:18	P	2.83	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-CON-01-WF-70	WF	Water fountain with filter & cooler	Outside Girls	5/5/2022	7:20	P	< 1.00	P	< 1.00
22-CON-01-WF-71	WF	Water fountain with filter & cooler	Outside Girls	5/5/2022	7:21	P	< 1.00	P	< 1.00
22-CON-02-WF-78	WF	Water fountain with filter & cooler	2nd Fl. Corridor	5/5/2022	7:27	P	< 1.00	P	< 1.00
22-CON-02-WF-79	WF	Water fountain with filter & cooler	2nd Fl. Corridor	5/5/2022	7:28	P	< 1.00	P	< 1.00
22-CON-02-CF-85	CF	Classroom faucets	Media Cntr Storage	5/5/2022	7:30	F	26.9	P	< 1.00
22-CON-02-CF-86	CF	Classroom faucets	Science Room	5/5/2022	7:35	P	2.14	P	< 1.00
22-CON-02-CF-87	CF	Classroom faucets	Science Room	5/5/2022	7:36	P	2.11	P	< 1.00
22-CON-02-WF-88	WF	Water fountain with filter & cooler	Outside Girls	5/5/2022	7:38	P	< 1.00	P	< 1.00
22-CON-02-WF-89	WF	Water fountain with filter & cooler	Outside Girls	5/5/2022	7:39	P	< 1.00	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Conroy

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Conroy

Address: 1398 Page St., Pittsburgh, PA 15233

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-CNY-GF-WM-00	WM	Water Main	14A	5/17/2022	0635	P	<1.00	N/A	N/A
22-CNY-GF-SL-00	SL	Service Line	14A	5/17/2022	0630	P	<1.00	N/A	N/A
22-CNY-GF-OF-05	OF	Office sink faucets	20	5/17/2022	0642	P	10.7	P	5.7
22-CNY-GF-WF-09	WF	Water fountain with filter and cooler	Corridor 10	5/17/2022	0644	P	<1.00	P	<1.00
22-CNY-GF-WF-10	WF	Water fountain with filter and cooler	Corridor 10	5/17/2022	0645	P	<1.00	P	<1.00
22-CNY-01-WF-21	WF	Water fountain with filter and cooler	Corridor by auditorium	5/17/2022	0649	P	<1.00	P	<1.00
22-CNY-01-WF-22	WF	Water fountain with filter and cooler	Corridor by auditorium	5/17/2022	0650	P	<1.00	P	<1.00
22-CNY-01-KF-23	KF	Kitchen faucets	122B	5/17/2022	0652	P	3.43	P	<1.00
22-CNY-01-KF-32	KF	Kitchen faucets	108A	5/17/2022	0657	P	5.24	P	<1.00
22-CNY-01-NF-33	NF	Nurse's office sink faucets	105I	5/17/2022	0659	P	7.78	P	<1.00
22-CNY-01-KF-36	KF	Kitchen faucets	108	5/17/2022	0705	P	4.91	P	<1.00
22-CNY-01-KF-37	KF	Kitchen faucets	108	5/17/2022	0706	P	3.38	P	<1.00
22-CNY-01-KF-38	KF	Kitchen faucets	108	5/17/2022	0709	P	1.08	P	<1.00
22-CNY-01-KF-39	KF	Kitchen faucets	108	5/17/2022	0711	P	3.16	P	<1.00
22-CNY-01-TF-40	TF	Teacher's faucet	102B	5/17/2022	0703	P	1.99	P	<1.00
22-CNY-01-KF-43	KF	Kitchen faucets	107A	5/17/2022	0707	P	1.09	P	<1.00
22-CNY-01-KF-44	KF	Kitchen faucets	107A	5/17/2022	0708	P	<1.00	P	<1.00
22-CNY-01-KF-45	KF	Kitchen faucets	107A	5/17/2022	0713	P	2.01	P	<1.00
22-CNY-01-KF-46	KF	Kitchen faucets	107	5/17/2022	0714	P	2.01	P	<1.00
22-CNY-01-WF-47	WF	Water fountain with filter and cooler	100C	5/17/2022	0716	P	<1.00	P	<1.00
22-CNY-01-WF-48	WF	Water fountain with filter and cooler	100C	5/17/2022	0717	P	<1.00	P	<1.00
22-CNY-02-WF-49	WF	Water fountain with filter and cooler	200A	5/17/2022	0722	P	<1.00	P	<1.00
22-CNY-02-WF-50	WF	Water fountain with filter and cooler	200A	5/17/2022	0723	P	<1.00	P	<1.00
22-CNY-01-WF-68	WF	Water fountain with filter and cooler	Corridor by west stairs	5/17/2022	0731	P	<1.00	P	<1.00
22-CNY-01-WF-72	WF	Water fountain with filter and cooler	Corridor by east stairs	5/17/2022	0732	P	<1.00	P	<1.00
22-CNY-01-CF-76	CF	Classroom faucets	101	5/17/2022	0734	P	<1.00	P	<1.00
22-CNY-02-WF-80	WF	Water fountain with filter and cooler	200C (West)	5/17/2022	0742	P	<1.00	P	<1.00
22-CNY-02-WF-81	WF	Water fountain with filter and cooler	200C (West)	5/17/2022	0743	P	<1.00	P	<1.00
22-CNY-02-WF-86	WF	Water fountain with filter and cooler	200C (East)	5/17/2022	0744	P	<1.00	P	<1.00
22-CNY-02-WF-87	WF	Water fountain with filter and cooler	200C (East)	5/17/2022	0745	P	<1.00	P	<1.00
22-CNY-03-WF-95	WF	Water fountain with filter and cooler	300C West	5/17/2022	0748	P	<1.00	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-CNY-03-WF-96	WF	Water fountain with filter and cooler	300C West	5/17/2022	0749	P	<1.00	P	<1.00
22-CNY-03-CF-100	CF	Classroom faucets	307A	5/17/2022	0751	F	30.6	P	3.12
22-CNY-03-WF-104	WF	Water fountain with filter and cooler	300C East	5/17/2022	0753	P	<1.00	P	<1.00
22-CNY-03-WF-105	WF	Water fountain with filter and cooler	300C East	5/17/2022	0754	P	<1.00	P	<1.00
22-CNY-04-WF-111	WF	Water fountain with filter and cooler	400C West	5/17/2022	0800	P	<1.00	P	<1.00
22-CNY-04-WF-112	WF	Water fountain with filter and cooler	400C West	5/17/2022	0801	P	<1.00	P	<1.00
22-CNY-04-WF-115	WF	Water fountain with filter and cooler	400C East	5/17/2022	0802	P	<1.00	P	<1.00
22-CNY-04-WF-116	WF	Water fountain with filter and cooler	400C East	5/17/2022	0803	P	<1.00	P	<1.00
22-CNY-GF-WO-122	WO	Water fountain without cooler	Corridor 10	5/17/2022	0638	F	30.8	P	9.61
22-CNY-GF-WO-123	WO	Water fountain without cooler	Corridor 10	5/17/2022	0639	F	15.6	P	4.83

P - Passed water sample result

F - Failed water sample result

Dilworth PreK-5

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Dilworth Pre K-5

Address: 6200 Stanton Avenue, Pittsburgh, PA 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-DIL-BS-SL-00	SL	Service Line	11	5/3/2022	06:40	P	< 1.00	N/A	N/A
22-DIL-BS-WM-00	WM	Water Main	11	5/3/2022	06:35	P	< 1.00	N/A	N/A
22-DIL-BS-CF-01	CF	Classroom faucets	5	5/3/2022	06:30	P	< 1.00	P	< 1.00
22-DIL-BS-WF-07	WF	New Water fountain with filter and cooler	Outside 2A	5/3/2022	06:45	P	< 1.00	P	< 1.00
22-DIL-BS-WF-08	WF	New Water fountain with filter and cooler	Outside 2A	5/3/2022	06:47	P	< 1.00	P	< 1.00
22-DIL-BS-MC-12	MC	Multi-Purpose Room/Cafeteria faucets	002	5/3/2022	06:47	P	< 1.00	P	< 1.00
22-DIL-BS-KF-14	KF	Kitchen faucets	002	5/3/2022	06:50	P	< 1.00	P	< 1.00
22-DIL-BS-WF-19	WF	Water fountain with filter & cooler	Outside 16	5/3/2022	06:59	P	< 1.00	P	< 1.00
22-DIL-BS-WF-20	WF	Water fountain with filter & cooler	Outside 16	5/3/2022	07:00	P	< 1.00	P	< 1.00
22-DIL-01-CF-26	CF	Classroom faucets	104-A	5/3/2022	07:11	P	2.38	P	< 1.00
22-DIL-01-CF-28	CF	Classroom faucets	106-A	5/3/2022	07:15	P	1.17	P	< 1.00
22-DIL-01-CF-29	CF	Classroom faucets	103-A	5/3/2022	07:16	P	2.75	P	< 1.00
22-DIL-01-WF-30	WF	New Water fountain with filter and cooler	Outside 102	5/3/2022	07:30	P	< 1.00	P	< 1.00
22-DIL-01-WF-31	WF	New Water fountain with filter and cooler	Outside 102	5/3/2022	07:31	P	< 1.00	P	< 1.00
22-DIL-01-CF-36	CF	Classroom faucets	114-A	5/3/2022	07:32	P	13.7	P	< 1.00
22-DIL-01-CF-37	CF	Classroom faucets	114-A	5/3/2022	7:32	P	5.89	P	9.61
22-DIL-01-WF-38	WF	Water fountain with filter & cooler	Outside 113	5/3/2022	07:33	P	< 1.00	P	< 1.00
22-DIL-01-WF-39	WF	Water fountain with filter & cooler	Outside 113	5/3/2022	07:34	P	< 1.00	P	< 1.00
22-DIL-01-CF-48	CF	Classroom faucets	113-A	5/3/2022	07:35	P	6.02	P	1.56
22-DIL-01-CF-49	CF	Classroom faucets	111-A	5/3/2022	07:36	P	2.78	P	< 1.00
22-DIL-01-CF-50	CF	Classroom faucets	112	5/3/2022	07:37	P	5.59	P	< 1.00
22-DIL-02-CF-51	CF	Classroom faucets	206-A	5/3/2022	07:42	P	< 1.00	P	< 1.00
22-DIL-02-CF-52	CF	Classroom faucets	202	5/3/2022	07:45	P	1.17	P	< 1.00
22-DIL-02-WF-53	WF	New Water fountain with filter and cooler	Outside 201	5/3/2022	07:47	P	< 1.00	P	< 1.00
22-DIL-02-WF-54	WF	New Water fountain with filter and cooler	Outside 201	5/3/2022	07:48	P	< 1.00	P	< 1.00
22-DIL-02-TF-55	TF	Teacher's lounge sinks	215	5/3/2022	07:48	P	< 1.00	P	1.15
22-DIL-02-WF-58	WF	Water fountain with filter & cooler	Corr. 200	5/3/2022	07:51	P	3.5	P	< 1.00
22-DIL-02-WF-59	WF	Water fountain with filter & cooler	Corr. 200	5/3/2022	07:52	P	< 1.00	P	< 1.00
22-DIL-02-CF-68	CF	Classroom faucets	212-A	5/3/2022	07:53	P	< 1.00	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Fulton PreK-5

Lead in Drinking Water Sample Results
 Drinking Water Quality Initiative 2022

School: Pittsburgh Fulton Pre K-5

Address: 5799 Hampton Street Pittsburgh, PA 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-FUL-BS-SL-00	SL	Service Line (Brass Valve)	Crawlspace	5/26/2022	6:34	P	<1.00	N/A	N/A
22-FUL-BS-WM-00	WM	Water Main	Crawlspace	5/26/2022	6:39	P	<1.00	N/A	N/A
22-FUL-BS-CF-01	CF	Classroom faucets	7	5/26/2022	6:25	P	5.77	P	1.59
22-FUL-BS-CF-02	CF	Classroom faucets	6	5/26/2022	6:40	P	<1.00	P	<1.00
22-FUL-BS-MS-03	MS	Miscellaneous sinks	8	5/26/2022	6:54	F	22.1	F	24.4
22-FUL-BS-WF-04	WF	Water fountain with filter & cooler	Outside 4	5/26/2022	6:42	P	<1.00	P	<1.00
22-FUL-BS-WF-05	WF	Water fountain with filter & cooler	Outside 4	5/26/2022	6:43	P	<1.00	P	<1.00
22-FUL-BS-CF-08	CF	Classroom faucets	1-A	5/26/2022	6:44	P	1.11	P	<1.00
22-FUL-01-MC-10	MC	Multi-Purpose Room/Cafeteria faucets	108-A	5/26/2022	6:46	P	1.94	P	1.42
22-FUL-01-WF-12	WF	Water fountain with filter & cooler	Outside 110	5/26/2022	6:49	P	<1.00	P	<1.00
22-FUL-01-WF-23	WF	Water fountain with filter & cooler	Outside 101	5/26/2022	6:55	P	<1.00	P	<1.00
22-FUL-01-WF-24	WF	Water fountain with filter & cooler	Outside 101	5/26/2022	6:56	P	<1.00	P	<1.00
22-FUL-01-TF-25	TF	Teacher's lounge sinks	102	5/26/2022	6:59	P	<1.00	P	<1.00
22-FUL-02-NF-27	NF	Nurse's office sink faucets	214	5/26/2022	7:04	P	2.35	P	2.63
22-FUL-02-WF-29	WF	Water fountain with filter & cooler	Outside 211	5/26/2022	7:06	P	<1.00	P	<1.00
22-FUL-02-WF-38	WF	Water fountain with filter & cooler	Outside 201	5/26/2022	7:10	P	<1.00	P	<1.00
22-FUL-02-WF-39	WF	Water fountain with filter & cooler	Outside 201	5/26/2022	7:11	P	<1.00	P	<1.00
22-FUL-02-CF-40	CF	Classroom faucets	203	5/26/2022	7:13	F	16.7	P	8.43
22-FUL-02-CF-41	CF	Classroom faucets	203	5/26/2022	7:14	P	<1.00	P	<1.00
22-FUL-02-CF-42	CF	Classroom faucets	203	5/26/2022	7:15	P	14.2	P	2.63

P - Passed water sample result

F - Failed water sample result

Grandview K-5

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Grandview

Address: 845 Mclain Street, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Estimated Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-GRD-BS-WM-00	WM	Water Main	B-08	8/24/2022	08:24	P	1.41	N/A	N/A
22-GRD-BS-SL-00	SL	Service Line	B-08	8/24/2022	08:29	P	1.15	N/A	N/A
22-GRD-BS-KF-01	KF	Kitchen faucets	B-08	8/24/2022	08:31	P	5.81	P	1.13
22-GRD-BS-KF-02	KF	Kitchen faucets	B-08	8/24/2022	08:32	P	5.58	P	1.22
22-GRD-BS-KF-03	KF	Kitchen faucets	B-08	8/24/2022	08:19	P	9.43	P	2.24
22-GRD-BS-WF-04	WF	Water fountain with filter and cooler	Basement Ramp	8/24/2022	08:33	P	< 1.00	P	< 1.00
22-GRD-BS-WF-05	WF	Water fountain with filter and cooler	Basement Ramp	8/24/2022	08:34	P	< 1.00	P	< 1.00
22-GRD-01-CF-18	CF	Classroom faucets	108	8/24/2022	08:40	P	11.2	P	1.23
22-GRD-01-GF-21	GF	Water fountain without cooler	106	8/24/2022	08:40	P	< 1.00	P	< 1.00
22-GRD-01-CF-22	CF	Classroom faucets	104	8/24/2022	08:51	F	46.5	P	12.5
22-GRD-01-CF-24	CF	Classroom faucets	104	8/24/2022	08:46	P	5.91	P	< 1.00
22-GRD-01-CF-25	CF	Classroom faucets	104	8/24/2022	08:47	F	27.6	P	< 1.00
22-GRD-01-WF-26	WF	Water fountain bubbler (Ceramic or Porcelain)	Hall 111	8/24/2022	08:52	P	< 1.00	P	< 1.00
22-GRD-01-WF-27	WF	Water fountain bubbler (Ceramic or Porcelain)	Hall 111	8/24/2022	08:53	P	< 1.00	p	< 1.00
22-GRD-01-TF-32	TF	Teacher's lounge sinks	106	8/24/2022	08:56	P	8.86	p	2.29
22-GRD-01-CF-33	CF	Classroom faucets	101	8/24/2022	08:58	F	35.6	P	4.77
22-GRD-01-CF-35	CF	Classroom faucets	103	8/24/2022	08:59	P	14.3	p	2.08
22-GRD-01-WF-40	WF	Water fountain with filter and cooler	Corridor 124	8/24/2022	09:03	P	< 1.00	p	< 1.00
22-GRD-01-WF-41	WF	Water fountain with filter and cooler	Corridor 124	8/24/2022	09:04	P	< 1.00	p	< 1.00
22-GRD-01-CF-42	CF	Classroom faucets	105	8/24/2022	09:05	P	6.93	p	< 1.00
22-GRD-01-CF-43	CF	Classroom faucets	107B	8/24/2022	09:08	F	31.8	p	2.65
22-GRD-01-CF-50	CF	Classroom faucets	111	8/24/2022	09:09	F	25	p	7.17
22-GRD-02-TF-54	TF	Teacher's lounge sinks	216	8/24/2022	09:10	P	4.39	p	1.47
22-GRD-02-WF-58	WF	Water fountain bubbler (Ceramic or Porcelain)	Corridor 201	8/24/2022	09:19	P	< 1.00	p	< 1.00
22-GRD-02-WF-59	WF	Water fountain bubbler (Ceramic or Porcelain)	Corridor 201	8/24/2022	09:20	P	< 1.00	p	< 1.00
22-GRD-02-CF-60	CF	Classroom faucets	217	8/24/2022	09:22	P	9.94	p	4.49
22-GRD-02-WO-61	WO	Water fountain without cooler	217	8/24/2022	09:23	P	13.2	p	5.37
22-GRD-02-WF-62	WF	Water fountain with filter and cooler	Corridor 201	8/24/2022	09:26	P	< 1.00	p	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Estimated Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-GRD-02-WF-63	WF	Water fountain with filter and cooler	Corridor 201	8/24/2022	09:27	P	< 1.00	P	< 1.00
22-GRD-02-CF-77	CF	Classroom faucets	213	8/24/2022	0920	F	21	P	6.67

P - Passed water sample result

F - Failed water sample result

Greenway (Classical-Gifted Center)

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Greenway Classical-Gifted Center

Address: 1400 Crucible Street Pittsburgh, PA 15205

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-GNW-2.6-WM-00	WM	Water Main	2-606	6/30/2022	7:05	P	<1.00	N/A	N/A
22-GNW-2.6-SL-00	SL	Service Line	2-606	6/30/2022	7:10	P	<1.00	N/A	N/A
22-GNW-2.6-WC-10	WC	Water fountain without cooler	2.601	6/30/2022	7:13	P	<1.00	P	<1.00
22-GNW-3.6-WF-13	WF	'Water fountain with filter and cooler	3.631	6/30/2022	7:19	P	<1.00	P	<1.00
22-GNW-3.6-WF-14	WF	'Water fountain with filter and cooler	3.631	6/30/2022	7:20	P	<1.00	P	<1.00
22-GNW-3.6-NF-20	NF	Nurse's office sink faucets	3.627	6/30/2022	7:38	P	<1.00	P	<1.00
22-GNW-3.6-WB-23	WB	Water fountain bubbler (Ceramic or Porcelain)	3.06	6/30/2022	7:45	P	1.48	P	<1.00
22-GNW-3.5-WC-36	WC	Water fountain with cooler	3.519	6/30/2022	7:30	P	<1.00	P	1.15
22-GNW-2.4-CF-42	CF	Classroom faucets	2.489	6/30/2022	8:00	P	2.65	P	<1.00
22-GNW-2.4-CF-52	CF	Classroom faucets	2.465	6/30/2022	8:04	P	1.27	P	<1.00
22-GNW-2.4-CF-53	CF	Classroom faucets	2.464	6/30/2022	8:05	P	4.01	P	1.38
22-GNW-2.4-CF-55	CF	Classroom faucets	2.463	6/30/2022	8:13	P	7.25	P	<1.00
22-GNW-2.4-WF-57	WF	Water fountain with filter and cooler	2.401	6/30/2022	8:18	P	<1.00	P	<1.00
22-GNW-2.4-WC-67	WC	Water fountain with cooler	2.410	6/30/2022	8:26	P	<1.00	P	<1.00
22-GNW-2.4-WC-68	WC	Water fountain with cooler	2.410	6/30/2022	8:27	P	<1.00	P	<1.00
22-GNW-2.4-KF-71	KF	Kitchen faucets	Cafeteria	6/30/2022	8:28	P	<1.00	P	<1.00
22-GNW-2.4-KF-72	KF	Kitchen faucets	Cafeteria	6/30/2022	8:29	P	<1.00	P	<1.00
22-GNW-2.4-KF-73	KF	Kitchen faucets	Cafeteria	6/30/2022	8:30	P	1.25	P	<1.00
22-GNW-2.4-CF-74	CF	Classroom faucets	2.472	6/30/2022	8:43	P	1.97	P	<1.00
22-GNW-2.4-CF-75	CF	Classroom faucets	2.473	6/30/2022	8:46	P	1.26	P	<1.00
22-GNW-2.4-WO-76	WO	Water fountain without cooler	2.417	6/30/2022	8:47	P	<1.00	P	<1.00
22-GNW-2.4-HF-77	HF	Home economics faucets (with cooking)	2.417	6/30/2022	8:49	P	1.25	P	<1.00
22-GNW-2.4-CF-78	CF	Classroom faucets	2.417	6/30/2022	8:50	F	153	F	69.7
22-GNW-2.4-HF-79	HF	Home economics faucets (with cooking)	2.417	6/30/2022	8:51	P	10.2	P	6.45
22-GNW-2.4-HF-80	HF	Home economics faucets (with cooking)	2.417	6/30/2022	8:52	P	1.17	P	<1.00
22-GNW-2.4-CF-81	CF	Classroom faucets	2.469	6/30/2022	8:59	P	1.0	P	<1.00
22-GNW-2.4-CF-82	CF	Classroom faucets	2.469	6/30/2022	9:00	P	1.02	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-GNW-2.4-WO-83	WO	Water fountain without cooler	2.418	6/30/2022	9:01	P	2.33	P	<1.00
22-GNW-2.4-CF-84	CF	Classroom faucets	2.468	6/30/2022	9:02	P	2.43	P	1.55
22-GNW-2.4-CF-85	CF	Classroom faucets	2.468	6/30/2022	9:03	P	1.61	P	<1.00
22-GNW-2.4-CF-86	CF	Classroom faucets	2.467	6/30/2022	9:04	P	1.99	P	<1.00
22-GNW-2.4-CF-87	CF	Classroom faucets	2.467	6/30/2022	9:05	P	8.21	P	<1.00
22-GNW-2.3-TF-88	TF	Teacher's lounge sinks	2.389	6/30/2022	9:06	P	<1.00	P	<1.00
22-GNW-2.3-WF-117	WF	Water fountain with filter and cooler	2.301	6/30/2022	9:17	P	<1.00	P	<1.00
22-GNW-2.3-WB-118	WB	Water fountain bubbler (Ceramic or Porcelain)	2.320	6/30/2022	9:39	P	1.91	P	<1.00
22-GNW-2.3-WB-119	WB	Water fountain bubbler (Ceramic or Porcelain)	2.319	6/30/2022	9:40	P	1.36	P	<1.00
22-GNW-2.1-WF-134	WF	Water fountain with filter and cooler	2.101	6/30/2022	10:21	P	<1.00	P	<1.00
22-GNW-1.1-MS-140	MS	Miscellaneous sinks	1.119	6/30/2022	10:34	P	12.5	P	1.13
22-GNW-1.1-WC-142	WC	Water fountain with cooler	1.106	6/30/2022	10:35	P	<1.00	P	<1.00
22-GNW-1.1-WC-143	WC	Water fountain with cooler	1.105	6/30/2022	10:41	P	<1.00	P	<1.00
22-GNW-1.1-WC-144	WC	Water fountain with cooler	1.151	6/30/2022	10:43	P	<1.00	P	<1.00
22-GNW-2.2-WF-156	WF	Water fountain with filter and cooler	2.201	6/30/2022	9:49	P	<1.00	P	<1.00
22-GNW-1.2-OF-157	OF	Office sink faucets	1.221	6/30/2022	9:55	P	<1.00	P	<1.00
22-GNW-1.2-MS-161	MS	Miscellaneous sinks	1.213	6/30/2022	9:56	P	1.09	P	<1.00
22-GNW-1.1-KF-162	KF	Kitchen faucets	1.113	6/30/2022	10:44	P	<1.00	P	<1.00
22-GNW-1.1-KF-164	KF	Kitchen faucets	1.113	6/30/2022	10:45	P	1.72	P	<1.00
22-GNW-1.1-KF-165	KF	Kitchen faucets	1.113	6/30/2022	10:46	P	<1.00	P	<1.00
22-GNW-2.1-WO-169	WO	Water fountain without cooler	2.120	6/30/2022	10:51	P	<1.00	P	<1.00
22-GNW-2.1-WO-170	WO	Water fountain without cooler	Outside 2.173	6/30/2022	10:52	P	6.66	P	<1.00
22-GNW-2.1-TF-176	TF	Teacher's lounge sinks	2.188	6/30/2022	10:55	P	1.24	P	<1.00
22-GNW-2.1-CF-189	CF	Classroom faucets	2.163	6/30/2022	10:56	P	<1.00	P	<1.00
22-GNW-2.2-WO-190	WO	Water fountain without cooler	2.220	6/30/2022	10:01	P	<1.00	P	<1.00
22-GNW-2.2-WO-191	WO	Water fountain without cooler	near 2.218	6/30/2022	10:02	P	<1.00	P	<1.00
22-GNW-2.2-TF-192	TF	Teacher's lounge sinks	2.289	6/30/2022	10:04	P	<1.00	P	<1.00
22-GNW-2.1-WF-215	WF	Water fountain with filter and cooler	2.101	6/30/2022	10:21	P	<1.00	P	<1.00
22-GNW-2.2-WF-216	WF	Water fountain with filter and cooler	2.201	6/30/2022	9:50	P	<1.00	P	<1.00
22-GNW-1.2-WC-217	WC	Water fountain with cooler	1.204	6/30/2022	10:09	P	1.89	P	1.95
22-GNW-2.3-WF-221	WF	Water fountain with filter and cooler	2.301	6/30/2022	9:18	P	<1.00	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-GNW-2.2-WF-222	WF	Water fountain with filter and cooler	2.401	6/30/2022	8:19	P	<1.00	P	<1.00
22-GNW-2.4-GF-74.5	GF	Filtered glass filler	2.472	6/30/2022	8:44	P	<1.00	P	<1.00
22-GNW-2.4-HF-80.5	HF	Home economics faucets (with cooking)	2.417	6/30/2022	8:53	P	1.62	P	<1.00
22-GNW-2.3-CF-99	CF	Classroom faucets	2.363	6/30/2022	9:30	P	<1.00	P	<1.00
22-GNW-2.3-CF-100	CF	Classroom faucets	2.363	6/30/2022	9:31	P	<1.00	P	<1.00
22-GNW-2.3-CF-101	CF	Classroom faucets	2.363	6/30/2022	9:32	P	1.26	P	1.22
22-GNW-2.3-CF-102	CF	Classroom faucets	2.363	6/30/2022	9:33	P	1.06	P	<1.00
22-GNW-2.3-CF-103	CF	Classroom faucets	2.363	6/30/2022	9:34	P	5.15	P	2.77
22-GNW-2.3-CF-104	CF	Classroom faucets	2.363	6/30/2022	9:35	P	3.43	P	2.96
22-GNW-1.1-CF-135	CF	Classroom faucets	1.140	6/30/2022	10:32	P	5.28	F	17.1
22-GNW-1.1-CF-136	CF	Classroom faucets	1.140	6/30/2022	10:33	P	<1.00	P	<1.00
22-GNW-1.1-CF-137	CF	Classroom faucets	1.126	6/30/2022	10:34	P	<1.00	P	<1.00

P - Passed water sample result

F - Failed water sample result

Langley Field House

Lead in Drinking Water Sample Results
 Drinking Water Quality Initiative 2022

School: Langley Field House

Address: 2940 Sheraden Boulevard, Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-LFH-GF-WM-00	WM	Water Main	Locker Room	6/30/2022	7:53	P	<1.00	NA	NA
22-LFH-GF-SL-00	SL	Service Line	Locker Room	6/30/2022	7:58	P	<1.00	NA	NA
22-LFH-GF-WF-01	WF	Water fountain with filter & cooler	Locker Room	6/30/2022	8:00	P	<1.00	P	<1.00
22-LFH-01-WM-00	WM	Water Main	Lower Field House	6/30/2022	8:10	P	2.24	NA	NA
22-LFH-01-SL-00	SL	Service Line	Lower Field House	6/30/2022	8:15	P	<1.00	NA	NA
22-LFH-02-IM-12	NF	Ice Machine	Upper Field House	6/30/2022	8:18	P	1.61	NA	NA
22-LFH-GF-MS-14	MS	Miscellaneous Sink	Locker Room Exterior	6/30/2022	8:03	P	<1.00	P	<1.00

P - Passed water sample result

F - Failed water sample result

Liberty K-5

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Liberty K-5

Address: 601 Filbert St. Pittsburgh, PA 15232

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Estimated Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-LIB-BS-WM-00	WM	Water Main	G1C	8/10/2022	08:30	P	< 1.00	N/A	N/A
22-LIB-BS-SL-00	SL	Service Line	G1C	8/10/2022	08:35	P	< 1.00	N/A	N/A
22-LIB-BS-OF-01	OF	Office sink faucets	B1A	8/10/2022	08:25	P	< 1.00	P	< 1.00
22-LIB-GF-CF-02	CF	Classroom faucets	B1A	8/10/2022	08:39	P	2.92	P	< 1.00
22-LIB-GF-CF-03	CF	Classroom faucets	G14	8/10/2022	08:40	P	11.1	P	1.66
22-LIB-GF-CF-04	CF	Classroom faucets	G10	8/10/2022	08:41	P	8.99	P	1.11
22-LIB-GF-WF-13	WF	Water fountain with filter & cooler	G10	8/10/2022	08:44	P	< 1.00	P	< 1.00
22-LIB-GF-WF-14	WF	Water fountain with filter & cooler	G3	8/10/2022	08:45	P	< 1.00	P	< 1.00
22-LIB-GF-KF-19	KF	Kitchen faucets	G7	8/10/2022	08:48	P	2.05	P	2.29
22-LIB-GF-CF-20	CF	Classroom faucets	G6	8/10/2022	08:52	P	< 1.00	P	< 1.00
22-LIB-GF-OF-22	OF	Office sink faucets	B1B	8/10/2022	08:54	P	< 1.00	P	< 1.00
22-LIB-GF-CF-24	CF	Classroom faucets	G5	8/10/2022	08:53	P	< 1.00	P	< 1.00
22-LIB-01-CF-28	CF	Classroom faucets	100A	8/10/2022	09:04	P	3.72	P	1.64
22-LIB-01-OF-31	OF	Office sink faucets	110	8/10/2022	09:05	P	< 1.00	P	< 1.00
22-LIB-01-WF-40	WF	Water fountain with filter & cooler		8/10/2022	09:09	P	< 1.00	P	< 1.00
22-LIB-01-WF-41	WF	Water fountain with filter & cooler		8/10/2022	09:10	P	< 1.00	P	< 1.00
22-LIB-01-CF-43	CF	Classroom faucets	104D	8/10/2022	09:14	P	1.42	P	3.10
22-LIB-01-CF-44	CF	Classroom faucets	201B	8/10/2022	09:16	P	< 1.00	P	< 1.00
22-LIB-01-CF-47	CF	Classroom faucets	200A	8/10/2022	09:17	P	< 1.00	P	< 1.00
22-LIB-01-NF-49	NF	Nurse's office sink faucets	208	8/10/2022	09:18	P	< 1.00	P	< 1.00
22-LIB-01-OF-51	OF	Office sink faucets	207A	8/10/2022	09:18	P	< 1.00	P	< 1.00
22-LIB-02-CF-52	CF	Classroom faucets	207B	8/10/2022	09:26	P	6.42	P	< 1.00
22-LIB-02-TF-53	TF	Teacher's lounge sinks	200B	8/10/2022	09:27	P	< 1.00	P	< 1.00
22-LIB-02-IM-55	IM	Ice machines	200B	8/10/2022	09:29	P	< 1.00		
22-LIB-02-WF-63	WF	Water fountain with filter & cooler		8/10/2022	09:32	P	< 1.00	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Estimated Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-LIB-02-WF-64	WF	Water fountain with filter & cooler		8/10/2022	09:33	P	< 1.00	P	< 1.00
22-LIB-02-CF-71	CF	Classroom faucets		8/10/2022	09:36	P	2.62	P	3.65

P - Passed water sample result

F - Failed water sample result

Mifflin PreK-8

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Mifflin Pre K-8

Address: 1290 Mifflin Road, Pittsburgh, PA , 15207

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-MIF-GF-WM-00	WM	Water Main	23D	6/1/2022	06:20	P	< 1.00	N/A	N/A
22-MIF-GF-SL-00	SL	Service Line	23D	6/1/2022	06:15	P	< 1.00	N/A	N/A
22-MIF-GF-WF-07	WF	Water fountain with filter & cooler	1st Floor Corridor	6/1/2022	06:21	P	< 1.00	P	< 1.00
22-MIF-GF-WF-08	WF	Water fountain with filter & cooler	1st Floor Corridor	6/1/2022	06:22	P	< 1.00	P	< 1.00
22-MIF-GF-KF-09	KF	Kitchen faucets	22A	6/1/2022	06:23	P	< 1.00	P	< 1.00
22-MIF-GF-KF-10	KF	Kitchen faucets	22A	6/1/2022	06:24	P	< 1.00	P	< 1.00
22-MIF-GF-KF-11	KF	Kitchen faucets	22A	6/1/2022	06:26	P	1.83	P	< 1.00
22-MIF-GF-CF-14	CF	Classroom faucets	35	6/1/2022	06:33	F	38.8	P	3.99
22-MIF-GF-WF-15	WF	Water fountain with filter & cooler	1st Floor Corridor	6/1/2022	06:34	P	< 1.00	P	< 1.00
22-MIF-GF-WF-16	WF	Water fountain with filter & cooler	1st Floor Corridor	6/1/2022	06:35	P	< 1.00	P	< 1.00
22-MIF-01-WF-27	WF	Water fountain with filter & cooler	125	6/1/2022	06:42	P	< 1.00	P	< 1.00
22-MIF-01-WF-28	WF	Water fountain with filter & cooler	125	6/1/2022	06:43	P	< 1.00	P	< 1.00
22-MIF-01-CF-29	CF	Classroom faucets	127	6/1/2022	06:44	P	2.86	P	< 1.00
22-MIF-01-CF-30	CF	Classroom faucets	121	6/1/2022	06:45	P	1.35	P	< 1.00
22-MIF-01-CF-31	CF	Classroom faucets	120	6/1/2022	06:47	P	1.77	P	< 1.00
22-MIF-01-CF-32	CF	Classroom faucets	128	6/1/2022	06:48	P	7.5	P	< 1.00
22-MIF-01-CF-33	CF	Classroom faucets	119	6/1/2022	06:51	P	3.53	P	< 1.00
22-MIF-01-CF-34	CF	Classroom faucets	129	6/1/2022	06:52	P	3.91	P	1.71
22-MIF-01-WF-41	WF	Water fountain with filter & cooler	1st Floor Corridor	6/1/2022	06:55	P	< 1.00	P	< 1.00
22-MIF-01-WF-42	WF	Water fountain with filter & cooler	1st Floor Corridor	6/1/2022	06:56	P	< 1.00	P	< 1.00
22-MIF-01-CF-43	CF	Classroom faucets	133	6/1/2022	06:58	P	1.47	P	< 1.00
22-MIF-01-CF-44	CF	Classroom faucets	133	6/1/2022	06:59	P	< 1.00	P	< 1.00
22-MIF-01-CF-45	CF	Classroom faucets	133	6/1/2022	07:00	P	< 1.00	P	< 1.00
22-MIF-01-NF-47	NF	Nurse's office sink faucets	116	6/1/2022	07:03	P	1.15	P	< 1.00
22-MIF-1-GF-47.5	GF	Glass filler with filter	116	6/1/2022	07:04	P	< 1.00	P	< 1.00
22-MIF-01-CF-51	CF	Classroom faucets	106	6/1/2022	07:07	P	8.72	P	1.03
22-MIF-01-WF-52	WF	Water fountain with filter & cooler	1st Floor Corridor	6/1/2022	07:09	P	< 1.00	P	< 1.00
22-MIF-01-WF-53	WF	Water fountain with filter & cooler	1st Floor Corridor	6/1/2022	07:10	P	< 1.00	P	< 1.00
22-MIF-01-TF-54	TF	Teacher's lounge sinks	109	6/1/2022	07:11	P	3.62	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-MIF-01-WF-56	WF	Water fountain with filter & cooler	1st Floor Corridor	6/1/2022	07:14	P	< 1.00	P	< 1.00
22-MIF-01-WF-57	WF	Water fountain with filter & cooler	1st Floor Corridor	6/1/2022	7:15	P	< 1.00	P	< 1.00
22-MIF-02-WF-65	WF	Water fountain with filter & cooler	2nd Floor Corridor	6/1/2022	7:21	P	< 1.00	P	< 1.00
22-MIF-02-WF-66	WF	Water fountain with filter & cooler	2nd Floor Corridor	6/1/2022	7:22	P	< 1.00	P	< 1.00
22-MIF-02-CF-67	CF	Classroom faucets	205	6/1/2022	7:24	P	2.78	P	3.05
22-MIF-02-WF-68	WF	Water fountain with filter & cooler	2nd Floor Corridor	6/1/2022	7:28	P	< 1.00	P	< 1.00
22-MIF-02-WF-69	WF	Water fountain with filter & cooler	2nd Floor Corridor	6/1/2022	7:29	P	< 1.00	P	< 1.00
22-MIF-02-CF-74	CF	Classroom faucets	201	6/1/2022	7:30	P	13.4	P	< 1.00
22-MIF-03-WF-76	WF	Water fountain with filter & cooler	3rd Floor Corridor	6/1/2022	7:37	P	< 1.00	P	< 1.00
22-MIF-03-WF-77	WF	Water fountain with filter & cooler	3rd Floor Corridor	6/1/2022	7:38	P	< 1.00	P	< 1.00
22-MIF-03-WF-82	WF	Water fountain with filter & cooler	3rd Floor Corridor	6/1/2022	7:39	P	< 1.00	P	< 1.00
22-MIF-03-WF-83	WF	Water fountain with filter & cooler	3rd Floor Corridor	6/1/2022	7:40	P	< 1.00	P	< 1.00
22-MIF-03-CF-87	CF	Classroom faucets	301	6/1/2022	7:42	P	6.43	P	10.1
22-MIF-01-CF-88	CF	Classroom faucets	101B	6/1/2022	7:16	F	18.2	F	18.0

P - Passed water sample result

F - Failed water sample result

Minadeo PreK-5

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Minadeo Pre K-5

Address: 6502 Lilac Street, Pittsburgh, PA 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-MIN-BS-SL-00	SL	Serve Line	Under 002	5/24/2022	5:51	P	< 1.00	N/A	N/A
22-MIN-BS-WM-00	WM	Water Main	Under 002	5/24/2022	5:46	P	< 1.00	N/A	N/A
22-MIN-GF-CF-01	CF	Classroom faucets	002	5/24/2022	5:39	P	1.10	P	< 1.00
22-MIN-GF-CF-02	CF	Classroom faucets	005	5/24/2022	5:54	P	1.34	P	< 1.00
22-MIN-GF-CF-03	CF	Classroom faucets	003	5/24/2022	5:58	P	1.22	P	< 1.00
22-MIN-GF-CF-04	CF	Classroom faucets	006	5/24/2022	5:59	P	< 1.00	P	< 1.00
22-MIN-GF-CF-08	CF	Classroom faucets	004	5/24/2022	6:02	P	2.49	P	< 1.00
22-MIN-GF-WF-09	WF	Water fountain with filter & cooler	Outside 004	5/24/2022	6:02	P	< 1.00	P	< 1.00
22-MIN-GF-WF-10	WF	Water fountain with filter & cooler	Outside 004	5/24/2022	6:03	P	< 1.00	P	< 1.00
22-MIN-GF-TF-12	TF	Teacher's lounge sinks	032	5/24/2022	6:06	P	1.74	P	< 1.00
22-MIN-GF-OF-15	OF	Office sink faucets	018	5/24/2022	6:09	P	3.20	P	< 1.00
22-MIN-GF-CF-19	CF	Classroom faucets	035	5/24/2022	6:10	P	4.17	P	< 1.00
22-MIN-GF-CF-20	CF	Classroom faucets	022	5/24/2022	6:11	P	< 1.00	P	< 1.00
22-MIN-GF-CF-22	CF	Classroom faucets	023	5/24/2022	6:17	P	< 1.00	P	< 1.00
22-MIN-GF-CF-23	CF	Classroom faucets	039	5/24/2022	6:19	P	3.16	P	< 1.00
22-MIN-GF-WF-24	WF	Water fountain with filter & cooler	Outside 023	5/24/2022	6:21	P	< 1.00	P	< 1.00
22-MIN-GF-WF-25	WF	Water fountain with filter & cooler	Outside 023	5/24/2022	6:22	P	< 1.00	P	< 1.00
22-MIN-GF-CF-26	CF	Classroom faucets	024	5/24/2022	6:23	P	1.38	P	< 1.00
22-MIN-GF-CF-27	CF	Classroom faucets	40	5/24/2022	6:27	P	10.0	P	< 1.00
22-MIN-GF-CF-28	CF	Classroom faucets	025	5/24/2022	6:28	P	1.20	P	< 1.00
22-MIN-GF-CF-30	CF	Classroom faucets	027	5/24/2022	6:35	P	< 1.00	P	< 1.00
22-MIN-GF-CF-35	CF	Classroom faucets	031	5/24/2022	6:36	P	< 1.00	P	< 1.00
22-MIN-GF-WF-37	WF	Water fountain with filter & cooler	Outside Cafeteria	5/24/2022	6:39	P	< 1.00	P	< 1.00
22-MIN-GF-WF-38	WF	Water fountain with filter & cooler	Outside Cafeteria	5/24/2022	6:40	P	< 1.00	P	< 1.00
22-MIN-GF-KF-39	KF	Kitchen faucets	045	5/24/2022	6:42	P	1.37	P	< 1.00
22-MIN-GF-KF-40	KF	Kitchen faucets	045	5/24/2022	6:43	P	1.05	P	< 1.00
22-MIN-GF-KF-41	KF	Kitchen faucets	045	5/24/2022	6:44	P	2.45	P	< 1.00
22-MIN-02-CF-43	CF	Classroom faucets	102	5/24/2022	6:52	P	1.42	P	< 1.00
22-MIN-02-CF-44	CF	Classroom faucets	104	5/24/2022	6:54	P	3.94	P	< 1.00
22-MIN-02-CF-45	CF	Classroom faucets	103	5/24/2022	6:55	P	3.59	P	< 1.00
22-MIN-02-CF-46	CF	Classroom faucets	105	5/24/2022	6:56	P	5.68	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-MIN-02-WF-52	WF	Water fountain with filter & cooler	101	5/24/2022	6:59	P	< 1.00	P	< 1.00
22-MIN-02-WF-53	WF	Water fountain with filter & cooler	101	5/24/2022	7:00	P	< 1.00	P	< 1.00
22-MIN-02-HF-59	HF	Home economics faucets (with cooking)	129	5/24/2022	7:02	P	4.02	P	< 1.00
22-MIN-02-CF-60	CF	Classroom faucets	128	5/24/2022	7:05	P	12.7	P	1.05
22-MIN-02-CF-62	CF	Classroom faucets	119	5/24/2022	7:06	P	< 1.00	P	< 1.00
22-MIN-02-CF-63	CF	Classroom faucets	119	5/24/2022	7:07	P	< 1.00	P	< 1.00
22-MIN-02-CF-65	CF	Classroom faucets	119	5/24/2022	7:08	P	< 1.00	P	< 1.00
22-MIN-02-CF-66	CF	Classroom faucets	127	5/24/2022	7:10	P	1.63	P	< 1.00
22-MIN-02-CF-67	CF	Classroom faucets	126	5/24/2022	7:14	P	2.71	P	< 1.00
22-MIN-02-CF-68	CF	Classroom faucets	120	5/24/2022	7:16	P	< 1.00	P	< 1.00
22-MIN-02-CF-69	CF	Classroom faucets	125	5/24/2022	7:17	P	1.58	P	< 1.00
22-MIN-02-WF-70	WF	Water fountain with filter & cooler	Outside 120	5/24/2022	7:20	P	< 1.00	P	< 1.00
22-MIN-02-WF-71	WF	Water fountain with filter & cooler	Outside 120	5/24/2022	7:21	P	< 1.00	P	< 1.00
22-MIN-02-CF-72	CF	Classroom faucets	121	5/24/2022	7:22	P	2.61	P	< 1.00
22-MIN-02-CF-73	CF	Classroom faucets	124	5/24/2022	7:26	P	2.61	P	< 1.00
22-MIN-02-CF-74	CF	Classroom faucets	123	5/24/2022	7:27	P	1.18	P	< 1.00
22-MIN-02-CF-76	CF	Classroom faucets	135	5/24/2022	7:32	P	4.47	P	< 1.00
22-MIN-01-GF-77.5	GF	Glass Filler with Filter	136	5/24/2022	7:36	P	< 1.00	P	< 1.00
22-MIN-02-OF-78	OF	Office sink faucets	140	5/24/2022	7:37	P	2.43	P	< 1.00
22-MIN-02-WF-80	WF	Water fountain with filter & cooler	Outside 149	5/24/2022	7:39	P	< 1.00	P	< 1.00
22-MIN-02-WF-81	WF	Water fountain with filter & cooler	Outside 149	5/24/2022	7:40	P	< 1.00	P	< 1.00
22-MIN-02-CF-92	CF	Classroom faucets	169	5/24/2022	7:43	P	< 1.00	P	< 1.00
22-MIN-02-WO-93	WO	Water fountain without cooler	Outside 165	5/24/2022	7:45	P	< 1.00	P	< 1.00
22-MIN-02-WO-94	WO	Water fountain without cooler	Outside 165	5/24/2022	7:46	P	< 1.00	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Obama 6-12, Early Childhood Center

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Obama

Address: 515 North Highland Ave, Pittsburgh, PA, 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-OBA-GF-WM-00	WM	Water Main	31	4/14/2022	7:50	P	< 1.00	N/A	N/A
22-OBA-GF-SL-00	SL	Service Line	31	4/14/2022	7:55	P	< 1.00	N/A	N/A
22-OBA-GF-WF-03	WF	Water fountain with filter and cooler	020A	4/14/2022	7:57	P	< 1.00	P	< 1.00
22-OBA-GF-WF-04	WF	Water fountain with filter and cooler	020A	4/14/2022	7:58	P	< 1.00	P	< 1.00
22-OBA-GF-CF-07	CF	Classroom faucets	023	4/14/2022	7:57	P	3.56	P	< 1.00
22-OBA-GF-CF-08	CF	Classroom faucets	023	4/14/2022	7:58	P	1.03	P	< 1.00
22-OBA-GF-WF-09	WF	Water fountain with filter and cooler	023	4/14/2022	7:59	P	< 1.00	P	< 1.00
22-OBA-GF-CF-10	CF	Classroom faucets	017	4/14/2022	8:04	P	2.39	P	< 1.00
22-OBA-GF-CF-11	CF	Classroom faucets	017	4/14/2022	8:04	F	43.9	P	< 1.00
22-OBA-GF-CF-14	CF	Classroom faucets	011	4/14/2022	8:14	P	< 1.00	P	< 1.00
22-OBA-GF-GF-15.1	GF	Filtered Glass Filler	014	4/14/2022	8:24	P	< 1.00	P	< 1.00
22-OBA-GF-WF-17	WF	Water fountain with filter and cooler	03	4/14/2022	8:15	P	< 1.00	P	< 1.00
22-OBA-GF-WF-18	WF	Water fountain with filter and cooler	03	4/14/2022	8:15	P	< 1.00	P	< 1.00
22-OBA-GF-CF-28	CF	Classroom faucets	020	4/14/2022	8:18	P	< 1.00	P	< 1.00
22-OBA-GF-CF-30	CF	Classroom faucets	030	4/14/2022	8:21	P	2.03	P	< 1.00
22-OBA-GF-CF-31	CF	Classroom faucets	030	4/14/2022	8:21	P	7.81	P	< 1.00
22-OBA-GF-CF-32	CF	Classroom faucets	030	4/14/2022	8:22	P	8.11	P	< 1.00
22-OBA-GF-CF-33	CF	Classroom faucets	030	4/14/2022	8:22	P	7.87	P	< 1.00
22-OBA-GF-WF-38	WF	Water fountain with filter and cooler	Hallway	4/14/2022	8:33	P	< 1.00	P	< 1.00
22-OBA-GF-WF-46	WF	Water fountain with filter and cooler	Hallway	4/14/2022	8:36	P	< 1.00	P	< 1.00
22-OBA-01-OF-51	OF	Office sink faucets	101A	4/14/2022	8:58	F	15.8	P	< 1.00
22-OBA-01-CF-54	CF	Classroom faucets	102	4/14/2022	9:03	P	5.33	P	< 1.00
22-OBA-01-CF-55	CF	Classroom faucets	106	4/14/2022	9:05	P	5.94	P	< 1.00
22-OBA-01-CF-56	CF	Classroom faucets	108	4/14/2022	8:59	P	2.75	P	< 1.00
22-OBA-01-CF-57	CF	Classroom faucets	124	4/14/2022	9:01	P	1.28	P	< 1.00
22-OBA-01-CF-57.5	CF	Classroom faucets	124	4/14/2022	9:03	P	2.75	P	< 1.00
22-OBA-01-HF-62	HF	Home economics faucets (with cooking)	147	4/14/2022	9:14	P	13.9	P	7.22
22-OBA-01-HF-63	HF	Home economics faucets (with cooking)	147	4/14/2022	9:16	F	15.5	P	3.16
22-OBA-01-HF-64	HF	Home economics faucets (with cooking)	147	4/14/2022	9:17	P	5.15	P	1.71

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-OBA-01-HF-65	HF	Home economics faucets (with cooking)	147	4/14/2022	9:18	P	6.05	P	5.2
22-OBA-01-HF-66	HF	Home economics faucets (with cooking)	147	4/14/2022	9:19	F	34.4	P	1.59
22-OBA-01-CF-67	CF	Classroom faucets	151	4/14/2022	9:28	P	< 1.00	P	< 1.00
22-OBA-01-CF-68	CF	Classroom faucets	132	4/14/2022	9:31	P	5.27	P	< 1.00
22-OBA-01-CF-69	CF	Classroom faucets	134	4/14/2022	9:29	P	2.67	P	< 1.00
22-OBA-01-CF-70	CF	Classroom faucets	149	4/14/2022	9:31	P	6.99	P	< 1.00
22-OBA-01-WF-71	WF	Water fountain with filter and cooler	100A	4/14/2022	9:38	P	< 1.00	P	< 1.00
22-OBA-01-WF-72	WF	Water fountain with filter and cooler	100A	4/14/2022	9:39	P	< 1.00	P	< 1.00
22-OBA-01-IM-75.1	IM	Ice maker	138	4/14/2022	9:48	P	< 1.00	N/A	N/A
22-OBA-01-KF-76	KF	Kitchen faucets	138	4/14/2022	9:50	F	15.6	P	< 1.00
22-OBA-01-KF-77	KF	Kitchen faucets	138	4/14/2022	9:52	P	2.04	P	< 1.00
22-OBA-01-KF-78	KF	Kitchen faucets	138	4/14/2022	9:33	P	7.12	P	< 1.00
22-OBA-01-KF-79	KF	Kitchen faucets	138	4/14/2022	9:55	P	8.15	P	< 1.00
22-OBA-01-WF-81	WF	Water fountain with filter and cooler	100	4/14/2022	10:01	P	< 1.00	P	< 1.00
22-OBA-01-WF-82	WF	Water fountain with filter and cooler	100	4/14/2022	10:01	P	< 1.00	P	< 1.00
22-OBA-01-WF-89	WF	Water fountain with filter and cooler	160	4/14/2022	10:02	P	< 1.00	P	< 1.00
22-OBA-01-WF-89.1	WF	Water fountain with filter and cooler	160	4/14/2022	10:02	P	< 1.00	P	< 1.00
22-OBA-01-KF-90	KF	Kitchen faucets	158	4/14/2022	10:14	P	6.77	P	< 1.00
22-OBA-01-KF-91	KF	Kitchen faucets	158	4/14/2022	10:15	P	1.42	P	< 1.00
22-OBA-01-KF-92	KF	Kitchen faucets	158	4/14/2022	10:15	P	< 1.00	P	1.73
22-OBA-01-WF-101	WF	Water fountain with filter and cooler	100	4/14/2022	10:16	P	< 1.00	P	< 1.00
22-OBA-01-WF-102	WF	Water fountain with filter and cooler	100	4/14/2022	10:17	P	< 1.00	P	< 1.00
22-OBA-01-WF-103	WF	Water fountain with filter and cooler	Pool	4/14/2022	10:25	P	< 1.00	P	< 1.00
22-OBA-01-WF-106	WF	Water fountain with filter and cooler	100B	4/14/2022	10:26	P	< 1.00	P	< 1.00
22-OBA-01-WF-107	WF	Water fountain with filter and cooler	100B	4/14/2022	10:27	P	< 1.00	P	< 1.00
22-OBA-01-CF-108	CF	Classroom faucets	163	4/14/2022	10:34	P	2.89	P	< 1.00
22-OBA-01-CF-109	CF	Classroom faucets	163	4/14/2022	10:35	P	2.93	P	< 1.00
22-OBA-01-CF-110	CF	Classroom faucets	163	4/14/2022	10:36	P	12.5	P	< 1.00
22-OBA-01-CF-111	CF	Classroom faucets	153	4/14/2022	10:37	F	19.8	P	1.29
22-OBA-01-KF-112	KF	Kitchen faucets	138	4/14/2022	9:54	F	26.4	P	1.61
22-OBA-02-WF-114	WF	Water fountain with filter and cooler	200A	4/14/2022	10:49	P	< 1.00	P	< 1.00
22-OBA-02-WF-115	WF	Water fountain with filter and cooler	200A	4/14/2022	10:50	P	< 1.00	P	< 1.00
22-OBA-02-CF-118	CF	Classroom faucets	240	4/14/2022	10:54	P	< 1.00	P	< 1.00
22-OBA-02-CF-119	CF	Classroom faucets	238	4/14/2022	10:55	F	26.6	P	1.02
22-OBA-02-CF-120	CF	Classroom faucets	224	4/14/2022	10:57	P	1.96	P	< 1.00
22-OBA-02-CF-121	CF	Classroom faucets	224	4/14/2022	10:58	P	2.94	P	< 1.00
22-OBA-02-CF-122	CF	Classroom faucets	224	4/14/2022	10:59	P	2.48	P	< 1.00
22-OBA-02-CF-123	CF	Classroom faucets	224	4/14/2022	11:00	P	6.4	P	< 1.00
22-OBA-02-WF-126	WF	Water fountain with filter and cooler	200	4/14/2022	11:05	P	< 1.00	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-OBA-02-WF-127	WF	Water fountain with filter and cooler	200	4/14/2022	11:06	P	< 1.00	P	< 1.00
22-OBA-02-NF-128.3	NF	Nurse's office faucet	246/248	4/14/2022	11:19	P	< 1.00	P	< 1.00
22-OBA-02-GF-128.4	GF	Filtered Glass Filler	246/248	4/14/2022	11:20	P	< 1.00	P	< 1.00
22-OBA-02-NF-128.5	NF	Nurse's office faucet	246/248	4/14/2022	11:21	P	4.58	P	< 1.00
22-OBA-02-NF-128.6	NF	Nurse's office faucet	246/248	4/14/2022	11:23	P	8.75	P	1.22
22-OBA-02-NF-128.7	NF	Nurse's office faucet	246/248	4/14/2022	11:24	P	2.72	P	< 1.00
22-OBA-02-TF-129	TF	Teacher's lounge sinks	205	4/14/2022	11:28	P	3.9	P	< 1.00
22-OBA-02-WF-137	WF	Water fountain with filter and cooler	200B	4/14/2022	11:30	P	< 1.00	P	< 1.00
22-OBA-02-WF-138	WF	Water fountain with filter and cooler	200B	4/14/2022	11:31	P	< 1.00	P	< 1.00
22-OBA-03-WF-166	WF	Water fountain with filter and cooler	3008	4/14/2022	11:39	P	< 1.00	P	< 1.00
22-OBA-03-WF-167	WF	Water fountain with filter and cooler	3008	4/14/2022	11:40	P	< 1.00	P	< 1.00
22-OBA-03-CF-193	CF	Classroom faucets	305	4/14/2022	11:40	F	16.5	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Oliver Field House

Lead in Drinking Water Sample Results
 Drinking Water Quality Initiative 2022

School: Pittsburgh Oliver Fieldhouse

Address: 2323 Brighton Road Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-OFH-GF-WM-00	WM	Water Main	Heater Room	8/19/2022	8:25	P	< 1.00	N/A	N/A
22-OFH-GF-SL-00	SL	Service Line	Heater Room	8/19/2022	8:30	P	< 1.00	N/A	N/A
22-OFH-GF-WF-263	WF	Water fountain with filter & cooler	Outside	8/19/2022	8:31	P	< 1.00	P	< 1.00
22-OFH-GF-FF-271	FF	Field House sink faucets	Trainer's Room	8/19/2022	8:20	P	1.58	P	1.7
22-OFH-GH-WF-263.5	WF	Water fountain with filter & cooler	Outside	8/19/2022	8:32	P	< 1.00	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Oliver

Lead in Drinking Water Sample Results
 Drinking Water Quality Initiative 2022

School: Oliver Citywide Academy

Address: 2323 Brighton Road Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-OLI-GF-WM-00	WM	Water Main	Under stair I	8/19/2022	08:17	P	< 1.00	N/A	N/A
22-OLI-GF-SL-00	SL	Service Line	Under stair I	8/19/2022	08:22	P	1.17	N/A	N/A
22-OLI-BS-MS-15	MS	Miscellaneous sinks	P26	8/19/2022	08:33	F	35.1	P	5.2
22-OLI-BS-WF-24	WF	Water fountain with filter and cooler	P30	8/19/2022	08:41	P	< 1.00	P	< 1.00
22-OLI-BS-WF-28	WF	Water fountain with filter and cooler	P44	8/19/2022	08:42	P	< 1.00	P	< 1.00
22-OLI-BS-WC-29	WC	Water fountain with cooler	B91	8/19/2022	08:52	P	< 1.00	P	< 1.00
22-OLI-GF-WF-35	WF	Water fountain with filter and cooler	Corridor by G41	8/19/2022	08:58	P	< 1.00	P	< 1.00
22-OLI-GF-WF-36	WF	Water fountain with filter and cooler	Corridor by G41	8/19/2022	08:59	P	< 1.00	P	< 1.00
22-OLI-GF-CF-38	CF	Classroom faucets	G64	8/19/2022	09:03	P	3.27	P	< 1.00
22-OLI-GF-CF-41	CF	Classroom faucets	G66	8/19/2022	09:05	F	919	F	215
22-OLI-GF-KF-44	KF	Kitchen faucets	G01	8/19/2022	09:14	P	< 1.00	P	< 1.00
22-OLI-GF-CF-47	CF	Classroom faucets	G04	8/19/2022	09:28	P	2.55	P	< 1.00
22-OLI-GF-WF-48	WF	Water fountain with filter and cooler	G04	8/19/2022	09:29	P	< 1.00	P	< 1.00
22-OLI-GF-WF-57	WF	Water fountain with filter and cooler	Corridor by G09	8/19/2022	09:34	P	< 1.00	P	< 1.00
22-OLI-GF-WF-58	WF	Water fountain with filter and cooler	Corridor by G09	8/19/2022	09:35	P	< 1.00	P	< 1.00
22-OLI-GF-OF-59	OF	Office sink faucets	G12	8/19/2022	09:36	P	6.52	P	3.66
22-OLI-GF-HF-64	HF	Home economics faucets (with cooking)	G14	8/19/2022	09:41	P	4.51	P	8.34
22-OLI-GF-HF-65	HF	Home economics faucets (with cooking)	G14A	8/19/2022	09:42	P	< 1.00	P	1.03
22-OLI-GF-CF-67	CF	Classroom faucets	G15	8/19/2022	09:43	P	3.35	P	1.54
22-OLI-GF-CF-68	CF	Classroom faucets	G15	8/19/2022	09:44	P	1.78	P	1.57
22-OLI-GF-CF-69	CF	Classroom faucets	G16	8/19/2022	09:46	P	3.66	P	4.1
22-OLI-GF-CF-70	CF	Classroom faucets	G16	8/19/2022	09:47	P	4.82	P	1.7
22-OLI-GF-WF-80	WF	Water fountain with filter and cooler	Outside G24	8/19/2022	09:51	P	< 1.00	P	< 1.00
22-OLI-GF-WF-81	WF	Water fountain with filter and cooler	Outside G24	8/19/2022	09:52	P	< 1.00	P	< 1.00
22-OLI-GF-WF-97	WF	Water fountain without cooler	Outside G30	8/19/2022	09:53	P	< 1.00	P	< 1.00
22-OLI-GF-WF-98	WF	Water fountain without cooler	Outside G30	8/19/2022	09:54	P	< 1.00	P	< 1.00
22-OLI-GF-WF-108	WF	Water fountain with filter and cooler	Outside G40	8/19/2022	09:58	P	< 1.00	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-OLI-GF-WF-109	WF	Water fountain with filter and cooler	Outside G40	8/19/2022	09:59	P	< 1.00	P	< 1.00
22-OLI-GF-WF-110	WF	Water fountain with filter and cooler	G44	8/19/2022	10:02	P	< 1.00	P	< 1.00
22-OLI-GF-WF-111	WF	Water fountain with filter and cooler	G44	8/19/2022	10:03	P	< 1.00	P	< 1.00
22-OLI-GF-KF-120	KF	Kitchen faucets	G58D	8/19/2022	10:06	P	3.5	P	< 1.00
22-OLI-GF-OF-122	OF	Office sink faucets	G58	8/19/2022	10:08	F	19.5	P	6.1
22-OLI-GF-WF-123	WF	Water fountain with filter and cooler	G17	8/19/2022	10:13	P	< 1.00	P	< 1.00
22-OLI-GF-WF-125	WF	Water fountain with filter and cooler	G17	8/19/2022	10:16	P	< 1.00	P	< 1.00
22-OLI-GF-KF-126	KF	Kitchen faucets	G01C	8/19/2022	10:19	P	4.76	P	< 1.00
22-OLI-GF-KF-127	KF	Kitchen faucets	G01C	8/19/2022	10:20	P	2.99	P	< 1.00
22-OLI-01-CF-130	CF	Classroom faucets	152	8/19/2022	10:33	F	15.5	P	2.68
22-OLI-01-WF-131	WF	Water fountain with filter and cooler	Outside 143A	8/19/2022	10:34	P	< 1.00	P	< 1.00
22-OLI-01-WF-132	WF	Water fountain with filter and cooler	Outside 143A	8/19/2022	10:35	P	< 1.00	P	< 1.00
22-OLI-01-NF-134	NF	Nurse's office sink faucets	154A	8/19/2022	10:40	P	6.28	P	< 1.00
22-OLI-01-TF-136	TF	Teacher's lounge sinks	100C	8/19/2022	10:46	P	5.53	P	1.26
22-OLI-01-CF-137	CF	Classroom faucets	103	8/19/2022	10:49	P	3.74	P	1.1
22-OLI-01-WF-144	WF	Water fountain with filter and cooler	111	8/19/2022	10:50	P	< 1.00	P	< 1.00
22-OLI-01-CF-149	CF	Classroom faucets	108	8/19/2022	10:54	P	9.83	P	1.47
22-OLI-01-CF-150	CF	Classroom faucets	108A	8/19/2022	10:55	P	7.69	P	2.01
22-OLI-01-CF-152	CF	Classroom faucets	123A	8/19/2022	11:02	P	2.55	P	2.38
22-OLI-01-CF-159	CF	Classroom faucets	125	8/19/2022	11:05	P	5.13	P	3.56
22-OLI-01-WF-162	WF	Water fountain with filter and cooler	Outside 122	8/19/2022	11:13	P	< 1.00	P	< 1.00
22-OLI-01-WF-163	WF	Water fountain with filter and cooler	Outside 122	8/19/2022	11:14	P	< 1.00	P	< 1.00
22-OLI-01-CF-214	CF	Classroom faucets	136	8/19/2022	11:19	P	14.1	P	7.38
22-OLI-01-OF-218	OF	Office sink faucets	121C	8/19/2022	11:25	P	5.82	P	12.1
22-OLI-02-WF-222	WF	Water fountain with filter and cooler	Outside A	8/19/2022	11:37	P	< 1.00	P	< 1.00
22-OLI-02-MC-225	MC	Sink faucet (Culinary Arts - not in use)	200B	8/19/2022	11:39	P	5.38	P	6.39
22-OLI-02-KF-233	KF	Sink faucet (Culinary Arts - not in use)	202	8/19/2022	11:47	P	5.97	P	14.9
22-OLI-02-KF-237	KF	Sink faucet (Culinary Arts - not in use)	202	8/19/2022	11:47	P	12.8	P	9.2
22-OLI-02-OF-246	OF	Office sink faucets	209A	8/19/2022	11:53	P	2.17	P	< 1.00
22-OLI-02-WF-256	WF	Water fountain with filter and cooler	Outside 244	8/19/2022	12:05	P	< 1.00	P	< 1.00
22-OLI-02-WF-257	WF	Water fountain with filter and cooler	Outside 244	8/19/2022	12:06	P	< 1.00	P	< 1.00
22-OLI-02-TF-261	TF	Teacher's lounge sinks	246	8/19/2022	12:07	P	2.84	P	4.11

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-OLI-GF-WF-266	WF	Water fountain with filter and cooler	G17	8/19/2022	10:17	P	< 1.00	P	< 1.00
22-OLI-GF-WF-267	WF	Water fountain with filter and cooler	G17	8/19/2022	10:14	P	< 1.00	P	< 1.00
22-OLI-GF-KF-128	KF	Kitchen faucets	G17	8/19/2022	10:21	F	17.7	P	< 1.00
22-OLI-01-GF-134.5	GF	Glass filler with filter	154A	8/19/2022	10:42	P	< 1.00	P	< 1.00
22-OLI-02-WF-251	WF	Water fountain with filter and cooler	Hall at 230	8/19/2022	11:59	P	< 1.00	P	< 1.00
22-OLI-02-WF-252	WF	Water fountain with filter and cooler	Hall at 230	8/19/2022	12:00	P	< 1.00	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Phillips K-5

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Phillips K-5

Address: 1901 Sarah Street Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-PHI-01-SL-00	SL	Service Line	Room 112B	6/9/2022	7:30	P	<1.00	N/A	N/A
22-PHI-01-WM-00	WM	Water Main	Room 112B	6/9/2022	7:35	P	<1.00	N/A	N/A
22-PHI-01-WC-07	WC	Water fountain with cooler	Corridor 100	6/9/2022	7:40	P	<1.00	P	<1.00
22-PHI-01-WC-08	WC	Water fountain with cooler	Corridor 100	6/9/2022	7:41	P	<1.00	P	<1.00
22-PHI-01-CF-10	CF	Classroom faucets	Room 106	6/9/2022	7:44	P	<1.00	P	<1.00
22-PHI-01-NF-13	NF	Nurse's office sink faucets	Doc Rm. 101	6/9/2022	7:49	P	<1.00	P	<1.00
22-PHI-02-WC-17	WC	Water fountain with cooler	Corridor 200	6/9/2022	7:58	P	<1.00	P	<1.00
22-PHI-02-WC-18	WC	Water fountain with cooler	Corridor 200	6/9/2022	7:59	P	<1.00	P	<1.00
22-PHI-02-TF-20	TF	Teacher's lounge sinks	Room 202	6/9/2022	8:02	P	<1.00	P	<1.00
22-PHI-02-WF-27	WF	Water fountain with filter & cooler	Corridor 200	6/9/2022	8:04	P	<1.00	P	<1.00
22-PHI-02-WF-28	WF	Water fountain with filter & cooler	Corridor 200	6/9/2022	8:05	P	<1.00	P	<1.00
22-PHI-01-WF-31	WF	Water fountain with filter & cooler	Corridor 100	6/9/2022	7:42	P	<1.00	P	<1.00
22-PHI-01-WF-32	WF	Water fountain with filter & cooler	Corridor 100	6/9/2022	7:43	P	<1.00	P	<1.00
22-PHI-01-KF-36	KF	Kitchen faucet	Kitchen 112	6/9/2022	7:35	P	<1.00	P	<1.00
22-PHI-01-KF-35	KF	Kitchen faucet	Kitchen 112	6/9/2022	7:20	P	<1.00	P	<1.00

P - Passed water sample result

F - Failed water sample result

Roosevelt PreK-1

Lead in Drinking Water Sample Results
 Drinking Water Quality Initiative 2022

School: Roosevelt PreK-1

Address: 200 The Boulevard, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-ROS-01-SL-00	SL	Service Line	Outside - Adjacent Rm 105	4/28/2022	7:16	<1.00	P	N/A	N/A
22-ROS-01-WM-00	WM	Water Main	Outside - Adjacent Rm 105	4/28/2022	7:11	<1.00	P	N/A	N/A
22-ROS-01-KF-02	KF	Kitchen faucets	Teacher's Room 106	4/28/2022	7:17	<1.00	P	<1.00	P
22-ROS-01-CF-11	CF	Classroom faucets	Classrom 105	4/28/2022	7:19	1.38	P	<1.00	P
22-ROS-01-WF-12	WF	Water fountain with filter and cooler	Outside Room 103/130	4/28/2022	7:21	<1.00	P	<1.00	P
22-ROS-01-WF-13	WF	WaterFountain with filter and cooler	Outside Room 103/130	4/28/2022	7:22	<1.00	P	<1.00	P
22-ROS-01-MC-16	MC	Multi- Purpose Room/Cafeteria faucets	Multi-Purpose 101	4/28/2022	7:26	<1.00	P	<1.00	P
22-ROS-01-CF-20	CF	Classroom faucets	Kindergarten 102	4/28/2022	7:29	<1.00	P	<1.00	P

P - Passed water sample result

F - Failed water sample result

Schiller 6-8

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Schiller 6-8

Address: 1018 Peralta Street, Pittsburgh, PA

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-SCH-01-WM-00	WM	Water Main	Storage 115-A	6/28/2022	7:05	P	<1.00	N/A	N/A
22-SCH-01-SL-00	SL	Service Line	Storage 115-A	6/28/2022	7:10	P	<1.00	N/A	N/A
22-SCH-01-KF-02	KF	Kitchen faucets	122-A	6/28/2022	7:17	P	<1.00	P	<1.00
22-SCH-01-KF-03	KF	Kitchen faucets	122-A	6/28/2022	7:18	P	<1.00	P	<1.00
22-SCH-GF-CF-06	CF	Classroom faucets	004	6/28/2022	7:15	P	3.74	P	<1.00
22-SCH-02-CF-10	CF	Classroom faucets	216	6/28/2022	7:45	P	3.41	P	<1.00
22-SCH-02-CF-14	CF	Classroom faucets	213	6/28/2022	7:50	P	3.14	P	2.85
22-SCH-02-CF-15	CF	Classroom faucets	213	6/28/2022	7:51	P	4.14	P	1.47
22-SCH-02-CF-16	CF	Classroom faucets	213	6/28/2022	7:52	P	3.45	P	2.57
22-SCH-02-CF-17	CF	Classroom faucets	211	6/28/2022	7:53	P	<1.00	P	<1.00
22-SCH-02-WF-19	WF	Water fountain with filter and cooler	Corridor 200	6/28/2022	7:54	P	<1.00	P	<1.00
22-SCH-02-WF-20	WF	Water fountain with filter and cooler	Corridor 200	6/28/2022	7:55	P	<1.00	P	<1.00
22-SCH-02-CF-23	CF	Classroom faucets	209	6/28/2022	8:00	P	12.20	P	<1.00
22-SCH-02-WF-25	WF	Water fountain with filter and cooler	Corridor 200	6/28/2022	8:06	P	<1.00	P	<1.00
22-SCH-02-WF-26	WF	Water fountain with filter and cooler	Corridor 200	6/28/2022	8:07	P	<1.00	P	<1.00
22-SCH-01-WF-31	WF	Water fountain with filter and cooler	Corridor 100	6/28/2022	7:26	P	<1.00	P	<1.00
22-SCH-01-WF-32	WF	Water fountain with filter and cooler	Corridor 100	6/28/2022	7:27	P	<1.00	P	<1.00
22-SCH-01-WF-36	WF	Water fountain with filter and cooler	Hallway	6/28/2022	7:30	P	<1.00	P	<1.00
22-SCH-01-WF-37	WF	Water fountain with filter and cooler	Hallway	6/28/2022	7:31	P	<1.00	P	<1.00
22-SCH-01-TF-43	TF	Teacher's lounge sinks	103	6/28/2022	7:33	P	2.27	P	<1.00
22-SCH-01-OF-46	OF	Office sink faucets	101	6/28/2022	7:34	F	16.3	P	3.36
22-SCH-01-KF-49	KF	Kitchen faucets	120	6/28/2022	7:37	P	4.23	P	3.19

P - Passed water sample result
F - Failed water sample result

Spring Garden Early Childhood Center

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Spring Garden ECC

Address: 1501 Spring Garden Ave, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
22-SPG-BS-SL-00	SL	Service Line	B-8	4/19/2022	6:14	P	< 1.00	N/A	N/A
22-SPG-BS-WM-00	WM	Water Main	B-8	4/19/2022	6:09	P	< 1.00	N/A	N/A
22-SPG-01-WF-02	WF	Water fountain with cooler	Outside Boys Toilet (106)	4/19/2022	6:16	P	< 1.00	P	< 1.00
22-SPG-01-WF-03	WF	Water fountain with cooler	Outside Boys Toilet (106)	4/19/2022	6:17	P	< 1.00	P	< 1.00
22-SPG-01-KF-09	KF	Kitchen faucets	Room 103-A	4/19/2022	6:26	P	1.31	P	< 1.00
22-SPG-01-WF-14	WF	Water fountain with cooler	Outside Girls Toilet (101)	4/19/2022	6:29	P	< 1.00	P	< 1.00
22-SPG-01-WF-15	WF	Water fountain with cooler	Outside Girls Toilet (101)	4/19/2022	6:30	P	< 1.00	P	< 1.00
22-SPG-01-KF-18	KF	Kitchen faucets	Stage 112-A	4/19/2022	6:31	P	2.85	P	< 1.00
22-SPG-02-WF-23	WF	Water fountain with cooler	Outside Boys Toilet (204)	4/19/2022	6:51	P	< 1.00	P	< 1.00
22-SPG-02-WF-24	WF	Water fountain with cooler	Outside Boys Toilet (204)	4/19/2022	6:52	P	< 1.00	P	< 1.00
22-SPG-02-CF-28	CF	Classroom faucets	Library Room 208	4/19/2022	6:46	P	2.47	P	< 1.00
22-SPG-02-WF-29	WF	Water fountain with cooler	Outside Girls Toilet (201)	4/19/2022	6:38	P	< 1.00	P	< 1.00
22-SPG-02-WF-30	WF	Water fountain with cooler	Outside Girls Toilet (201)	4/19/2022	6:39	P	< 1.00	P	< 1.00
22-SPG-01-CF-33	CF	Water fountain with cooler	Demountable Classroom	4/19/2022	7:06	P	< 1.00	P	< 1.00
22-SPG-01-GF-33.1	GF	Filtered glass filler	Demountable Classroom	4/19/2022	7:05	P	< 1.00	P	< 1.00
22-SPG-01-WB-34	WB	Water fountain with cooler	Demountable Classroom	4/19/2022	7:07	P	< 1.00	P	< 1.00
22-SPG-01-GF-34.1	GF	Filtered glass filler	Demountable Classroom	4/19/2022	7:06	P	< 1.00	P	< 1.00
22-SPG-01-CF-35	CF	Classroom faucets	Demountable Classroom	4/19/2022	7:12	F	52.4	P	< 1.00
22-SPG-01-CF-36	CF	Classroom faucets	Demountable Classroom	4/19/2022	7:11	P	< 1.00	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Spring Hill K-5

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Spring Hill K-5

Address: 1351 Damas Street Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-SRG-BS-WM-00	WM	Water Main	006	6/3/2022	8:35	P	< 1.00	N/A	N/A
22-SRG-BS-SL-00	SL	Service Line	006	6/3/2022	8:30	P	< 1.00	N/A	N/A
22-SRG-BS-CF-04	CF	Classroom faucets	007	6/3/2022	8:36	P	4.36	P	< 1.00
22-SRG-BS-KF-05	KF	Kitchen faucets	001	6/3/2022	8:38	P	2.29	P	< 1.00
22-SRG-BS-CF-07	CF	Classroom faucets	010	6/3/2022	8:39	P	2.57	P	< 1.00
22-SRG-BS-CF-08	CF	Classroom faucets	011	6/3/2022	8:40	P	1.29	P	< 1.00
22-SRG-BS-CF-09	CF	Classroom faucets	011	6/3/2022	8:41	P	< 1.00	P	< 1.00
22-SRG-BS-WF-12	WF	Water fountain with filter and cooler	008	6/3/2022	8:42	P	< 1.00	P	< 1.00
22-SRG-BS-WF-13	WF	Water fountain with filter and cooler	008	6/3/2022	8:43	P	< 1.00	P	< 1.00
22-SRG-01-WF-20	WF	Water fountain with filter and cooler	129	6/3/2022	8:50	P	< 1.00	P	< 1.00
22-SRG-01-WF-21	WF	Water fountain with filter and cooler	129	6/3/2022	8:51	P	< 1.00	P	< 1.00
22-SRG-01-TF-22	TF	Teacher's lounge sinks	135	6/3/2022	8:52	P	< 1.00	P	< 1.00
22-SRG-01-NF-31	NF	Nurse's office sink faucets	104	6/3/2022	8:54	P	6.79	P	< 1.00
22-SRG-01-WF-33	WF	Water fountain with filter and cooler	Hallway	6/3/2022	8:56	P	< 1.00	P	< 1.00
22-SRG-01-WF-34	WF	Water fountain with filter and cooler	Hallway	6/3/2022	8:57	P	< 1.00	P	< 1.00
22-SRG-02-CF-35	CF	Classroom faucets	219	6/3/2022	8:59	F	107	P	12.8
22-SRG-02-CF-36	CF	Classroom faucets	219	6/3/2022	9:00	P	< 1.00	P	< 1.00
22-SRG-02-CF-37	CF	Classroom faucets	201	6/3/2022	9:01	P	11.7	P	1.00
22-SRG-02-CF-38	CF	Classroom faucets	210	6/3/2022	9:02	P	4.62	P	1.59
22-SRG-02-CF-39	CF	Classroom faucets	210	6/3/2022	9:04	P	1.46	P	< 1.00
22-SRG-02-WF-40	WF	Water fountain with filter and cooler	208	6/3/2022	9:05	P	< 1.00	P	< 1.00
22-SRG-02-WF-41	WF	Water fountain with filter and cooler	208	6/3/2022	9:06	P	< 1.00	P	< 1.00

P - Passed water sample result

F - Failed water sample result

Student Achievement Center

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Student Achievement Center

Address: 925 Brushton Ave., Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-SAC-BS-WM-00	WM	Water Main	21	6/14/2022	06:09	P	1.63	N/A	N/A
22-SAC-SB-SL-00	SL	Service Line	B-1	6/14/2022	06:14	P	2.15	N/A	N/A
22-SAC-BS-KF-03	KF	Kitchen faucets	27	6/14/2022	06:15	P	7.47	P	8.96
22-SAC-BS-KF-04	KF	Kitchen faucets	27	6/14/2022	06:16	P	9.17	P	7.70
22-SAC-01-WF-13	WF	Water fountain with filter and cooler	120	6/14/2022	06:19	P	< 1.00	P	< 1.00
22-SAC-01-WF-14	WF	Water fountain with filter and cooler	120	6/14/2022	06:20	P	< 1.00	P	< 1.00
22-SAC-01-NF-21	NF	Nurse's office sink faucets	119A	6/14/2022	06:21	P	< 1.00	P	< 1.00
22-SAC-01-WC-22	WC	Water fountain with cooler	120	6/14/2022	06:23	P	< 1.00	P	< 1.00
22-SAC-01-WC-23	WC	Water fountain with cooler	121	6/14/2022	06:24	P	< 1.00	P	< 1.00
22-SAC-02-WF-29	WC	Water fountain with filter and cooler	CORRIDOR 200	6/14/2022	06:32	P	< 1.00	P	< 1.00
22-SAC-02-WF-30	WC	Water fountain with filter and cooler	CORRIDOR 200	6/14/2022	06:33	P	< 1.00	P	< 1.00
22-SAC-02-TF-33	TF	Teacher's lounge sinks	206	6/14/2022	06:36	P	4.47	P	< 1.00
22-SAC-02-OF-34	OF	Office sink faucets	205	6/14/2022	06:41	P	10.5	P	8.30
22-SAC-02-CF-36	CF	Classroom faucets	203	6/14/2022	06:42	F	15.6	P	2.18
22-SAC-02-CF-40	CF	Classroom faucets	210B	6/14/2022	06:45	F	137	P	4.06
22-SAC-02-WC-45	WC	Water fountain with cooler	220	6/14/2022	06:46	P	< 1.00	P	< 1.00
22-SAC-02-WC-46	WC	Water fountain with cooler	221	6/14/2022	06:47	P	< 1.00	P	< 1.00
22-SAC-03-WC-54	WC	Water fountain with cooler	332	6/14/2022	06:52	F	15.6	P	10.9
22-SAC-03-WF-59	WF	Water fountain with filter and cooler	300	6/14/2022	06:54	P	< 1.00	P	< 1.00
22-SAC-03-WF-60	WF	Water fountain with filter and cooler	300	6/14/2022	06:55	P	< 1.00	P	< 1.00
22-SAC-03-HF-61	HF	Home economics faucets (with cooking)	303	6/14/2022	07:02	P	1.51	P	< 1.00
22-SAC-03-HF-62	HF	Home economics faucets (with cooking)	303	6/14/2022	07:03	P	3.10	P	1.84
22-SAC-03-HF-63	HF	Home economics faucets (with cooking)	303	6/14/2022	07:04	P	1.41	P	1.44
22-SAC-03-TF-64	TF	Teacher's lounge sinks	301	6/14/2022	07:06	P	13.5	P	3.95
22-SAC-BS-KF-65	KF	Kitchen faucets	27	6/14/2022	06:17	P	2.30	P	6.55

P - Passed water sample result
F - Failed water sample result

Westwood PreK-5

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Westwood K-5

Address: 508 Shadyhill Road Pittsburgh, PA 15205

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-WWD-GF-SL-00	SL	Service Line	115	4/26/2022	6:32	P	< 1.00	N/A	N/A
22-WWD-GF-WM-00	WM	Water Main	115	4/26/2022	6:27	P	< 1.00	N/A	N/A
22-WWD-GF-NF-01	NF	Nurse's office faucet	108D	4/26/2022	6:20	P	3.07	P	< 1.00
22-WWD-GF-NF-02	NF	Nurse's office faucet	108D	4/26/2022	6:34	P	1.01	P	< 1.00
22-WWD-GF-GF-2.1	GF	Filtered Glass Filler	108C	4/26/2022	6:35	P	< 1.00	P	< 1.00
22-WWD-GF-CF-04	CF	Classroom faucets	106	4/26/2022	6:43	P	2.43	P	< 1.00
22-WWD-GF-WF-06	WF	Water fountain with filter & cooler	110C	4/26/2022	6:43	P	< 1.00	P	< 1.00
22-WWD-GF-WF-07	WF	Water fountain with filter & cooler	110C	4/26/2022	6:44	P	< 1.00	P	< 1.00
22-WWD-GF-TF-11	TF	Teacher's lounge sinks	109	4/26/2022	6:46	P	6.1	P	< 1.00
22-WWD-GF-CF-13	CF	Classroom faucets	104	4/26/2022	6:50	F	24.1	P	9.67
22-WWD-GF-WF-16	WF	Water fountain with filter & cooler	110	4/26/2022	6:52	P	< 1.00	P	< 1.00
22-WWD-GF-WF-17	WF	Water fountain with filter & cooler	110	4/26/2022	6:53	P	< 1.00	P	< 1.00
22-WWD-GF-CF-27	CF	Classroom faucets	102	4/26/2022	6:57	P	3.01	P	< 1.00
22-WWD-GF-CF-31	CF	Classroom faucets	100	4/26/2022	6:58	P	2.43	P	< 1.00
22-WWD-GF-CF-32	CF	Classroom faucets	127	4/26/2022	7:03	P	< 1.00	P	< 1.00
22-WWD-GF-CF-33	CF	Classroom faucets	127	4/26/2022	7:04	P	< 1.00	P	< 1.00
22-WWD-GF-CF-33.1	CF	Classroom faucets	127	4/26/2022	7:05	P	< 1.00	P	< 1.00
22-WWD-01-WF-34	WF	Water fountain with filter & cooler	Corridor 200	4/26/2022	7:19	P	< 1.00	P	< 1.00
22-WWD-01-WF-35	WF	Water fountain with filter & cooler	Corridor 200	4/26/2022	7:20	P	< 1.00	P	< 1.00
22-WWD-01-CF-36	CF	Classroom faucets	208	4/26/2022	7:21	P	1.86	P	< 1.00
22-WWD-01-CF-37	CF	Classroom faucets	206	4/26/2022	7:22	P	2.44	P	< 1.00
22-WWD-01-CF-38	CF	Classroom faucets	209	4/26/2022	7:24	P	< 1.00	P	< 1.00
22-WWD-01-CF-42	CF	Classroom faucets	204	4/26/2022	7:29	P	8.13	P	4.95
22-WWD-01-WF-50	WF	Water fountain with filter & cooler	Corridor 200 C	4/26/2022	7:30	P	< 1.00	P	< 1.00
22-WWD-01-WF-51	WF	Water fountain with filter & cooler	Corridor 200 C	4/26/2022	7:31	P	< 1.00	P	< 1.00
22-WWD-01-KF-57	KF	Kitchen faucets	221	4/26/2022	7:33	P	< 1.00	P	< 1.00
22-WWD-01-CF-59	CF	Classroom faucets	202	4/26/2022	7:43	P	1.84	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-WWD-01-CF-60	CF	Classroom faucets	201	4/26/2022	7:46	P	1.21	P	< 1.00
22-WWD-01-GF-61	GF	Filtered Glass Filler	201	4/26/2022	7:47	P	< 1.00	P	< 1.00
22-WWD-01-CF-62	CF	Classroom faucets	201A	4/26/2022	7:48	P	< 1.00	P	< 1.00
22-WWD-01-GF-63	GF	Filtered Glass Filler	201A	4/26/2022	7:49	P	< 1.00	P	< 1.00
22-WWD-01-OF-64	OF	Office sink faucets	222-A	4/26/2022	7:54	P	7.23	P	11.6

P - Passed water sample result

F - Failed water sample result

Whittier K-5

Lead in Drinking Water Sample Results
Drinking Water Quality Initiative 2022

School: Pittsburgh Whittier K-5

Address: 150 Meridan Street Pittsburgh, PA 15211

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-WHI-SB-SL-00	SL	Service Line	B-1	6/7/2022	6:15	P	<1.00	N/A	N/A
22-WHI-SB-WM-00	WM	Water Main	B-1	6/7/2022	6:10	P	<1.00	N/A	N/A
22-WHI-BS-OF-02	OF	Office sink faucets	10	6/7/2022	6:05	P	<1.00	P	<1.00
22-WHI-BS-CF-03	CF	Classroom faucets	9	6/7/2022	6:16	P	1.64	P	<1.00
22-WHI-BS-WF-05	WF	Water fountain with filter & cooler	Bottom of Stairs	6/7/2022	6:18	P	<1.00	P	<1.00
22-WHI-01-WF-09	WF	Water fountain with filter & cooler	Outside Boys	6/7/2022	6:21	P	<1.00	P	<1.00
22-WHI-01-WF-12	WC	Water fountain with cooler	Boys	6/7/2022	6:22	P	<1.00	P	<1.00
22-WHI-01-NF-16	NF	Nurse's office sink faucets	114	6/7/2022	6:25	P	3.91	P	1.21
22-WHI-01-OF-19	OF	Office sink faucets	107	6/7/2022	6:28	P	4.6	P	<1.00
22-WHI-01-KF-20	KF	Kitchen faucets	Kitchen	6/7/2022	6:29	P	3.24	P	1.23
22-WHI-01-CF-22	CF	Classroom faucets	103	6/7/2022	6:32	P	3.74	P	<1.00
22-WHI-01-WF-23	WF	Water fountain with filter & cooler	Girls	6/7/2022	6:32	P	<1.00	P	<1.00
22-WHI-01-WC-25	WC	Water fountain with cooler	Outside Girls	6/7/2022	6:37	P	<1.00	P	<1.00
22-WHI-01-CF-29	CF	Classroom faucets	102	6/7/2022	6:38	F	19.6	P	2.75
22-WHI-01-CF-30	CF	Classroom faucets	102	6/7/2022	6:39	F	52.0	P	13.4
22-WHI-01-OF-33	OF	Office sink faucets	101B	6/7/2022	6:40	P	2.29	P	<1.00
22-WHI-02-CF-34	CF	Classroom faucets	205	6/7/2022	6:46	P	2.9	P	<1.00
22-WHI-02-CF-35	CF	Classroom faucets	205	6/7/2022	6:47	P	1.9	P	<1.00
22-WHI-02-WF-36	WF	Water fountain with filter & cooler	Outside Boys	6/7/2022	6:51	P	<1.00	P	<1.00
22-WHI-02-WF-39	WF	Water fountain with filter & cooler	200BT	6/7/2022	6:54	P	<1.00	P	<1.00
22-WHI-02-CF-41	CF	Classroom faucets	208	6/7/2022	6:55	P	<1.00	P	<1.00
22-WHI-02-TF-43	TF	Teacher's lounge sinks	209	6/7/2022	6:58	P	1.87	P	<1.00
22-WHI-02-WF-44	WF	Water fountain with filter & cooler	200GT	6/7/2022	6:59	P	<1.00	P	<1.00
22-WHI-02-WC-46	WC	Water fountain with cooler	Outside Girls	6/7/2022	7:00	P	<1.00	P	<1.00

22-WHI-02-CF-50	CF	Classroom faucets	202	6/7/2022	7:01	P	1.1	P	<1.00
-----------------	----	-------------------	-----	----------	------	---	-----	---	-------

P - Passed water sample result

F - Failed water sample result

Woolslair K-5

Lead in Drinking Water Sample Results
Drinking Water Quality Results 2022

School: Pittsburgh Woolslair K-5

Address: 501 40th Street Pittsburgh, PA 15224

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-WOL-BS-SL-00	SL	Service Line	G1C	5/12/2022	06:36	P	< 1.00	N/A	N/A
22-WOL-BS-WM-00	WM	Water Main	G1C	5/12/2022	06:31	P	< 1.00	N/A	N/A
22-WOL-BS-WF-01	WF	Water fountain with filter & cooler	B1A	5/12/2022	06:24	P	< 1.00	P	< 1.00
22-WOL-BS-WF-02	WF	Water fountain with filter & cooler	B1A	5/12/2022	06:25	P	< 1.00	P	< 1.00
22-WOL-BS-NF-03	NF	Nurse's office sink faucets	G14	5/12/2022	06:26	P	2.94	P	< 1.00
22-WOL-BS-KF-04	KF	Kitchen faucets	G10	5/12/2022	06:37	P	1.97	P	< 1.00
22-WOL-BS-KF-05	KF	Kitchen faucets	G10	5/12/2022	06:38	P	5.19	P	1.48
22-WOL-BS-CF-11	CF	Classroom faucets	G3	5/12/2022	06:39	P	4.53	P	< 1.00
22-WOL-BS-CF-14	CF	Classroom faucets	G7	5/12/2022	06:40	P	< 1.00	P	< 1.00
22-WOL-BS-CF-15	CF	Classroom faucets	G6	5/12/2022	06:43	P	< 1.00	P	< 1.00
22-WOL-BS-GF-15.5	GF	Glass filler with filter	G6	5/12/2022	06:44	P	< 1.00	P	< 1.00
22-WOL-BS-WF-16	WF	Water fountain with filter & cooler	B1B	5/12/2022	06:44	P	< 1.00	P	< 1.00
22-WOL-BS-WF-17	WF	Water fountain with filter & cooler	B1B	5/12/2022	06:45	P	< 1.00	P	< 1.00
22-WOL-BS-CF-19	CF	Classroom faucets	G5	5/12/2022	06:47	P	1.14	P	< 1.00
22-WOL-01-WF-20	WF	Water fountain with filter & cooler	100A	5/12/2022	06:53	P	< 1.00	P	< 1.00
22-WOL-01-WF-21	WF	Water fountain with filter & cooler	100A	5/12/2022	06:54	P	< 1.00	P	< 1.00
22-WOL-01-CF-23	CF	Classroom faucets	103	5/12/2022	06:55	P	< 1.00	P	< 1.00
22-WOL-01-CF-24	CF	Classroom faucets	103	5/12/2022	06:56	P	< 1.00	P	< 1.00
22-WOL-01-OF-27	OF	Office sink faucets	110	5/12/2022	06:59	P	2.8	P	< 1.00
22-WOL-01-WF-31	WF	Water fountain with filter & cooler	100B	5/12/2022	07:04	P	< 1.00	P	< 1.00
22-WOL-01-WF-32	WF	Water fountain with filter & cooler	100B	5/12/2022	07:05	P	< 1.00	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
22-WOL-02-CF-34	CF	Classroom faucets	201B	5/12/2022	07:12	F	15.2	P	2.97
22-WOL-02-WF-36	WF	Water fountain with filter & cooler	200A	5/12/2022	07:15	P	< 1.00	P	< 1.00
22-WOL-02-WF-37	WF	Water fountain with filter & cooler	200A	5/12/2022	07:16	P	< 1.00	P	< 1.00
22-WOL-02-CF-38	CF	Classroom faucets	203	5/12/2022	07:17	P	< 1.00	P	< 1.00
22-WOL-02-CF-47	CF	Classroom faucets	207B	5/12/2022	07:21	P	< 1.00	P	< 1.00
22-WOL-02-WF-48	WF	Water fountain with filter & cooler	200B	5/12/2022	07:22	P	< 1.00	P	< 1.00
22-WOL-02-WF-49	WF	Water fountain with filter & cooler	200B	5/12/2022	07:23	P	< 1.00	P	< 1.00

P - Passed water sample result

F - Failed water sample result